

3/25/97 3/26 1PM
12:30

PERMIT

SEWAGE DISPOSAL SYSTEM

DEPARTMENT OF HEALTH AND MENTAL HYGIENE

HOWARD COUNTY HEALTH DEPARTMENT
BUREAU OF ENVIRONMENTAL HEALTH
461-9933

#191253

\$25.00
PAID BY CHECK # 11754 3/25/97

P 58047-A

A _____

DISTRICT 3rd

DATE 3/25/97

DATE SYSTEM APPROVED 3/27/97

INSPECTOR st

INDEXED

Ed Linsenmeyer _____ IS PERMITTED TO INSTALL X ALTER _____

ADDRESS _____ PHONE 992-8172

SUBDIVISION _____ LOT 71 ROAD 9402 Suland Road Circle

PROPERTY OWNER Jose Allulis

ADDRESS 9402 Suland Circle

SEPTIC TANK CAPACITY _____ GALLONS HOUSE HAS PUBLIC WATER, PUBLIC SEWER NOT AVAILABLE

NUMBER OF BEDROOMS 3

125 SQUARE FEET PER BEDROOM

LINEAR FEET OF TRENCH REQUIRED 126 REPAIR:

DRYWELL HAS COLLAPSED, WAS FULL, TO BE ABANDONED AND REPLACED WITH TRENCHES

WIDTH 3' INLET 4' MAX BOTTOM DEPTH 5.5'

1.5' STONE BELOW DIST PIPE

PLANS APPROVED BY [Signature] DATE 3/25/97

COVER NO WORK UNTIL INSPECTED AND APPROVED

NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM

NOTE: CLEANOUT REQUIRED EVERY 70 FEET OF SEWER LINE AND/OR AT 90° SWEEPS IN LINES FROM HOUSE TO DRAIN FIELDS, 90° ELBOWS NOT ACCEPTABLE.

NOTE: ALL PARTS OF SEPTIC SYSTEMS (I.E. TANK, DISTRIBUTION BOX TRENCHES) TO BE 100 FEET FROM WELL (UNLESS OTHERWISE SPECIFICALLY AUTHORIZED)

NOTE: IF DEEP TRENCH(ES) ARE USED CALL FOR INSPECTION BEFORE AND AFTER PLACING GRAVEL IN TRENCH(ES)

NOTE: NO DRY WELL SHALL EXCEED 15 FOOT IN DIAMETER NO ABSORPTION TRENCH TO EXCEED 100 FEET IN LENGTH

NOTE: ALL PIPE FROM HOUSE TO SEPTIC TANK MUST BE CAST IRON OR SCHEDULE 35/40 PVC OR ABS

PERMIT VOID AFTER TWO YEARS

NOTE: INSTALL STAND PIPE ON SEPTIC TANK AND DRY WELL STAND PIPES MUST BE 6 INCHES IN DIAMETER CAST IRON. CONCRETE OR TERRA COTTA OR PVA OR ABS ACCEPTED. IF TOP OF SEPTIC TANK IS DEEPER THAN 3 FEET. MANHOLE TO GRADE REQUIRED.

NOTE: DISTRIBUTION BOXES MUST HAVE BAFFLES

***INSTALLER IS RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT**

HD-260(6-90) *CALL 461-9933 FOR INSPECTION OF SEPTIC SYSTEM.

A 58047-A

