

7/21/97
10:00 & later

PERMIT

SEWAGE DISPOSAL SYSTEM

DEPARTMENT OF HEALTH AND MENTAL HYGIENE

P 58559
REPAIR
A 24786

HOWARD COUNTY HEALTH DEPARTMENT
BUREAU OF ENVIRONMENTAL HEALTH
461-9933

#384575

INDEXED

DISTRICT _____

DATE 7-10-97

DATE SYSTEM APPROVED 7/21/97

INSPECTOR DKS

Olen Ketterman IS PERMITTED TO INSTALL _____ ALTER ☒

ADDRESS 14960 Route 144 Woodbine, Maryland 21797 PHONE 442-1336

SUBDIVISION Allnutt Farms LOT 1 ROAD 13459 Sorghum Ct.

PROPERTY OWNER Mr. and Mrs. Desai

ADDRESS 13459 Sorghum Ct.

SEPTIC TANK CAPACITY EX GALLONS

NUMBER OF BEDROOMS 5

125 SQUARE FEET PER BEDROOM

LINEAR FEET OF TRENCH REQUIRED 90

REPAIR - Septic System has failed.

Call for inspection when ground is opened so sanitarian can recommend repair.

Install trench thru pipe hole @ along contour of d.w.
Trench to be 2' wide, 12' x 4', bottom 11', slope 7'.
Drywell to be maintained; any pipe off d.w.
to be abandoned.

PLANS APPROVED BY M. Ristkin DATE _____

COVER NO WORK UNTIL INSPECTED AND APPROVED

NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM

NOTE: CLEANOUT REQUIRED EVERY 70 FEET OF SEWER LINE AND/OR AT 90° SWEEPS IN LINES FROM HOUSE TO DRAIN FIELDS, 90° ELBOWS NOT ACCEPTABLE.

NOTE: ALL PARTS OF SEPTIC SYSTEMS (I.E. TANK, DISTRIBUTION BOX TRENCHES) TO BE 100 FEET FROM WELL (UNLESS OTHERWISE SPECIFICALLY AUTHORIZED)

NOTE: IF DEEP TRENCH(ES) ARE USED CALL FOR INSPECTION BEFORE AND AFTER PLACING GRAVEL IN TRENCH(ES)

NOTE: NO DRY WELL SHALL EXCEED 15 FOOT IN DIAMETER NO ABSORPTION TRENCH TO EXCEED 100 FEET IN LENGTH

NOTE: ALL PIPE FROM HOUSE TO SEPTIC TANK MUST BE CAST IRON OR SCHEDULE 35/40 PVC OR ABS


PERMIT VOID AFTER TWO YEARS

NOTE: INSTALL STAND PIPE ON SEPTIC TANK AND DRY WELL STAND PIPES MUST BE 6 INCHES IN DIAMETER CAST IRON. CONCRETE OR TERRA COTTA OR PVA OR ABS ACCEPTED. IF TOP OF SEPTIC TANK IS DEEPER THAN 3 FEET. MANHOLE TO GRADE REQUIRED.

NOTE: DISTRIBUTION BOXES MUST HAVE BAFFLES

*INSTALLER IS RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT

58559



①
topsoil
org brn
2 1/2 m
3
pale org
brn
to med
brn
5 1/2 salm
15 10% Ry

INDICATE NORTH - NAME ADJOINING ROADWAY AS BASE LINE

SEPTIC TANK LEVEL Existing Sorghum Court CLEANOUTS one on s.d., one on d.w.

DISTRIBUTION BOX LEVEL N/A

DRAIN FIELD/TITLE DEPTH 11 FT.

TRENCH WIDTH 2 FT.

INLET DEPTH 4 FT.

EFFECTIVE GRAVEL DEPTH 7 FT.

TOTAL LENGTH 91 FT.

NUMBER OF TRENCHES _____

ONE SIDEWALL/BOTTOM AREA 637 SQ. FT.

DRYWALL INSIDE DIAMETER EX FT.

EFFECTIVE DEPTH BELOW INLET EX FT.

ABSORBENT AREA _____ SQ. FT.

REMARKS: 7/21/97 A.M. OK to begin repair trench
as specified. DKS

7/21/97 P.M. FINAL INSP - OK to cover all work.
Pipe found and disconnected from d.w. to area of
overflow. DKS

DATE SYSTEM APPROVED

7/21/97

INSPECTOR

Donna K. Joe



REGION _____

AREA _____ RATING _____

ACKNOWLEDGMENT AND CONTROLS	DATE

Howard County Department of Health
BUREAU OF ENVIRONMENTAL HEALTH

RECORD OF INVESTIGATION

DISPOSITION	DATE
	9/30/97

LOCATION 13459 S Morghum Ct Farms Est. ZIP 924-1000
OWNER ☒ Drew Desai ADDRESS same PHONE 301-854-0331
OCCUPANT ☐ Ludy Callow ADDRESS same PHONE 301-854-0331

COMPLAINANT Ludy Callow ADDRESS same PHONE 301-854-0331

REASON FOR INVESTIGATION Failing septic system for about one year; in right side yard adjacent to woods

RECEIVED BY M. Rifkin DATE 5/8/97 ASSIGNED TO M.R. CODES DATE 5/9

DATE OF INVESTIGATION 5/9/97 TIME 11:00 WEATHER cloudy, showers

REPORT MET OWNER OF PROPERTY @ SITE: SHE ACKNOWLEDGED SEPTIC FAILING ~1 YEAR, AND FLOCK WAS SUPPOSED TO MEET W/HER, BUT "HE NEVER SHOWED"; DESPITE THAT, SHE STILL CLAIMED TO BE "WORKING ON IT", ALTHO SHE HAD NOT CALLED OTHER CONTRACTORS; SHE ALSO DEMANDED TO KNOW WHO COMPLAINED, BUT I ADVISED HER SHE WOULD HAVE TO REQUEST THAT IN WRITING FROM PROG. DIR.; INSP. CONFIRMS LARGE SEWAGE DISCH. (SEE DRAWING); NAMES OF 3 CONTRACTORS ALSO PROVIDED TO OWNER (M); DISCHARGE WET, NOT FLOWING, ~20' x 30' IN DIMENSION; IN REPORTED LOCATION ~60-70' TO RIGHT SIDE OF HOUSE

— TELEPHONE CALL FROM PROPERTY OWNER 3:15 PM;

REQUESTING NAME OF COMPLAINANT — I EXPLAINED TO

HER THAT POLICY WAS TO NOT DISCLOSE IF APPLICANT REQUESTED TO REMAIN ANONYMOUS. CALL

DATE SUBMITTED _____ SANITARIAN _____

ACKNOWLEDGMENT AND CONTROLS	DATE
<u>9/1/97</u>	<u>9/1/97</u>
<u>9/1/97</u>	<u>9/1/97</u>
<u>9/1/97</u>	<u>9/1/97</u>
<u>9/1/97</u>	<u>9/1/97</u>

Howard County Department of Health
 BUREAU OF ENVIRONMENTAL HEALTH

DISPOSITION	DATE
<u>121</u>	<u>9/1/97</u>
<u>121</u>	<u>9/1/97</u>
<u>121</u>	<u>9/1/97</u>
<u>121</u>	<u>9/1/97</u>

RECORD OF INVESTIGATION

LOCATION 11111 11th St, N.W. ZIP 20912
 OWNER Dreadnaught ADDRESS 11111 11th St, N.W. PHONE 301-254-1234
 OCCUPANT Dreadnaught ADDRESS 11111 11th St, N.W. PHONE 301-254-1234
 COMPLAINANT Dreadnaught ADDRESS 11111 11th St, N.W. PHONE 301-254-1234
 REASON FOR INVESTIGATION Septic tank failure

RECEIVED BY M. Rifkin DATE 5/8/97 ASSIGNED TO M. R DATE 5/9

DATE OF INVESTIGATION 5/9/97 TIME 11:00 WEATHER cloudy, showers

REPORT MET OWNER OF PROPERTY @ SITE: SHE ACKNOWLEDGED SEPTIC FAILING ~1 YEAR, AND FLOCK WAS SUPPOSED TO MEET W/HER, BUT "HE NEVER SHOWED"; DESPITE THAT, SHE STILL CLAIMED TO BE "WORKING ON IT", ALTHO SHE HAD NOT CALLED OTHER CONTRACTORS; SHE ALSO DEMANDED TO KNOW WHO COMPLAINED, BUT I ADVISED HER SHE WOULD HAVE TO REQUEST THAT IN WRITING FROM PROG. NR.; INSP. CONFIRMS LARGE SEWAGE DISCH. (SEE DRAWING); NAMES OF 3 CONTRACTORS ALSO PROVIDED TO OWNER (R) DISCHARGE WET NOT FLOWING, ~20' x 30' IN DIMENSION IN REPORTED LOCATION ~60-70' TO RIGHT SIDE OF HOUSE

— TELEPHONE CALL FROM PROPERTY OWNER 3:15 PM; REQUESTING NAME OF COMPLAINANT — I EXPLAINED TO HER THAT POLICY WAS TO NOT DISCLOSE IF APPLICANT REQUESTED TO REMAIN ANONYMOUS. OK

5/23/97 FOLLOW-UP INSP: OWNER REPORTS TANK PUMPED
& "FYOCK WORKING ON IT"; INSP REVEALS
1ST TANK FULL ~~AND~~ @ C/O, 2ND TANK C/O CAP
NOT REMOVABLE; DISCHARGE WET (MR)

5/28/97 T/C w/ FYOCK REPORTS SITE VISIT & PUMPING
ON 5/20/97, BUT ADD'L DETAIL NOT AVAIL.;
SHE WILL CALL BACK LATER (MR)

6/5/97 ROCKY OF FYOCK REPORTS NO OTHER
PUMP JOBS; ~~THEY~~ ALSO REPORTS THEY
ARE WAITING FOR CALL FROM OWNER (MR)



HOWARD COUNTY HEALTH DEPARTMENT

Joyce M. Boyd, M.D., County Health Officer

June 13, 1997

Mr. & Mrs. Drupad Desai
13459 Sorghum Court
Highland, MD 20777

RE: **SECOND NOTICE OF VIOLATION**
13459 Sorghum Court
Allnutt Farms Estates
Section 4, Lot 1

Dear Mr. & Mrs. Desai:

On May 9, 1997, this office issued a Notice of Violation to you subsequent to observation of a sewage discharge at the above referenced property. The Notice ordered septic system repairs to be completed within fifteen (15) days of receipt. Although that fifteen-day deadline expired May 29, 1997, no septic system repair has been performed. Additionally, the required septic tank pumping has not occurred with sufficient frequency to prevent additional sewage discharges.

This letter constitutes a Notice of Intent to Pursue Additional Enforcement Actions. In enforcing the repair order, this agency has the authority to issue citations and seek judicial relief. Prompt execution of a septic system repair and interim pumping to avoid further discharges prevents initiation of these enforcement actions.

If you wish to discuss the evidence, the regulations, or your individual circumstances, you are encouraged to call this office to schedule a meeting.

To schedule a meeting or request a septic system repair permit (\$25 fee), please call 410-313-2640. Thank you for your attention to this matter.

THIS LETTER WAS NOT
CLAIMED BY ADDRESSEE,
RETURNED TO A.D. ON
7/1/97 (MR)

Very truly yours,

Mark E. Rifkin
Mark E. Rifkin, R.S.
Water & Sewerage Program

MR
cc: File

Z 191 146 059



**Receipt for
Certified Mail**

No Insurance Coverage Provided
Do not use for International Mail
(See Reverse)

PS Form 3800, March 1993

Sent to Mr. & Mrs. Drupad Desai	
Street and No. 13459 Sorghum Court	
P.O., State and ZIP Code Highland, Maryland 20777	
Postage ¹	\$
Certified Fee ²	
Special Delivery Fee	
Restricted Delivery Fee	
Return Receipt Showing to Whom & Date Delivered	
Return Receipt Showing to Whom, Date, and Addressee's Address	
TOTAL Postage & Fees	\$
Postmark or Date Mark Rifkin 06/13/97	

From ~~the~~ Front to back



HOWARD COUNTY HEALTH DEPARTMENT

Joyce M. Boyd, M.D., County Health Officer

May 9, 1997

Mr. & Mrs. Drupad Desai
13459 Sorghum Court
Highland, MD 20777

RE: NOTICE OF VIOLATION
13459 Sorghum Court
Allnutt Farms Estates
Section 4, Lot 1

Dear Mr. & Mrs. Desai:

On May 9, 1997, I, a sanitarian from this office, conducted an inspection at your property at the above referenced address in response to a report of an overflowing septic system. On that date, I observed a significant sewage discharge approximately sixty feet from the right side of your house.

This condition is in violation of Section 12.110 of the Howard County Code.

As the sewage discharge creates a condition which is, or may be, hazardous to the public health you are hereby ordered to effect repairs within fifteen (15) days of receipt of this letter. If any new septic tanks or drainfields are necessary, then you must also apply to this office for a septic system repair permit, the fee for which is \$25.00. Until repairs are completed, you must immediately (within 48 hours) have the septic tank contents pumped by a licensed sewage scavenger, and continue pumping, as often as necessary, to prevent future sewage overflows.

If you believe that the condition described above is not and could not be a hazard to health, or that the Health Department is not acting in compliance with pertinent laws and regulations, you may request a formal hearing before the Board of Health within ten (10) days of receipt of this letter. If you wish to discuss the evidence, the regulations, or your individual circumstances, you are encouraged to request a meeting with us by calling 313-2640 and scheduling an appointment.

Z. 191 149 022



**Receipt for
Certified Mail**

No Insurance Coverage Provided
Do not use for International Mail
(See Reverse)

PS Form 3800, March 1993

Sent to	
Mr. and Mrs. Drupad Desai	
Street and No.	
13459 Sorghum Court	
P.O., State and ZIP Code	
Highland, Maryland 20777	
Postage	\$
Certified Fee	
Special Delivery Fee	
Restricted Delivery Fee	
Return Receipt Showing to Whom & Date Delivered	
Return Receipt Showing to Whom, Date, and Addressee's Address	
TOTAL Postage & Fees	\$
Postmark or Date	
Mark Rifkin 05/09/97	

Mr. & Mrs. Desai


Page Two

May 9, 1997

The investigation of this complaint and the enforcement powers of the Health Department are set forth in Section 12 of the Howard County Code, a copy of which is available for your investigation at this office.

If you have any questions, please contact me at 313-2640.

Very truly yours,



Mark E. Rifkin, R.S.
Water & Sewerage Program

MR

cc: File

SITE INSPECTION SHEET

OWNER: Desai

DATE REQUESTED: _____

PHONE #: _____


CONTRACTOR: _____

ADDRESS: 13459 Sorghum Ct

WELL TAG #: _____

COUNTY #: _____

PROPOSAL: reported failing septic



COMMENTS: 5/9/97 SEE COMPLAINT SHEET (WR)

DATE: _____

INSPECTOR: _____



HOWARD COUNTY HEALTH DEPARTMENT

Joyce M. Boyd, M.D., County Health Officer

July 24, 1997

Mr. & Mrs. Drupad Desai
13459 Sorghum Court
Highland, MD 20777

RE: Termination of Notice of Violation
13459 Sorghum Court
Allnutt Farms Estates
Sec 4, Lot 1

Dear Mr. and Mrs. Desai:

The above referenced Notice of Violation is hereby terminated. The condition cited in the Notice, which was issued on May 9, 1997 pursuant to Section 12.110 of the Howard County Code, has been remediated. Confirmation of the remediation of the specified condition is described below.

On July 21, 1997, a septic system repair was installed, inspected and approved by Kim Soe, registered sanitarian. Ms. Soe also observed the proper disconnection of the trench running downhill toward the area of the overflow.

If you have any questions, please call me at (410) 313-2640. No further action on your part is required. Thank you very much for your cooperation in this matter.

Very truly yours,

Mark E. Rifkin, R.S.
Water and Sewerage Program

MR
cc: File