1/11/02
NOON

ISSUE DATE: 1/11/02

APPROVAL DATE: 1/14/02

PERMIT

INDEXED

P 512774

A REPAIR

ON-SITE SEWAGE DISPOSAL SYSTEM
HOWARD COUNTY HEALTH DEPARTMENT
BUREAU OF ENVIRONMENTAL HEALTH

03-303748

Jack Fyock Septic Service IS PERMITTED TO INSTALL ☐ ALTER ☒

ADDRESS: 13775 Triadelphia Rd., GLenelg PHONE NUMBER: 410-988-9270

SUBDIVISION: Henryton Heights LOT NUMBER: 25

ADDRESS: 11846 Ramsburg Road PROPERTY OWNER: Meerschaert

410 442-5579

SEPTIC TANK CAPACITY (GALLONS): ex 1000

PUMP CHAMBER CAPACITY (GALLONS): NA

NUMBER OF BEDROOMS: 3

SQUARE FEET PER BEDROOM: 180 ft²

LINEAR FEET OF TRENCH REQUIRED: 50'-60' (2-25's) or (2-30's)

TRENCHES:	Trench to be 2 feet wide. Inlet 4-5 feet below original grade. Bottom maximum depth 10-11 feet below original grade. Effective area begins at 4-5 feet below original grade. 6 feet of stone below distribution pipe.
LOCATION:	repl.
PURPOSE:	Perc's to ~~establish additional~~ septic capacity in support of future building permit addition.

PLANS APPROVED: Mark Rifkin & SRM DATE: 01/11/2002

NOTE: PERMIT VOID AFTER 2 YEARS
NOTE: CONTRACTOR RESPONSIBLE FOR SCHEDULING A PRE-CONSTRUCTION INSPECTION FOR ALL INSTALLATIONS
NOTE: WATERTIGHT SEPTIC TANKS REQUIRED
NOTE: ALL PARTS OF SEPTIC SYSTMEM SHALL BE 100 FEET FROM ANY WATER WELL
NOTE: MANHOLE RISERS REQUIRED ON ALL SEPTIC TANKS AND PUMP CHAMBERS

[redacted] 1-16-02

B00133446 - fAm. Ron Addleton

NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM
PERMITTEE RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT
CALL 410-313-2640 FOR INSPECTION OF SEPTIC SYSTEM

P512774

6' stone

NOT TO SCALE



TRENCH/DRAINFIELD DATA

	WIDTH	INLET ①	INLET ②	BOTTOM ①	BOTTOM ②
	2	4'	5'	10'	11'

NUMBER OF TRENCHES 2
TOTAL LENGTH 55' + exist.
ABSORPTION AREA 330 ft² + exist.
DISTRIBUTION BOX LEVEL ✓
DISTRIBUTION BOX BAFFLE ✓
DISTRIBUTION BOX PORT NA

SEPTIC TANK DATA Ex. ✓

SEPTIC TANK 1 LEVEL	✓
CAPACITY	1000 GAL
SEAM LOC	Midseam
TANK LID DEPTH	2.5'
BAFFLES	✓
BAFFLE FILTER	NA
MANHOLE LOC	NA
6" PORT LOC	front
WATERTIGHT TEST	NA
SEPTIC TANK 2 LEVEL	NA
CAPACITY	NA GAL
SEAM LOC	NA
TANK LID DEPTH	NA
BAFFLES	NA
BAFFLE FILTER	NA
MANHOLE LOC	NA
6" PORT LOC	NA
WATERTIGHT TEST	NA

PRE-CONSTRUCTION 1/11/02 - DUG PERC HOLE IN LOCATION (A) SEE SOIL PROFILE, INSTALL PER DISCUSSED, OK TO INSTALL 80-90' FROM SURROUNDING WELLS SINCE THEY ARE NOT USED FOR SANITARY USES & ARE NOT IN THE DRAINAGE FLOW PATTERN

INSTALLATION OF THE REPAIR, SEPTIC TRENCHES WITHIN 20' OF FUTURE ADD. TO BE CUT OFF (50 LINEAR FT LOST) & REPL. IN LOCATION (A) (THIS ALSO PRESERVES REPAIR AREA IN 10,000 ft² EASEMENT) - SRV

1/14/02 - OK TO COVER ALL WORK, NEW SYSTEM TO BE USED 1ST AS FLOW WILL BE DIVERTED AT NEW D. BOX, THEN AT FAILURE, SEWAGE CAN BACK TO OLD D. BOX & OLD SYSTEM (THIS GIVES OLD SYSTEM TIME TO REST FOR POTENTIAL UNCLOGGING) - SRV

FINAL INSPECTOR Steven R. Craig DATE OF APPROVAL 1/14/02

20647



180/BC
2.5-6.5'

INDICATE NORTH — NAME ADJOINING ROADWAY AS BASE LINE

SEPTIC TANK LEVEL ✓ 1000 Gal CLEANOUTS ST ✓

DISTRIBUTION BOX LEVEL ✓

DRAIN FIELD/TILE FIELD DEPTH 6½ FT. TRENCH WIDTH [illegible] FT INLET DEPTH 2½ FT.

EFFECTIVE GRAVEL DEPTH 7 4 FT TOTAL LENGTH 57 60 FT

NUMBER OF TRENCHES 2+ ONE SIDEWALL/BOTTOM AREA 2280 SQ FT.

DRYWELL INSIDE DIAMETER — FT EFFECTIVE DEPTH BELOW INLET — FT.

2/9/87 ABSORBENT AREA ______ SQ FT

REMARKS 1st trench OK to add [illegible]

2/11/87 OK to cover trench #1. OK to finish stone pipe papering trench #2 OK to start trench #3. Trench #3 will be a little farther away from #2 [illegible] in hopes of maximizing trench length.

3/24/87 [illegible] 3rd TRENCH COMPLETED. NW

DATE SYSTEM APPROVED 3/24/87 INSPECTOR [signature]

60
60
120
57
177

2/9/87 pm
2/10/87 pm

PERMIT

SEWAGE DISPOSAL SYSTEM

MARYLAND STATE DEPARTMENT OF HEALTH*

P 18620

A 20547

DISTRICT 5th

DATE 2/05/87

DATE SYSTEM APPROVED 3/24/87

INSPECTOR Cwilki

HOWARD COUNTY
BUREAU OF ENVIRONMENTAL HEALTH
461-9933

INDEXED

{ Expired }

Cornwell Pump Company IS PERMITTED TO INSTALL X ALTER

ADDRESS 12126 Triadelphia Road, Ellicott City, MD PHONE 988-9221

SUBDIVISION Kenrytan Heights ROAD 11846 Ramsburg Road LOT 25

PROPERTY OWNER ~~Gerald Martin~~ Mrs. Simpson

ADDRESS

IF GARBAGE GRINDER IS USED INCREASE SEPTIC TANK CAPACITY BY 50% AND ABSORPTION AREA BY 22%

GARBAGE GRINDER? YES NO X

SEPTIC TANK CAPACITY 1000 GALLONS NUMBER OF BEDROOMS 1

TRENCHES - 160 sq. ft. per bedroom. Trench to be 2 feet wide. Inlet 24 ins. below original grade. Bottom maximum depth 6½ feet below original grade. Effective area begins at 2½ feet below original grade. 6 feet of stone below distribution pipe.

LOCATION - Place the distribution box 190 feet from the left lot line and 75 feet from the front lot line. Run trench(s) along contour toward right side of property.

NOTE - No trench to exceed 100 feet in length. If more than one trench used, a distribution box is required. Provide 6" - 8" diameter clean-out and cap to grade or above on septic tank.

PLANS APPROVED BY C. Williams DATE 6/08/86

COVER NO WORK UNTIL INSPECTED AND APPROVED

NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM

NOTE CLEANOUT REQUIRED EVERY 70 FEET OF SEWER LINE WITH AT 90° SWEEPS IN LINES FROM HOUSE TO DRAIN FIELDS

NOTE ALL PARTS OF SEPTIC SYSTEMS (I.E. TANK DISTRIBUTION BOX TRENCHES) TO BE 100 FEET FROM WELL (UNLESS OTHERWISE SPECIFICALLY AUTHORIZED)

NOTE IF DEEP TRENCHES ARE USED CALL FOR INSPECTION BEFORE AND AFTER PLACING GRAVEL IN TRENCHES

NOTE NO DRY WELL SHALL EXCEED 15 FOOT IN DIAMETER OR ABSORPTION TRENCH TO EXCEED 100 FEET IN LENGTH

NOTE ALL PIPE FROM HOUSE TO SEPTIC TANK MUST BE CAST IRON OR SCHEDULE 40 PVC OR ABS

PERMIT VOID AFTER TWO YEARS

NOTE INSTALL STAND PIPE ON SEPTIC TANK AND DRY WELL STAND PIPES MUST BE 6 INCHES IN DIAMETER CAST IRON, CONCRETE OR TERRA COTTA OR PVC OR ABS. ACCEPTED IF TOP OF SEPTIC TANK IS DEEPER THAN 2 FEET MANHOLE TO GRADE REQUIRED

NOTE DISTRIBUTION BOXES MUST HAVE BAFFLES

BLDG. PERMIT ISSUED

RETURNED 6/27/95

Seal # 60466 - dick

A 20547

*INSTALLER IS RESPONSIBLE FOR OBTAINING FINAL APROVAL ON THIS PERMIT

*CALL 461-9933 FOR INSPECTION OF SEPTIC SYSTEMS.

EH - 2-1186

20647



INDICATE NORTH — NAME ADJOINING ROADWAY AS BASE LINE

Unnamed Road

DATE	TEST NO.	DEPTH	PRE-WET START	PRE-WET STOP	TEST - 1" DROP START	TEST - 1" DROP STOP	TIME	
4/1/72	1	3	9:52	9:53	9:53	9:55	2 min	
	1A	9'	9:52	9:59	9:59	10:06	7 min	H_2O at 10'
	2 high	3	10:01	10:03	10:03	10:11	8 min	
	2A	$11\frac{1}{2}$	10:00	10:03	10:03	10:10	7 min	
	3 low	$2\frac{1}{2}$'	10:17	10:19	10:19	10:22	3 min	
	3A	11	10:17	10:27	10:27	10:43	16 min	
	5	9'	Harder mica in bottom, mica loam 1-9'					
	4	$11\frac{1}{2}$	Dry to 10', mica loam below					

REMARKS: Recommend ... to get ... for 25' setback to 50'

TYPE OF SOIL: Sandy mica loam below top ~2' clayey soil

TESTED BY: F. C. ALSO PRESENT: E. Romekus, ...

4-13 [illegible]
[illegible]

APPLICATION

A 20647

SEWAGE DISPOSAL TESTING

P. ____

STATE OF MARYLAND · DEPARTMENT OF HEALTH AND MENTAL HYGIENE

HOWARD COUNTY HEALTH DEPARTMENT 3BR. 1000 gal. septic tank | 4 B.R. 1250 gal. septic tank

ENVIRONMENTAL HEALTH SERVICES

P. O. BOX 476, ELLICOTT CITY, MARYLAND 21043

TELEPHONE: 465-5000, EXT. 390

DISTRICT 5th

DATE 9/9/76

4/6/76 9:30 Drywell and trench system to have 140 sq. ft. effective sidewall absorption area per bedroom to begin below the first 2½ ft. of [illegible] soil. Maximum depth permitted for drywell or trench is 7½ ft. below original grade. Place the drywell 90 ft. from the left side line and 75 ft. from the front lot line as seen when facing the property from Ramsburg Road. Start the trench after a 5 foot earth buffer with the drywell and proceed to dig it on level ground [illegible] towards the center of the front lot line.

NOTE: WELL & SEPTIC SYSTEM TO BE INSTALLED BEFORE BUILDING PERMIT IS RELEASED

NOTE: Call for inspection of trench before gravel is installed.

TO: THE COUNTY HEALTH OFFICER
ELLICOTT CITY, MARYLAND

I, HEREBY, APPLY FOR THE NECESSARY TEST IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE DISPOSAL SYSTEM.

PROPERTY OWNER ~~E. L. Ramsburg and wife~~ GERALD MARTIN

ADDRESS 185 Henryton Road, Marriottsville, Md. PHONE 328-2696

PROPERTY LOCATION: NEW 25

SUBDIVISION Henryton Heights LOT NO. ~~36, Sect 2~~

ROAD AND DESCRIPTION Ramsburg Road 11846

SIZE OF LOT 53,000 sq. ft. ± TYPE BLDG. 3 or 4 bedrooms
NUMBER OF BEDROOMS

IF NOT SINGLE RESIDENCE DESCRIBE ____

THE SYSTEM INSTALLED UNDER THIS APPLICATION IS ACCEPTABLE ONLY UNTIL PUBLIC FACILITIES BECOME AVAILABLE

SIGNATURE OF APPLICANT /s/ F. L. Ramsburg

APPROVED BY Frank [illegible] FOR Drywell & trench (KIND OF SYSTEM) DATE 2/24/77

REJECTED BY ____ FOR ____ (KIND OF SYSTEM) DATE ____

HOLD PENDING FURTHER TESTS ____ DATE

BLDG. PERMIT SIGNED AND RETURNED [illegible]

REASONS FOR REJECTION OR HOLDING [illegible] BP# 72066

4/7/7[illegible] This lot is non-buildable until approved by H.C. Health Dept. [illegible]
Water well & septic system FIRST F.S.

THIS IS NOT A PERMIT

DNR-214 (7-77)

C 1. 1269 — SEQUENCE NO. (WRA USE ONLY) — (SEQ. NO.) — (THIS NUMBER IS TO BE PUNCHED IN COLS. 3-6 ON ALL CARDS)

STATE OF MARYLAND
WATER RESOURCES ADMINISTRATION
TAWES STATE OFFICE BLDG., ANNAPOLIS, MD. 21401
WELL COMPLETION REPORT

THIS REPORT MUST BE SUBMITTED WI IN 30 DAYS AFTER WELL COMPLET

- FILL IN THIS FORM COMPLETELY

COUNTY NUMBER

DATE RECEIVED (WRA USE ONLY)

DATE WELL COMPLETED: Nov 22 1977

DEPTH OF WELL: 225 (TO NEAREST FOOT)

PERMIT NO. FROM "PERMIT TO DRILL WELL": 80-78-0294

DRILLERS IDENTIFICATION NO.: 282

OWNER: Rowland Everett
LAST NAME FIRST NAME

STREET OR RFD: 185 Hilton Rd. POST OFFICE: Manchester Md.

WELL DESCRIPTION

WELL LOG

STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING

DESCRIPTION (USE ADDITIONAL SHEETS IF NECESSARY)	FEET FROM	FEET TO	CHECK IF WATER BEARING
Brown Shale	0	55	
Gray Mica Rock	55	225	

GROUTING RECORD

WELL HAS BEEN GROUTED (CIRCLE APPROPRIATE BOX): YES (Y) NO (N)

TYPE OF GROUTING MATERIAL (CIRCLE BOX): CEMENT (C M) BENTONITE CLAY (B C)

NO. OF BAGS: 10 NO. OF POUNDS: 940

GALLONS OF WATER: 60

DEPTH OF GROUT SEAL (TO NEAREST FOOT): FROM: 0 FT. TO: 60 FT. (ENTER 0 IF FROM SURFACE)

CASING RECORD

CASING TYPES — INSERT APPROPRIATE CODE BELOW: S.T. STEEL; C O CONCRETE; P L PLASTIC; O T. OTHER

MAIN CASING TYPE	NOMINAL DIAMETER TOP (MAIN) CASING (NEAREST INCH)	TOTAL DEPTH OF MAIN CASING (NEAREST FOOT)
S T	6	67

OTHER CASING (IF USED)

EACH CASING

DIAMETER (INCH)	DEPTH (FEET) FROM	TO

SCREEN RECORD

SCREEN TYPE OR OPEN HOLE — INSERT APPROPRIATE CODE BELOW: S T STEEL; B R BRASS OR BRONZE; H O OPEN HOLE; P L PLASTIC; O T OTHER

C 2 (SEQ. NO.)

DEPTH (NEAREST WHOLE FOOT)

EACH SCREEN

		FROM	TO
1	H O	65	225
2			
3			

SLOT SIZE 1. ____ 2. ____ 3. ____

DIAMETER OF SCREEN: ____ (NEAREST INCH)

GRAVEL PACK: FROM ____ TO ____

IF WELL DRILLED WAS A FLOWING WELL CIRCLE BOX: F

CIRCLE APPROPRIATE BOXES

- A — A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED
- E — ELECTRIC LOG OBTAINED
- P — TEST WELL CONVERTED TO PRODUCTION WELL

I HEREBY CERTIFY THAT I HAVE COMPLIED WITH ALL CONDITIONS STATED ON THE ABOVE-CAPTIONED "PERMIT TO DRILL WELL", AND THAT INFORMATION CONTAINED IN THIS REPORT IS TRUE, ACCURATE, AND COMPLETE TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF.

DRILLERS NAME (PLEASE PRINT): Joseph L. Mayne

SIGNATURE: Joseph L. Mayne

WRA USE ONLY (NOT TO BE FILLED IN BY DRILLER)

T — TELESCOPE CASING; (E.R.O.S.) — LOG INDICATOR; W O T — OTHER DATA AVAILABLE

C 3

PUMPING TEST

HOURS PUMPED (TO NEAREST HOUR): 2

PUMPING RATE (GALLONS PER MINUTE TO NEAREST GALLON):

METHOD USED TO MEASURE PUMPING RATE: WS

WATER LEVEL: (DISTANCE FROM LAND SURFACE)

BEFORE PUMPING: 45 (NEAREST FOOT)

WHEN PUMPING: 5 (NEAREST FOOT)

TYPE OF PUMP USED (CIRCLE APPROPRIATE BOX) (FOR PUMPING TEST)

A AIR; P PISTON; T TURBINE; C CENTRIFUGAL; R ROTARY; O OTHER (DESCRIBE BELOW); J JET; S SUBMERSIBLE

PUMP INSTALLED

TYPE OF PUMP (WRITE APPROPRIATE LETTER IN BOX — SEE ABOVE: A, C, J, P, R, S, T, O): J

DRILLER WILL INSTALL PUMP (CIRCLE APPROPRIATE BOX): YES (Y) NO (N)

CAPACITY:

GALLONS PER MINUTE (TO NEAREST GALLON):

PUMP HORSE POWER:

PUMP COLUMN LENGTH (NEAREST FOOT):

CASING HEIGHT (CIRCLE APPROPRIATE BOX AND ENTER CASING HEIGHT)

+ ABOVE / − BELOW LAND SURFACE: 2 (NEAREST FOOT)

LOCATION OF WELL ON LOT

N

SHOW PERMANENT STRUCTURE SUCH AS BUILDINGS, SEPTIC TANKS, AND/OR OTHER LAND MARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL).



HEALTH

DNR-131 (7/73) EMERGENCY NO. (If any) –

B 1 2314 SEQUENCE NO. (WRA USE ONLY)

1 2 (SEQ. NO.) 6 (THIS NUMBER IS TO BE PUNCHED IN COLS. 3-6 ON ALL CARDS)

STATE OF MARYLAND
WATER RESOURCES ADMINISTRATION
TAWES STATE OFFICE BLDG., ANNAPOLIS, MARYLAND 21401
APPLICATION FOR PERMIT TO DRILL WELL

A 20647

WRA PERMIT NUMBER HO-75

FILL IN THIS FORM COMPLETELY

DATE RECEIVED (WRA USE ONLY) 8/23/77 1:30 P.M.

OWNER Ramsburg Ernest (COL 15 LAST NAME, FIRST NAME COL. 34)

STREET OR RFD 185 Hemlton Rd - (COL 36, COL. 55)

POST OFFICE Marriottsville Md. 21104 (COL 57, COL. 76)

8-13

B 1 CONTINUED (1 2 3 (SEQ. NO.) 6)

DRILLER INFORMATION

DATE July 20, 1977 LICENSE NUMBER 338 (77 80)

Joseph L. Mayne (FIRST NAME DRILLER LAST NAME)

SIGNATURE Joseph L. Mayne

B 2 (1 2 3 (SEQ. NO.) 6)

WELL INFORMATION

MAXIMUM PUMPING RATE (GALLONS PER MINUTE) 15 (8 12)

AVERAGE DAILY QUANTITY NEEDED (GALLONS PER DAY) 750 (14 20)

USE FOR WATER (CIRCLE APPROPRIATE BOX)

(D) HOME (SINGLE OR DOUBLE HOUSEHOLD UNIT ONLY)

F FARMING, AGRICULTURE, IRRIGATION

I INDUSTRIAL, COMMERCIAL, STATE AND FEDERAL GOVERNMENT

22

M MUNICIPAL WATER SUPPLY

P PRIVATE WATER COMPANY

} MUST HAVE STATE HEALTH DEPT. APPROVAL

T TEST

APPROXIMATE DEPTH OF WELL 180 FEET (24 28)

APPROXIMATE DIAMETER OF WELL 6 (NEAREST INCH)

METHOD OF DRILLING USED (CIRCLE APPROPRIATE METHOD)

BORED (OR AUGERED) JETTED DRIVEN

30-37 (AIR-ROTARY) AIR-PERCUSSION ROTARY (HYDRAULIC ROTARY)

CABLE REVERSE-ROTARY DRIVE-POINT

OTHER (DESCRIBE)

REPLACEMENT OR DEEPENED WELLS (CIRCLE APPROPRIATE BOX)

(N) THIS WELL WILL NOT REPLACE AN EXISTING WELL

Y THIS WELL WILL REPLACE A WELL THAT WILL BE ABANDONED AND SEALED

39

S THIS WELL WILL REPLACE A WELL THAT WILL BE USED AS A STANDBY

D THIS WELL WILL DEEPEN AN EXISTING WELL

PERMIT NUMBER OF WELL TO BE REPLACED OR DEEPENED (IF AVAILABLE) (41 52)

NOT TO BE FILLED IN BY DRILLER (WRA USE ONLY)

APPROPRIATION PERMIT NUMBER G A P (54 63) ENGINEER REVIEW DISTRICT NO. (65)

FORCE WRITE INITIALS IN BOX (67 68) CONDITIONS A E N S G W Q C L U (70 71 72 73 74 75 76 77 78 79)

B 4 CONTINUED (1 2 3 (SEQ. NO.) 6)

HEALTH DEPARTMENT APPROVAL

41 (S) STATE HEALTH (CIRCLE BOX)

Howard (COUNTY NAME) 136460 (COUNTY NO.)

DATE MO. 7 DAY 21 YR. 77 (43 48)

Walter T. Palmer (APPROVED BY)

Palmer Mine

B 5 (1 2 3 (SEQ. NO.) 6)

SPECIAL CONDITIONS 8-63 (WRA USE ONLY) (8 63)

HEALTH

B 3 (1 2 3 (SEQ. NO.) 6)

LOCATION OF WELL

COUNTY Howard (8 21 DO NOT ABBREVIATE COUNTY NAME)

SUBDIVISION Hemnitton Rd (23 42)

SECTION 20 (44 46) LOT 2 (48 50)

NEAREST TOWN Alpha (52)

MILES FROM TOWN (ENTER 0 IF IN TOWN) .1 (73) (M I) (76 77 78)

B 4 (1 2 3 (SEQ. NO.) 6)

DIRECTION FROM TOWN (CIRCLE APPROPRIATE BOX)

N NORTH E EAST NE NORTHEAST SE SOUTHEAST

S SOUTH W WEST NW NORTHWEST SW SOUTHWEST

(8 8 8 9 8 9)

NEAR WHAT ROAD Ramsburg Drive (11)

ON WHICH SIDE OF ROAD (CIRCLE APPROPRIATE BOX) NORTH (N) SOUTH E WEST (32 32 32 32)

DISTANCE FROM ROAD (ENTER DISTANCE AND CIRCLE APPROPRIATE BOX) 2.0 (34 37) (F T) (M I) (38 39)

DRAW A SKETCH BELOW SHOWING LOCATION OF WELL IN RELATION TO NEARBY TOWNS, ROADS AND STREAMS WITH NORTH IN THE DIRECTION OF THE ARROW, AND GIVE DISTANCE FROM WELL TO NEAREST ROAD JUNCTION OR STREAM CROSSING SHOWN ON THE SKETCH. ALSO SHOW, BY MEANS OF AN "X", THE WELL LOCATION IN THE BOX BELOW, AND THE BOX NUMBER FROM THE WELL LOCATION MAP.



BOX NUMBER E 8520 N 540



NORTH COORDINATE (50 51 52 53 54 55)

EAST COORDINATE (57 58 59 60 61 62 63)

ELEVATION AT WELL HEAD (FEET) (65 66 67 68)


LEGEND
Prop. dwelling location
Prop. well location
Exist. perc. test hole
Lot No.
15
16
17
County Health Officer
Note: The lots shown herein comply with minimum ownership width & lot area as required by the Maryland State Dept. of Health and Mental Hygiene regulations.
Lot 22
Lot 24
13
Lot 26
15
Lot 25
14
Lot 27
17
new 24
A20646
A20647
Existing Pond
Ex. 1½ Story Brick Dwelling
Ex. Sheds
Ex. Barn
25' Building Restriction Line
20' Drainage Easement
260'±
170'±
150'±
188'±
225'±
270'±
140'±
100'±
105'±
1"=100'
Oct. 11, 1976.
OWNER & DEVELOPER
Henryton Sec. 2
Hgt. Lots 15, 16 & 17
10/18/76.



LOT 24
LOT 29
LOT 25
1.30 ACRES
S43° 30' 50" E
473.00'
N73° 31' 50" W
225.00'
54.00'
50.00'
154.09'
N16° 28' 10" E
20'-0" BRL
75'-0" BRL
20'-0" BRL
240.45'
31.49'
S63° 05' 29" E
220.49'
N65° 34' 15" E
51.49'
423.45'
S82° 26' 19" W
55.45'
212.74'
136.00'
S16° 28' 10" W
104.09'
CTRLINE OF 20' DRAINAGE EASEMENT
TEMP 10' DRAINAGE ESM'T
N88° 02' 00" W
26.61'
24.99'
142.76'
L=393.74
225.99'
R=1670.00
129'-0.4133"
75'-4.4264"
93'-7.0051"
111'-6.5708"
111'-2.1617"
16.75'
13.25'
38.25'
EXIST'G DECK
EXIST'G RESIDENCE
PROP. ADDITION
1/16/02- Proposed addition on SRK
B001339446
SEPTIC LOCATION
EX WELL
EXIST'G DRIVEWAY
EXISTING PUBLIC WATER LINE
RAMSBURG ROAD
SITE PLAN
SC: 1" = 30'-0"
THESE DRAWINGS ARE NOT TO BE REPRODUCED OR COPIED EITHER WHOLLY OR PARTIALLY, UNLESS WRITTEN PERMISSION IS FIRST OBTAINED FROM DEEDRA A. MORLEY-ARTIS AND/OR LEROY T. ARTIS. THE USERS OF THESE DOCUMENTS AGREE NOT TO HOLD DEEDRA A. MORLEY-ARTIS AND/OR LEROY T. ARTIS OR THEIR HEIRS FOR ANY ERRORS OR OMISSIONS, PERMISSION GRANTED OR NOT. CONTRACTOR SHALL VERIFY ALL INFORMATION PRIOR TO CONSTRUCTION.
ARTIS DESIGNS, INC.
AN ADDITION TO THE RESIDENCE OF MR. AND MRS AUGUST MEERSCHAERT
11846 RAMSBURG ROAD
MARRIOTSVILLE, MD 21104
GAYTHROP CONSTRUCTION, INC.
(410) 531-6413
COPYRIGHT 2002-2006.
REVISIONS
1/15/02 LOT/RESIDENCE LOC REVISION
PROJECT NUMBER GAW 110101
4 JANUARY 2002
SC: 1" = 30'-0"
SITE PLAN
SHEET S-1-1 OF 5