

PERMIT

P 514729-B

SEWAGE DISPOSAL SYSTEM

A REPAIR

HOWARD COUNTY HEALTH DEPARTMENT

BUREAU OF ENVIRONMENTAL HEALTH

ISSUE DATE 1/3/2001

410-313-2640

APPROVAL DATE 1/3/01

Jack Fyock Septic Service

IS PERMITTED TO INSTALL ☐ ALTER ☒

ADDRESS P.O. Box 89, Glenelg, MD 21737 PHONE 410-988-9270

SUBDIVISION (910) 489-0053 LOT NUMBER 1678 St Michael's RoadPROPERTY OWNER McNamara PROPERTY OWNER'S ADDRESS SameSEPTIC TANK CAPACITY 1000 GALLONS Topseam w/ PVC baffle extensionsPUMP CHAMBER CAPACITY NA GALLONSNUMBER OF BEDROOMS 3SQUARE FEET PER BEDROOM 540 ft²LINEAR FEET OF TRENCH REQUIRED 30'

BED

[LEACHING BED TO BE INSTALLED
ON CONTOUR]

SEE SPECS BELOW *

TRENCHES: Bed Trenches to be 20 feet wide. Inlet 1.5 feet below original grade. Bottom maximum depth 3'LOCATION: 1.5 feet below original grade. 1.5 feet of stone below distribution box
pipe

REPAIR - PURPOSE - Existing septic system has failed.

Call for inspection when ground is opened so sanitarian can recommend repair. 12/26/00

* Replace line from house to tank w/ PVC, move Tank 50' further to rear of house so it will be 100' from ex. well. Pump, seal/collapse ex. tank. Replace line from new tank to dbox w/ PVC. Install bed on contour w/ dbox & perforated pipe.

PLANS APPROVED Steven R. Krieg DATE 1/3/01

PERMIT VOID AFTER 2 YEARS

NOTE: CONTRACTOR RESPONSIBLE FOR SCHEDULING A PRE-CONSTRUCTION INSPECTION FOR ALL INSTALLATIONS

NOTE: TOP OF SEPTIC TANKS ARE TO BE NO DEEPER THAN 3.0 FEET BELOW FINISH GRADE

NOTE: WATERTIGHT SEPTIC TANKS REQUIRED

NOTE: CLEANOUT REQUIRED EVERY 70 FEET OF SEWER LINE AND/OR AT 90° SWEEPS IN LINES FROM HOUSE TO DRAIN FIELDS, 90° ELBOWS ARE NOT ACCEPTABLE

NOTE: ALL PARTS OF SEPTIC SYSTEMS (I.E. TANK, DISTRIBUTION BOX, DRAINFIELDS) TO BE 100 FEET FROM ANY WATER WELL UNLESS OTHERWISE SPECIFICALLY AUTHORIZED

NOTE: NO ABSORPTION TRENCH TO EXCEED 100 FEET IN LENGTH UNLESS SPECIFICALLY AUTHORIZED

NOTE: ALL PIPE FROM HOUSE TO SEPTIC TANK MUST BE CAST IRON OR SCHEDULE 35/40 PVC OR ABS

NOTE: MANHOLE RISERS REQUIRED ON ALL SEPTIC TANKS AND PUMP CHAMBERS

NOTE: DISTRIBUTION BOXES MUST HAVE BAFFLES

NOTE: IF PUMPED SEPTIC SYSTEM REQUIRED, (1) SEPTIC PUMP DETAIL TO BE PROVIDED BY INSTALLER PRIOR TO ISSUANCE OF SEPTIC PERMIT (2) PUMP PERFORMANCE TEST IS NECESSARY PRIOR TO HEALTH DEPARTMENT APPROVAL OF SEPTIC PERMIT

NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE
SUCCESSFUL OPERATION OF ANY SYSTEM

PERMITTEE RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT

CALL 410-313-2640 FOR INSPECTION OF SEPTIC SYSTEM

514729-B

INSPECTOR Steven R. Krieg DATE SYSTEM APPROVED 1/3/2001