

10/24/91
10/25/91 AM
12/28/91 ASH

PERMIT

SEWAGE DISPOSAL SYSTEM

DEPARTMENT OF HEALTH AND MENTAL HYGIENE

INDEXED

HOWARD COUNTY HEALTH DEPARTMENT

BUREAU OF ENVIRONMENTAL HEALTH

461-9933

P 47575

A 44280

DISTRICT 3rd

DATE 9/30/91

DATE SYSTEM APPROVED 10/29/91

INSPECTOR RH

Charles A. Klein & Sons, Inc. IS PERMITTED TO INSTALL X ALTER

ADDRESS 5220 Klees Mill Road, Sykesville, Maryland 21784 PHONE 549-6960

SUBDIVISION Parkside LOT 6 ROAD 1811 Quarter Horse Drive

PROPERTY OWNER Vincent and Theresa Bracciale

ADDRESS 1830 Woodstock Road
Woodstock, Maryland 21163

SEPTIC TANK CAPACITY 1250 GALLONS

NUMBER OF BEDROOMS 4

180 SQUARE FEET PER BEDROOM

LINEAR FEET OF TRENCH REQUIRED 144

TRENCHES - Trench to be 2 feet wide. Inlet $3\frac{1}{2}$ feet below original grade. Bottom maximum depth $8\frac{1}{2}$ feet below original grade. Effective area begins at $3\frac{1}{2}$ feet below original grade. 5 feet of stone below distribution pipe.

LOCATION - Start the first trench 135' from the left lot line and 130' from the rear lot line. Run trenches along contour toward rear of lot.

NOTE - No trench to exceed 100 feet in length. Provide 6" - 8" diameter cleanout and cap to grade or above on septic tank. OK 7/10/91 RH

PLANS APPROVED BY Craig Williams cm DATE 10/15/90

COVER NO WORK UNTIL INSPECTED AND APPROVED

NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM

NOTE: CLEANOUT REQUIRED EVERY 70 FEET OF SEWER LINE AND/OR AT 90° SWEEPS IN LINES FROM HOUSE TO DRAIN FIELDS, 90° ELBOWS NOT ACCEPTABLE.

NOTE: ALL PARTS OF SEPTIC SYSTEMS (I.E. TANK, DISTRIBUTION BOX TRENCHES) TO BE 100 FEET FROM WELL (UNLESS OTHERWISE SPECIFICALLY AUTHORIZED)

NOTE: IF DEEP TRENCH(ES) ARE USED CALL FOR INSPECTION BEFORE AND AFTER PLACING GRAVEL IN TRENCH(ES)

NOTE: NO DRY WELL SHALL EXCEED 15 FOOT IN DIAMETER NO ABSORPTION TRENCH TO EXCEED 100 FEET IN LENGTH

NOTE: ALL PIPE FROM HOUSE TO SEPTIC TANK MUST BE CAST IRON OR SCHEDULE 35/40 PVC OR ABS

PERMIT VOID AFTER TWO YEARS

NOTE: INSTALL STAND PIPE ON SEPTIC TANK AND DRY WELL STAND PIPES MUST BE 6 INCHES IN DIAMETER CAST IRON. CONCRETE OR TERRA COTTA OR PVA OR ABS ACCEPTED. IF TOP OF SEPTIC TANK IS DEEPER THAN 3 FEET. MANHOLE TO GRADE REQUIRED.

NOTE: DISTRIBUTION BOXES MUST HAVE BAFFLES

***INSTALLER IS RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT**

A
44281

DETAIL 'A'
SCALE: 1"=20'

N 64° 25' 31" W 20.00'
N 75° 58' 45" W

EX. WELL

EX. S.D.A.

(6)

*SEE DETAIL

RESTRICTION LINE 7

MIN. BLOC.

QUARTER HORSE DRIVE
(50' R/W)

OK AS REVISED BY NANCY BROWN
6/28/91 C. W. McKEE ASSOC.

PROPOSED ELEVATIONS

FIRST FLOOR - 103.5
GARAGE - 101.5
BASEMENT FLOOR - 95.5

SEWER

IN OUT OF HOUSE 95.5
IN INTO SEPTIC TANK 93.1
OUT OF SEPTIC TANK 93.2
IN INTO DIST. BOX 92.2
OUT OF DIST. BOX 92.2
IN INTO TRENCHES 92.2

SITE PLAN
FOR

LOT 6

Δ 9681
LOTS 5-17

GRD ELECT. DIST.
SCALE: 1"=50'

CONTRACT PURCHASER

WILLIAM & BONNIE TEAL
3913 FOXHILL DRIVE
ELLICOTT CITY, MD 21043

OWNER

VINCENT & THERES
1830 WOODSTOCK
WOODSTOCK, VA

CKEE & ASSOCIATES, INC.
VIL ENGINEERS - LAND SURVEYORS
IAWAN PLACE 5 SHAWAN ROAD
INT VALLEY, MD 21030
ONE - (301) 527-1555