apper a 117101 Late PM

PERMIT

SEWAGE DISPOSAL SYSTEM

HOWARD COUNTY HEALTH DEPARTMENT

BUREAU OF ENVIRONMENTAL HEALTH 410-313-2640 A 56495

ISSUE DATE 7/16/2004

P 515340

APPROVAL DATE 7/18/01

IS PERMITTED TO INSTALL X ALTER WTC III RESS 1820 Gills Falls Road, Woodbine, MD 21797 PHONE 410-489-4457 DIVISION Spring Meadow Farm LOT NUMBER 4 ADDRESS 2351 Roxbury Mills Road PERTY OWNER Vozniak PROPERTY OWNER'S ADDRESS P.O. Box 310 (21794) **GALLONS** TIC TANK CAPACITY 1000 * WATERTIGHT SEPTIC TANK REQUIRED * MP CHAMBER CAPACITY N/A GALLONS MBER OF BEDROOMS 3 JARE FEET PER BEDROOM 180 EAR FEET OF TRENCH REQUIRED Trenches to be 3 feet wide. Inlet . 3.5 feet below original grade. Bottom maximum depth NCHES: 5.5 feet below original grade. 2 feet of stone below distribution pipe. ATION: Starting at the left front property corner (286.55'/129.42' intersection), place the distribution box 55 feet up the left (286.55') lot line and 85 feet off this same lot line. Run (3) trenches on contour to front of lot. 3/1/01 OK BB

ANS APPROVED Mark Rifkin, R.S.

DATE 2/27/2001

MIT VOID AFTER 2 YEARS

- E: CONTRACTOR RESPONSIBLE FOR SCHEDULING A PRE-CONSTRUCTION INSPECTION FOR ALL INSTALLATIONS
- E: TOP OF SEPTIC TANKS ARE TO BE NO DEEPER THAN 3.0 FEET BELOW FINISH GRADE
- E: WATERTIGHT SEPTIC TANKS REQUIRED
- E: CLEANOUT REQUIRED EVERY 70 FEET OF SEWER LINE AND/OR AT 90° SWEEPS IN LINES FROM HOUSE TO DRAIN FIELDS, 90° ELBOWS ARE NOT ACCEPTABLE
- E: ALL PARTS OF SEPTIC SYSTEMS (I.E. TANK, DISTRIBUTION BOX, DRAINFIELDS) TO BE 100 FEET FROM ANY WATER WELL UNLESS OTHERWISE SPECIFICALLY AUTHORIZED
- E: NO ABSORPTION TRENCH TO EXCEED 100 FEET IN LENGTH UNLESS SPECIFICALLY AUTHORIZED
- E: ALL PIPE FROM HOUSE TO SEPTIC TANK MUST BE CAST IRON OR SCHEDULE 35/40 PVC OR ABS
- E: MANHOLE RISERS REQUIRED ON ALL SEPTIC TANKS AND PUMP CHAMBERS
- E: DISTRIBUTION BOXES MUST HAVE BAFFLES
- :: IF PUMPED SEPTIC SYSTEM REQUIRED, (1) SEPTIC PUMP DETAIL TO BE PROVIDED BY INSTALLER PRIOR TO ISSUANCE OF SEPTIC PERMIT (2) PUMP PERFORMANCE TEST IS NECESSARY PRIOR TO HEALTH DEPARTMENT APPROVAL OF SEPTIC PERMIT

NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM

PERMITTEE RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT

CALL 410-313-2640 FOR INSPECTION OF SEPTIC SYSTEM

P 515340

HO-94-2889
30' 14' 10' 50'
JIO'ETE SO'

TRENCH DATA
TRENCH WIDTH
TRENCH INLET DEPTH 3.5'
TRENCH BOTTOM DEPTH 5.5
DEPTH OF STONE
NUMBER OF TRENCHES 3
TOTAL TRENCH LENGTH 180
ABSORBENT AREA 540+12
DISTRIBUTION BOX LEVEL
BAFFLE IN DISTRIBUTION BOX

SEPTIC TANK 1000 TS	GALLONS			
MANHOLE RISER On Cen	ter			
6 INCH INSPECTION PORT 6	. Front			
PUMP CHAMBER DATA				
PUMP CHAMBER	2			
GALLONS	<u>A</u>			
A	A A			
GALLONS // /	A			

SEPTIC TANK DATA

PRE-CONSTRUCTION	Route 9 INSPECTION:	77/16/01 For in	stell as be	r B.P. plan	. Easement not
NSPECTION COMMENT	NTS: <u>lanement</u> TO COVER	corners from	n property	corner sta	ker. (B)
				4)	
NSPECTOR Sto	ven R. 1	Crieg	DATE SYSTI	EM APPROVED _	7/18/01

