

LAYOUT _____

INSP 1 2/17/11 INSP 3 _____

INSP 2 _____ INSP 5 _____

ISSUE DATE:

11/18/10

APPROVAL
DATE:

7/8/11

PERMIT

SHARED SEPTIC SYSTEM

P

534096

A

Tax ID # 05-448719

HOUSE SEWER LINE CONNECTION

HOWARD COUNTY HEALTH DEPARTMENT BUREAU OF ENVIRONMENTAL HEALTH

South Carroll Backhoe

IS PERMITTED TO INSTALL ☒ ALTER ☐

ADDRESS:

440 Salem Bottom Rd Westminster MD 21157

PHONE NUMBER:

410-875-4197

SUBDIVISION

Walnut Grove

LOT NUMBER:

12

ADDRESS:

12212 Running Fence Lane

PROPERTY OWNER:

Huzefa and Michelle Bahrain

NUMBER OF BEDROOMS:

5

HOUSE SERVED BY PUBLIC WATER? NO

LOCATION:

Install 4" house sewer line connection per the approved site plan.

NOTES:

This permit is limited to the installation of the individual house sewer line connection and installation of the grinder pump, if applicable. The Howard County Bureau of Utilities must be contacted for scheduling of inspection of these items as well, at 410-313-4900.

PLANS APPROVED:

Heidi Scott

DATE:

7/27/10

PERMIT VOID AFTER 2 YEARS

1. CONTRACTOR IS RESPONSIBLE FOR SCHEDULING A PRE-CONSTRUCTION INSPECTION FOR ALL INSTALLATIONS.
2. ALL PARTS OF SEPTIC SYSTEM SHALL BE 100 FEET FROM ANY WATER WELL UNLESS SPECIFICALLY AUTHORIZED.
3. MANHOLE RISERS REQUIRED ON ALL SEPTIC TANKS AND PUMP CHAMBERS UNLESS SPECIFICALLY AUTHORIZED.
4. CONTRACTOR RESPONSIBLE FOR COMPLIANCE WITH APPLICABLE REGULATIONS, GUIDELINES AND THE TERMS OF THIS PERMIT.
5. NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM.
6. PERMITTEE RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT.

CALL 410-313-1771 FOR INSPECTION HOUSE CONNECTION

1" = 30'

NOT TO SCALE

HO-95-0569

75'

69'

Prop. Dome.

TRENCH/DRAINFIELD DATA

WIDTH INLET BOTTOM

NUMBER OF TRENCHES

TOTAL LENGTH

ABSORPTION AREA

DISTRIBUTION BOX LEVEL

DISTRIBUTION BOX BAFFLE

DISTRIBUTION BOX PORT

SEPTIC TANK DATA

SEPTIC TANK 1 LEVEL

MANUFACTURER

CAPACITY GAL

SEAM LOC

TANK LID DEPTH

BAFFLES

BAFFLE FILTER

MANHOLE LOC

6" PORT LOC

WATERTIGHT TEST

SLOTTED

PUMP/SEPTIC TANK LEVEL

MANUFACTURER

CAPACITY GAL

SEAM LOC

TANK LID DEPTH

BAFFLES

BAFFLE FILTER

MANHOLE LOC

6" PORT LOC

WATERTIGHT TEST

SLOTTED

PRE-CONSTRUCTION

INSTALLATION:

2/17/11 1.5% fall on pipe. Connection made to
1/0 @ grinder pump. Need verification of grinder pump
start-up from utilities. (KW)
7/8/11 Confirmation of grinder pump start-up received
by the office

FINAL INSPECTOR

(KW)

DATE OF APPROVAL

7/8/11

