

WATER RESOURCES DIVISION
WELL LOG

DATE WELL COMPLETED 9/10/77 DEPTH OF WELL 250 DRILLER'S IDENTIFICATION NO. 10

OWNER State of Ohio LAST NAME State FIRST NAME State
STREET OR RFD 21720 OFFICE 21720

WELL LOG
STATE THE KIND OF FORMATIONS PENETRATED, PERMIT COLOR, DEPTH, THICKNESS AND IF WATER BEARING

DESCRIPTION (USE UNIVERSAL SHEETS IF NECESSARY)	FEET	THICKNESS	WATER BEARING
FROM	TO		
OB	0	20	
slate	20	250	✓

GRouting RECORD
ALL HAS BEEN GROUTED (CIRCLE APPROPRIATE BOX)
TYPE OF GROUTING MATERIAL (CIRCLE BOX)
NO. OF BAGS 9 NO. 5 POUNDS 900
GALLONS OF WATER 45
DEPTH OF GROUT SEAL (ITS NEAREST FOOT)
FROM 0 TO 39 1/2 FT. (ENTER 0 IF FROM SURFACE)
CIRCUIT TYPE (CIRCLE APPROPRIATE CODE BELOW)
STEEL ST CONCRETE CO
PLASTIC PL OTHER OT
MAIN CASING TYPE 2 NOMINAL DIAMETER OF MAIN CASING (NEAREST INCH) 6 TOTAL DEPTH OF MAIN CASING (NEAREST FOOT) 39 1/2

CASING RECORD
OTHER CASING (IF USED)
DIAMETER (INCH) 4 DEPTH (FEET) 10
EACH CASING

SCREEN RECORD
SCREEN TYPE OR OPEN HOLE (CIRCLE APPROPRIATE CODE BELOW)
STEEL ST BRASS BR OPEN HOLE HO
PLASTIC PL OTHER OT
C 2
1 2 3 (SEE NO.) 0
DEPTH (NEAREST WHOLE FOOT)
FROM 39 1/2 TO 250
EACH SCREEN
1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100
SLOT SIZE 1. 1 2. 2 3. 3

CIRCLE APPROPRIATE BOXES
☐ A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED
☐ E ELECTRIC LOG OBTAINED
☐ TEST WELL CONVERTED TO PRODUCTION WELL

I HEREBY CERTIFY THAT I HAVE COMPLIED WITH ALL CONDITIONS STATED ON THE ABOVE-CAPTIONED "PERMIT TO DRILL WELL", AND THAT INFORMATION CONTAINED IN THIS REPORT IS TRUE, ACCURATE, AND COMPLETE TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF.

DRILLER'S NAME Kepler
PLEASE PRINT Kepler
SIGNATURE Kepler

WRA USE ONLY (NOT TO BE FILLED IN BY DRILLER)
TELESCOPE CASING 70 LOG INDICATOR 72 OTHER DATA AVAILABLE 74 75 76

PUMPING TEST
HOURS PUMPED (TO NEAREST HOUR) 2
PUMPING RATE (GALLONS PER MINUTE TO NEAREST GALLON) 2
METHOD USED TO MEASURE PUMPING RATE PIR
WATER LEVEL (DISTANCE FROM LAND SURFACE)
DEPTH PUMPING 17 (NEAREST FOOT)
WHEN PUMPING 70 (NEAREST FOOT)
TYPE OF PUMPER USED (CIRCLE APPROPRIATE BOX FOR PUMPING TEST)
A AIR 27 PISTON 27 TURBINE 27
C CENTRIFUGAL 27 ROTARY 27 OTHER (DESCRIBE BELOW) 27
J JET 27 SUBMERSIBLE 27

PUMP INSTALLED
TYPE OF PUMP (WRITE APPROPRIATE LETTER IN BOX - SEE ABOVE: A, C, J, P, T, S, V, W)
DRILLER WILL INSTALL PUMP (CIRCLE APPROPRIATE BOX)
CAPACITY:
GALLONS PER MINUTE (TO NEAREST GALLON) 31
PUMP HORSE POWER 37
PUMP COLUMN LENGTH (NEAREST FOOT) 45
CASING HEIGHT (CIRCLE APPROPRIATE BOX AND ENTER CASING HEIGHT)
ABOVE 45 BELOW 45 LAND SURFACE 2 (NEAREST FOOT)

LOCATION OF WELL ON LOT
SHOW PERMANENT STRUCTURE SUCH AS BUILDINGS, SEPTIC TANKS, AND/OR OTHER LAND MARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL).
15' 47'
25'
60'