

WATER RESOURCES ADMINISTRATION

TOWNSHIP OFFICE BLDG., ANNAPOLIS, MD. 21401

WELL COMPLETION REPORT

FALL IN THIS

COUNTY NUMBER

DRUG RECEIVED (SEE USE ONLY)

DATE WELL COMPLETED

DEPTH OF WELL

PERMIT NO. FROM "PERMIT TO DRILL WELL"

401-125-1496

DRILLER'S IDENTIFICATION NO.

OWNER Judge Joseph

STREET OR RFD 6349 Amberst Ave.

POST OFFICE ELLICOTT CITY Md.

WELL LOG

STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING

DESCRIPTION (USE ADDITIONAL SHEETS IF NECESSARY)	FEET	THICKNESS
Top Soil	0	2
Shale	2	18
Blue Slate	18	25
Brown Slate	25	37
Blue Slate	37	165

GROUTING RECORD

WELL HAS BEEN GROUTED (CIRCLE APPROPRIATE BOX)

TYPE OF GROUTING MATERIAL (CIRCLE BOX)

CEMENT ☒ BENTONITE CLAY ☒

NO. OF BAGS 16 NO. OF POUNDS 1600

GALLONS OF WATER 80

DEPTH OF GROUT SEAL (TO NEAREST FOOT)

FROM 2 FT. TO 36 FT.

(ENTER 0 IF FROM SURFACE)

CASING RECORD

CASING TYPES (CIRCLE APPROPRIATE CODE BELOW)

STEEL ☒ CONCRETE ☒

PLASTIC ☒ OTHER ☒

MAIN CASING TYPE 5

NOMINAL DIAMETER TOP (MAIN) CASING (NEAREST INCH) 6

TOTAL DEPTH OF MAIN CASING (NEAREST FOOT) 40

OTHER CASING (IF USED) DIAMETER (INCH) DEPTH (FEET) FROM TO

SCREEN TYPE OR SIZE

STEEL ☒ BRASS ☒ OPEN HOLE ☒

PLASTIC ☒ OTHER ☒

C 2

1 2 3 (SEQ. NO.) 6

DEPTH (NEAREST WHOLE FOOT)

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100

SCREEN SIZE 1. 2. 3.

DIAMETER OF SCREEN 58 (NEAREST INCH) FROM TO

GRAVEL PACK

IF WELL DRILLED WAS A FLOWING WELL CIRCLE BOX ☒

WPA USE ONLY (NOT TO BE FILLED IN BY DRILLER)

TELESCOPE CASING LOG INDICATOR

PUMPING TEST

HOURS PUMPED (TO NEAREST HOUR) 2

PUMPING RATE GALLONS PER MINUTE TO NEAREST GALLON 4

METHOD USED TO MEASURE PUMPING RATE BUCKET

WATER LEVEL (DISTANCE FROM LAND SURFACE) BEFORE PUMPING 40 (NEAREST FOOT)

WHEN PUMPING 165 (NEAREST FOOT)

TYPE OF PUMPED USED (CIRCLE APPROPRIATE BOX)

AIR ☒ PISTON ☒ TURBINE ☒

CENTRIFUGAL ☒ ROTARY ☒ OTHER (DESCRIBE BELOW)

JET ☒ SUBMERSIBLE ☒

PUMP INSTALLED

TYPE OF PUMP (WRITE APPROPRIATE LETTER IN BOX - SEE ABOVE: A, C, J, P, R, S, T, O)

DRILLER WILL INSTALL PUMP (CIRCLE APPROPRIATE BOX) YES ☒ NO ☒

CAPACITY: GALLONS PER MINUTE (TO NEAREST GALLON) 31 35

PUMP HORSE POWER 37 41

PUMP COLUMN LENGTH (NEAREST FOOT) 43 47

CASING HEIGHT (CIRCLE APPROPRIATE BOX AND ENTER CASING HEIGHT)

ABOVE ☒ BELOW ☒ LAND SURFACE 2 (NEAREST FOOT)

LOCATION OF WELL ON LOT

SHOW PERMANENT STRUCTURE SUCH AS BUILDINGS, SEPTIC TANKS, AND/OR OTHER LAND MARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL).

WELL 30 HOUSE 125

CIRCLE APPROPRIATE BOXES

A A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED

E ELECTRIC LOG OBTAINED

P TEST WELL CONVERTED TO PRODUCTION WELL

I HEREBY CERTIFY THAT I HAVE COMPLIED WITH ALL CONDITIONS STATED ON THE ABOVE-CAPTIONED "PERMIT TO DRILL WELL", AND THAT INFORMATION CONTAINED IN THIS REPORT IS TRUE, ACCURATE, AND COMPLETE TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF.

DRILLER'S NAME

(PLEASE PRINT)

SIGNATURE