

APPLICATION

SEWAGE DISPOSAL TESTING

A 09223

P

MARYLAND STATE DEPARTMENT OF HEALTH

HOWARD COUNTY

ELLCOTT CITY

See the tank - 1200

DISTRICT 5

1,500
Leaching bed - 208 sq. ft. bottom area in sub-basement. Depth
lead to bottom of ground to bed 5 1/2 ft below
original grade.

DATE 10/26/65

TO: THE COUNTY HEALTH OFFICER
ELLCOTT CITY, MARYLAND

I, HEREBY, APPLY FOR THE NECESSARY TESTS IN ORDER TO CONSTRUCT OR RECONSTRUCT A SEWAGE DISPOSAL SYSTEM.

PROPERTY OWNER Anne E. Gray & Susan Kondrup

ADDRESS 5132 Loughboro Rd., Washington 16, D. C. PHONE 363-5335

PROPERTY LOCATION:

SUBDIVISION Beaufort Park

LOT NO. 4, Blk. B.

ROAD AND DESCRIPTION Reservoir Rd.

Drivewell located 81 ft. from left side line and
120 ft. from front lot line, depth to be no deeper
than 4 ft. - maximum depth was

PERSON TO CONSTRUCT SYSTEM

ADDRESS ~~Reservoir Rd.~~ 10 1/2 ft. unless water encountered

SIZE OF LOT 40,000 sq. ft. 125 sq. ft. per bedroom (4) rest of bedroom

IF NOT SINGLE RESIDENCE DESCRIBE

** (300 sq. ft. drivewell @ 30 ft. trench & pipe trench 1/2 in. if need trench to run for drivewell toward right property line)*

SIGNATURE OF APPLICANT /s/ Gray & Kondrup

APPROVED BY 3-29-73

FOR Lead in bed

DATE 1/8/65

REJECTED BY

FOR personal hole at 10 1/2 ft. (B.S.)

DATE

HOLD PENDING FURTHER TESTS

DATE

REASONS FOR REJECTION OR HOLDING

Geo. Schless
16614 Greenacre Ave.
Two dates, no
20840

THIS IS NOT A PERMIT

ALSO PRESENT LOT NO. 4B

REMARKS: Note of 13 ft. of gravelly soil below the surface of the soil.

TESTED BY: JOT 10/28/64

SOIL AUGER FINDING: 3 1/2 ft. clayed - 5 ft. gravelly soil

DATE	TEST NO.	DEPTH	START	STOP	TEST - 1" PROB	TIME
10/28/64	1	9 ft	1152	1154	1154	1:58.4 min
	2	5 ft	1153	1205	1205	12:30.25 min
	3	9 ft	1155	1158	1158	12:05 min
	4	5 ft	1157	1202	1202	12:12.10 min

