

11862 SECURITY NO (WRA USE ONLY) STATE OF MARYLAND WELL COMPLETION REPORT THIS REPORT MUST BE SUBMITTED WITHIN 30 DAYS AFTER WELL IS COMPLETED
FILL IN THIS FORM COMPLETELY PLEASE PRINT OR TYPE COUNTY NUMBER 19 20339

Date Received (WRA use only) DATE WELL COMPLETED 07/05/94 Depth of Well 300 (TO NEAREST FOOT) PERMIT NO. FROM "PERMIT TO DRILL WELL" 190-51-0592

OWNER SHRYOCK Emma & Jeff STREET OR RD. PHILADELPHIA RD. TOWN MAYFIELD SUBDIVISION MAYFIELD MANOR SECTION LOT 7

STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING

DESCRIPTION (Use additional sheets if needed)	FEET FROM	TO	Check of water bearing
Top Soil	0	2	
Sandy	2	8	✓
Sandstone	8	30	
Clay	30	45	
Sandstone	45	50	✓
Clay	50	300	

CIRCLE APPROPRIATE BOX
☒ A A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED
☐ E ELECTRIC LOG OBTAINED
☐ P TEST WELL CONVERTED TO PRODUCTION WELL
 I HEREBY CERTIFY THAT I HAVE COMPLIED WITH ALL CONDITIONS STATED ON THE ABOVE-CAPTIONED "PERMIT TO DRILL WELL", AND THAT INFORMATION CONTAINED IN THIS REPORT IS TRUE, ACCURATE, AND COMPLETE TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF.
 DRILLERS IDENT NO. [Signature]
 DRILLERS SIGNATURE [Signature]
 MUST MATCH SIGNATURE ON APPLICATION
 SITE SUPERVISOR (sign of driller or journeyman responsible for sitework if different from permittee)

WELL HAS BEEN GROUTED (Circle Appropriate Box) ☒ Y ☐ N

TYPE OF GROUTING MATERIAL CEMENT ☒ B BENTONITE CLAY ☐ C
 NO. OF BAGS 6 NO. OF POUNDS 250
 GALLONS OF WATER 48
 DEPTH OF GROUT SEAL (to nearest foot): from 0 ft. to 46 ft. (Enter 0 if from surface)

CASING RECORD
 Casing type (insert appropriate code below) ☒ ST STEEL ☐ CO CONCRETE ☐ PL PLASTIC ☐ OT OTHER

MAIN CASING TYPE Normal diameter (nearest inch) 6 Total depth of main casing (nearest foot) 28

OTHER CASING (if used) diameter (nearest inch) depth (feet) from to

SCREEN RECORD
 Screen type (insert appropriate code below) ☒ ST STEEL ☐ BR BRASS ☐ HO OPEN HOLE ☐ PL PLASTIC ☐ OT OTHER

DEPTH (nearest ft.) 300
 SLOT SIZE 2
 DIAMETER OF SCREEN (NEAREST INCH) 4
 GRAVEL PACK IF WELL DRILLED WAS FLOWING WELL (CIRCLE BOX) ☐ F
 WRA USE ONLY (NOT TO BE FILLED IN BY DRILLER)
 T (E.R.O.S.) W Q
 TELESCOPE CASING LOG INDICATOR OTHER DATA

C 3

PUMPING YES ☒ 6 HOURS PUMPED (nearest hour)
 PUMPING RATE (gal. per min. to nearest gal.) I
 METHOD USED TO MEASURE PUMPING RATE Bucket
 WATER LEVEL (distance from land surface) BEFORE PUMPING 5 WHEN PUMPING 2
 TYPE OF PUMP USED (See list) ☒ A air ☐ P piston ☐ T turbine ☐ C centrifugal ☐ R rotary ☐ O other (describe below) ☐ J jet ☒ S submersible

PUMP INSTALLED YES ☒ NO ☐ DRILLER WILL INSTALL PUMP (CIRCLE APPROPRIATE BOX) ☐ Y ☒ N

IF DRILLER INSTALLS PUMP, THIS SECTION MUST BE COMPLETED FOR ALL WELLS EXCEPT HOME USE
 TYPE OF PUMP (WRITE APPROPRIATE LETTER IN BOX - SEE ABOVE: A, C, J, P, R, S, T, O)
 CAPACITY: GALLONS PER MINUTE (to nearest gallon)
 PUMP HORSE POWER
 PUMP COLUMN LENGTH (nearest ft.)
 CASING HEIGHT (circle appropriate box and enter casing height) ☒ + above LAND SURFACE ☐ - below 2 (nearest foot)

LOCATION OF WELL ON LOT
 SHOW PERMANENT STRUCTURE SUCH AS BUILDING, SEPTIC TANKS, AND/OR LANDMARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL)
 [Diagram showing well location on lot with distances to building and septic tank]