

COUNTY #

SOIL PROFILE

0'

①
Brown
top soil
L

1
red
brown
SCL
micaceous

3/4
red brown
micaceous
L w/ 10-15%
weak
sugilite

16

①

Highland Rd

well (pit)

6

5

2" conc
C/O

40

78'

100'

134'

0'

SOIL PROFILE

INDICATE NORTH NAME ADJOINING ROADWAY AS BASE LINE.

DATE	TEST NO.	DEPTH	PRE-WET		TEST - 1" DROP		TIME
			START	STOP	START	STOP	
1/21/02	①	5 / 16	11:50:15	11:53:45	11:53:45	11:59:30	5:45 OK

REMARKS

TYPE OF SOIL

TESTED BY

S. Boris

ALSO PRESENT

Robert Fyock

TRENCH DESIGN DATA: AVERAGE PERCOLATION TIME

5:45

TRENCH WIDTH

3

INLET DEPTH

4

MAXIMUM BOTTOM DEPTH

7

SQ. FT./BEDROOM

180