

STATE OF MISSOURI
 DEPARTMENT OF REVENUE
WELL COMPLETION REPORT
 COUNTY NUMBER 120
 PERMIT NO. FROM (PERMIT TO DRILL WELL)
 DATE RECEIVED (SEE BACK ONLY) 04-28-74
 DATE WELL COMPLETED 04-28-74
 DEPTH OF WELL 120
 DRILLER IDENTIFICATION NO. 73

OWNER Ellington
 STREET OR RPO 1545 N. Main St.
 POST OFFICE HO-73-0796

WELL LOG

STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING

DEPTH	FORMATION	WATER BEARING
0 to 20	Loess	
20 to 120	Prague Limestone	

GRouting RECORD

WELL HAS BEEN GROUTED (CIRCLE APPROPRIATE BOX)

TYPE OF GROUTING MATERIAL (CIRCLE ONE)

CEMENT ☒ CM DENTONITE SLAY ☒ DC

NO. OF BAGS 6 NO. OF POUNDS 360

GALLONS OF WATER 36

DEPTH OF GROUT SEAL (TO NEAREST FOOT)

FROM 0 FT. TO 20 FT.

CASING RECORD

LASTING TYPE (CIRCLE ONE)

INSTEAD OF TYPE (CIRCLE ONE)

STEEL ☒ CONCRETE ☒ PLASTIC ☒ OTHER ☐

MAIN CASING TYPE S 1 1/2

NOMINAL DIAMETER (TO NEAREST INCH) 22

TOTAL DEPTH OF MAIN CASING (NEAREST FOOT)

OTHER CASING (IF UP)

DIAMETER (INCH) 1 1/2 DEPTH (FEET) 10

SCREEN RECORD

INSERT (CIRCLE ONE)

SCREEN TYPE (CIRCLE ONE)

STEEL ☒ PLASTIC ☒ OTHER ☐

DEPTH (NEAREST WHOLE FOOT)

FROM 0 TO 120

DIAMETER OF SCREEN (NEAREST INCH)

FROM 0 TO 120

GRAVEL PACK

IF WELL DRILLED WAS A FLOWING WELL (CIRCLE ONE)

YES ☐ NO ☒

WRA USE ONLY (NOT TO BE FILLED IN BY DRILLER)

TELEPHONE CORDING ☐ LOG INDICATOR ☐

PUMPING TEST

WATER PUMPED ITS NEAREST, NEAREST 7

PUMPING RATE (GALLONS PER MINUTE TO NEAREST GALLON) 8

METHOD USED TO MEASURE PUMPING RATE 1

WATER LEVEL (DISTANCE FROM LAND SURFACE)

DEPTH OF PUMPING 3 FEET

TYPE OF PUMPER USED (CIRCLE APPROPRIATE BOX)

A AIR ☐ B MOTOR ☐ C CENTRIFUGAL ☐ D ROTARY ☐ E JET ☐ F OTHER (DESCRIBE BELOW)

PUMP INSTALLER

TYPE OF PUMP (WRITE APPROPRIATE LETTER IN BOX - SEE ABOVE) A, C, J, P, R, S, T, O

DRILLER WILL INSTALL PUMP (CIRCLE ONE)

YES ☒ NO ☐

CAPACITY: GALLONS PER MINUTE (TO NEAREST GALLON) 8

PUMP HORSE POWER 1

PUMP COLUMN LENGTH (NEAREST FOOT) 3

CASING HEIGHT (CIRCLE APPROPRIATE BOX)

ABOVE ☐ BELOW ☒

LAND SURFACE 2 FEET

LOCATION OF WELL ON LOT

SHOW PERMANENT STRUCTURE SUCH AS BUILDINGS, SEPTIC TANKS, AND/OR OTHER LAND MARKS AND INDICATE NOT LESS THAN TWO DISTANCES (NEAREST FEET) TO WELL.

50 FEET

10 FEET

CIRCLE APPROPRIATE BOXES

A A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED

E ELECTRIC LOG OBTAINED

P TEST WELL CONVERTED TO PRODUCTION WELL

I HEREBY CERTIFY THAT I HAVE COMPLIED WITH ALL CONDITIONS STATED ON THE ABOVE CAPTIONED "PERMIT TO DRILL WELL", AND THAT INFORMATION CONTAINED IN THIS REPORT IS TRUE, ACCURATE, AND COMPLETE TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF.

DRILLER'S NAME J. S. L. H. H. H.

PRINT NAME J. S. L. H. H. H.

SIGNATURE J. S. L. H. H. H.