

PERMIT

SEWAGE DISPOSAL SYSTEM

MARYLAND STATE DEPARTMENT OF HEALTH

HOWARD COUNTY

ELLICOTT CITY

DISTRICT 2nd

DATE 8/13/81

INDEX
02379058

Costello Builders

IS PERMITTED TO INSTALL X ALTER

ADDRESS Box 2201 Route 94, Woodbine, Maryland 21797 PHONE 442-2288

SUBDIVISION Terra Maria ROAD 3173 SAINT CHARLES RACE LOT 106

PROPERTY OWNER Nr. & Mrs. Robert J. Lancelotta Pete & Elizabeth Horowitz

ADDRESS 2121 Oak Lodge Road, Baltimore, Md. 21228 Phone: 788-4344

SPECIFICATIONS 3 bedrooms

SEPTIC TANK CAPACITY 1000 GALLONS

DRAIN FIELD _____ DEPTH _____ FEET, BOTTOM AREA _____ SQ. FT.

DEEP TRENCH _____ DEPTH _____ FEET, BOTTOM AREA _____ SQ. FT.

DRY WELL SEEPAGE PITS XXX ABSORBENT SIDE-WALL AREA 130 SQ. FT. per bedroom

INLET PIPE 3 FT. BELOW ORIGINAL GRADE, MAXIMUM DEPTH 10 FT. BELOW ORIGINAL GRADE

EFFECTIVE DEPTH AT 4 FT. BELOW ORIGINAL GRADE.

LOCATE DISPOSAL AREA _____ FT. FROM _____ LOT LINE AND _____ FT. FROM _____ LOT LINE AS SEEN WHEN

FACING LOT FROM

Place the dry well 1000 ft. more or less ~~from~~ from the front lot line and 420 feet from lot

the left lot line as seen when facing the ~~HOUSE~~ from Route 144 (perc hole #2). Okay to run a deep ditch off dry well after a 5 foot earth buffer to make additional sidewall area. Inlet to ditch to be 4 ft. deep below original grade and bottom to be 10 ft. deep below original grade. Ditch to have 6 ft. of stone. Run ditch toward perc hole #4. Perc hole location is shown on the perc test certification plat.

PLANS APPROVED BY Raymond Hodges OK TO DATE 2/6/81

COVER NO WORK UNTIL INSPECTED AND APPROVED.

NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM.

NOTE: IF TRENCH IS USED CALL FOR INSPECTION BEFORE PLACING GRAVEL IN TRENCH.

NOTE: NO DRY WELL SHALL EXCEED 15 FOOT IN DIAMETER.

NOTE: ALL PIPE FROM HOUSE TO DISPOSAL AREA MUST BE CAST IRON.

PERMIT VOID AFTER THREE YEARS.

NOTE: INSTALL STAND PIPE ON SEPTIC TANK AND DRY WELL. STAND PIPES MUST BE 6 INCHES IN DIAMETER. CAST IRON, CONCRETE OR TERRA

COTTA ACCEPTED.

*INSTALLER IS RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT.

OLD PERMIT SIGNED

AND RETURNED 7/17/95

Serial # 60705
~~at~~ found for
New Garage

OLD PERMIT SIGNED

AND RETURNED 7/17/95

Serial # 60705
move of garage
from one spot to
another

EH-2-1079

