

Preliminary

APPLICATION

SEWAGE DISPOSAL TESTING

A 16815
P _____

MARYLAND STATE DEPARTMENT OF HEALTH

HOWARD COUNTY *Septic Tank 1000 gallons - 3 Bedrooms* ELLICOTT CITY

1250 gallons - 4 Bedrooms DISTRICT 5th

*Dry Well To have 100 sq ft effective absorbent
sidewall area per bedroom below inlet. Inlet to be 3' below
original grade and maximum depth 1 1/2' below original
grade. Location 135' from left property line and 130'
from back property line of lot when facing lot from
Reservoir road.*

DATE 3-72

TO: THE COUNTY HEALTH OFFICER
ELLICOTT CITY, MARYLAND

I, HEREBY, APPLY FOR THE NECESSARY TESTS IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE DISPOSAL SYSTEM.

PROPERTY OWNER Otis A. Mauck, Seymour W. Mauck, Herman E. Mauck, Bernard L. Mauck
and Linda Jones Blyton

ADDRESS Lime Kiln Rd, Fulton, Md

PHONE 725-4628

PROPERTY LOCATION:

SUBDIVISION Mauck Farm Estates

LOT NO. No. 6 & 7 Combine
into lot 6

ROAD AND DESCRIPTION Reservoir Road - Macadam

OCCUPANT _____

PHONE _____

PERSON TO CONSTRUCT SYSTEM _____

ADDRESS _____

PHONE _____

SIZE OF LOT 40,000 + sq feet

TYPE BLDG. 4 bedrooms
Dwelling

NUMBER OF BEDROOMS

IF NOT SINGLE RESIDENCE DESCRIBE _____

SIGNATURE OF APPLICANT Otis Mauck

APPROVED BY R. T. ...

FOR Dry Well

(KIND OF SYSTEM)

DATE June 30, 1972

REJECTED BY _____

FOR _____

(KIND OF SYSTEM)

DATE _____

HOLD PENDING FURTHER TESTS _____

DATE _____

REASONS FOR REJECTION OR HOLDING _____

THIS IS NOT A PERMIT

APPLICATION

SEWAGE DISPOSAL TESTING

MARYLAND STATE DEPARTMENT OF HEALTH

HOWARD COUNTY

ELLICOTT CITY

DISTRICT 5th

DATE 3-72

A 16814
P _____

TO: THE COUNTY HEALTH OFFICER
ELLICOTT CITY, MARYLAND

I, HEREBY, APPLY FOR THE NECESSARY TESTS IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE DISPOSAL SYSTEM.

PROPERTY OWNER Otis A. Mauck, Seymour W. Mauck, Herman E. Mauck, Bernard L. Mauck
and Linda Jones Blyton

ADDRESS Lime Kiln Rd, Fulton, Md

PHONE 725-4628

PROPERTY LOCATION:

SUBDIVISION Mauck Farm Estates

*Combined with lot # 6
No. 7 from preliminary*

ROAD AND DESCRIPTION Reservoir Rd - Mcadam

OCCUPANT _____

PHONE _____

PERSON TO CONSTRUCT SYSTEM _____

ADDRESS _____

PHONE _____

SIZE OF LOT 40,000 + sq feet

TYPE BLDG. Dwelling

NUMBER OF BEDROOMS _____

IF NOT SINGLE RESIDENCE DESCRIBE _____

SIGNATURE OF APPLICANT Otis Mauck

APPROVED BY _____

FOR _____

DATE _____

(KIND OF SYSTEM)

REJECTED BY _____

FOR _____

DATE _____

(KIND OF SYSTEM)

HOLD PENDING FURTHER TESTS _____

DATE _____

REASONS FOR REJECTION OR HOLDING _____

THIS IS NOT A PERMIT

