

OWR 214 8/71

C 1 1563 (THIS NUMBER IS TO BE PUNCHED IN COLS. 2-6 ON ALL CARDS)		SEQUENCE NO. (PRAUSE ONLY) STATE OF MARYLAND WATER RESOURCES ADMINISTRATION TAWES STATE OFFICE BLDG., ANNAPOLIS, MD. 21401 WELL COMPLETION REPORT	THIS REPORT MUST BE SUBMITTED WITHIN 30 DAYS AFTER WELL COMPLETION FILL IN THIS FORM COMPLETELY COUNTY NUMBER <u>AI2974</u>
DATE RECEIVED (WRA USE ONLY) <u>March 29 1974</u>	DATE WELL COMPLETED 15 16 17 18 19 20	DEPTH OF WELL <u>75</u> 22 (TO NEAREST FOOT) 26	PERMIT NO. FROM "PERMIT TO DRILL WELL" <u>HO-145-0612</u> 28 29 30 31 32 33 34 35 36 37
OWNER <u>DORSEY</u> LAST NAME		FIRST NAME <u>ROGER</u> STREET OR RFD <u>6636 CEDAR LN.</u> POST OFFICE <u>COLUMBIA, MD. 21044</u>	

WELL LOG STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING		GROUTING RECORD WELL HAS BEEN GROUTED (CIRCLE APPROPRIATE BOX) YES ☒ NO ☐ TYPE OF GROUTING MATERIAL (CIRCLE BOX) CEMENT ☒ BENTONITE CLAY ☐ NO. OF BAGS <u>8</u> NO. OF POUNDS <u>752</u> GALLONS OF WATER <u>48</u> DEPTH OF GROUT SEAL (TO NEAREST FOOT) FROM <u>0</u> FT. TO <u>22</u> FT. (ENTER 0 IF FROM SURFACE)	
DESCRIPTION SHAKE Rock 0 22 FLINT Rock 22 75	FEET FROM TO 0 22 22 75	CASING RECORD Casing Type ☒ STEEL ☐ CONCRETE MAIN CASING TYPE ☒ ST ☐ PL ☐ OT NOMINAL DIAMETER TOP (MAIN) CASING (NEAREST INCH) <u>6</u> TOTAL DEPTH OF MAIN CASING (NEAREST FOOT) <u>24</u>	
OTHER CASING (IF USED) DIAMETER (INCH) <u>6</u> DEPTH (FEET) <u>24</u>		SCREEN RECORD SCREEN TYPE OR OPEN HOLE ☒ ST ☐ BR ☐ HO DIAMETER OF SCREEN (NEAREST INCH) <u>6</u> DEPTH (NEAREST WHOLE FOOT) <u>75</u>	
PUMPING TEST HOURS PUMPED (TO NEAREST HOUR) <u>2</u> PUMPING RATE GALLONS PER MINUTE TO NEAREST GALLON <u>10</u> METHOD USED TO MEASURE PUMPING RATE <u>Baler</u> WATER LEVEL (TO NEAREST FOOT) BEFORE PUMPING <u>35</u> WHEN PUMPING <u>0</u> (NEAREST FOOT) TYPE OF PUMPED USED (CIRCLE APPROPRIATE BOX) FOR PUMPING TEST AIR ☐ PISTON ☐ TURBINE ☐ CENTRIFUGAL ☐ ROTARY ☐ OTHER (DESCRIBE BELOW) ☐ JET ☐ SUBMERSIBLE ☐ <u>Baler</u>		PUMP INSTALLED TYPE OF PUMP (WRITE APPROPRIATE LETTER IN BOX - SEE ABOVE: A, C, J, P, R, S, T, O) DRILLER WILL INSTALL PUMP (CIRCLE APPROPRIATE BOX) YES ☒ NO ☐ CAPACITY: GALLONS PER MINUTE (TO NEAREST GALLON) <u>31</u> PUMP HORSE POWER <u>37</u> PUMP COLUMN LENGTH (NEAREST FOOT) <u>43</u>	
CIRCLE APPROPRIATE BOXES: A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED E ELECTRIC LOG OBTAINED P TEST WELL CONVERTED TO PRODUCTION WELL		CASING HEIGHT (CIRCLE APPROPRIATE BOX AND ENTER CASING HEIGHT) ABOVE ☐ BELOW ☒ LAND SURFACE <u>2</u> (NEAREST FOOT) LOCATION OF WELL ON LOT SHOW PERMANENT STRUCTURE SUCH AS BUILDINGS, SEPTIC TANKS, AND/OR OTHER LAND MARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL). <u>Front</u> <u>35'</u> <u>a Well</u>	
I HEREBY CERTIFY THAT I HAVE COMPLIED WITH ALL CONDITIONS STATED ON THE ABOVE-CAPTIONED "PERMIT TO DRILL WELL", AND THAT INFORMATION CONTAINED IN THIS REPORT IS TRUE, ACCURATE, AND COMPLETE TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF. DRILLER'S NAME PLEASE PRINT: <u>RALPH MAYNE</u> SIGNATURE: <u>Ralph Mayne</u>		IF WELL DRILLED WAS A FLOWING WELL CIRCLE BOX ☒ WRA USE ONLY (NOT TO BE FILLED IN BY DRILLER) TELESCOPE CASING ☐ LOG INDICATOR ☐ OTHER DATA AVAILABLE ☐	

HEALTH