

**TRACE LABORATORIES, INC**

5 North Park Drive

Hunt Valley, MD 21030 USA

Telephone: 410/584-9099 / Fax: 410/584-9117

Website: www.tracelabs.com / Email: info@tracelabs.com

Maryland State Certified Laboratory #318

**CERTIFICATE OF ANALYSIS****Requester:**

Envision Builders  
Attn: Al Guerieri  
7939 Honeygo Boulevard, Suite 112  
Nottingham, Maryland 21236

**S/O Number:** 93095**Report Date:** May 15, 2014*Follow Up*

**Property Sampled:** 15156 Bushy Park Road, 21797  
**Sample Location:** Pressure Tank Tap  
**Residual Chlorine:** <0.1 mg/L

**Building Permit #:** B13003238  
**Sampler ID #:** 7483AM  
**Samples Iced:** Yes

**County:** Howard**Subdivision:** Country Springs Overlook**Lot#:** 2**Date/Time Collected in Field:** May 14, 2014 12:00 pm**Date/Time Received in Lab:** May 14, 2014 3:10 pm**Well Tag #:** HO-95-2280**Well Condition:** 2-Piece Cap, Satisfactory**Water Treatment/Conditioning:** None

PARAMETER	METHOD	MCL	RESULT	COMMENT
Total Coliform	SM 9223B	Absent	Absent	Pass
E. coli	SM 9223B	Absent	Absent	Pass

The results in this report relate only to those items tested. If any additional information or clarification of this report is required, please contact us. This test report shall not be reproduced except in full without the written approval of Trace Laboratories Inc.

Katherine C. Higgs

Manager – Drinking Water Testing