

CASSELL TESTING, INC.

ENVIRONMENTAL SAMPLING AND TESTING
10940 BEAVER DAM ROAD, HUNT VALLEY, MD 21030-2211
(410) 252-7742

CERTIFICATE OF ANALYSIS

Maryland State Certified Water Quality

Laboratory No. 115

REQUESTER:

Custom Plumbing & Heating
Attention: Mike
6482 Grommet Drive
Elkridge, Maryland 21075

REPORT DATE: Jul 2, 2004

County Howard

Lab Number 04-3107

Sample iced Yes
Residual Cl_2 <0.1 mg/L Yes

cc: County Health Dept. Yes

Property Sampled: U&O: 3603 Clear Drive Court

Station Sampled: Laundry tub tap

Date/Time Sampled: Jul 1, 2004 11:05 am

Owner, Telephone No.: Van Horn

Subdivision Name: Wellington

Building Permit No.: B00136528

Well Number: HO-94-3261

Tax Map #: 14

Parcel #: 73

Sampler: 6724GP

Lot Number: Par D

Observation: 2-Piece Cap
Satisfactory

RESULTS OF ANALYSIS:

PARAMETER	RESULT	METHOD	*MCL/**SMCL	
Nitrate	<1.0 mg/L as N	SM 4500D	*10 mg/L as N	Pass
Turbidity	<1.0 NTU	EPA 180.1	*10 NTU	Pass
pH	6.0 Units	EPA 150.1	**6.5-8.5 Units	***
Sand	Negative		Negative	
Total Coliform	Absent	SM 9223B	*Absent	SAFE
E. coli	Absent	SM 9223B	*Absent	SAFE
(18 Hour Test)				

Treatment/Conditioning: None

***A non-enforceable parameter that may cause cosmetic effects or aesthetic effects (such as taste, odor, or color) in drinking water.

Sharon K. Cassell

Sharon K. Cassell

*MCL = Maximum Contamination Level

**SMCL = Secondary Maximum Contamination Level

IRON TO FOLLOW