

Water Testing Laboratories

of Maryland, Inc.

If responding, please contact:

☐ P.O. Box 696, Bel Air, MD 21014
☐ P.O. Box 861, Finksburg, MD 21048
☐ 406 S. Camp Meade Rd., Unit 104, Linthicum, MD 21090
☐ 113 High St., Salisbury, MD 21801
☐ P.O. Box 712, Stevensville, MD 21666
☐ P.O. Box 463, Timonium, MD 21093
☐ P.O. Box 10591, Burke, VA 22009-0591

(410) 893-5257
 (410) 876-2035
 (410) 691-2223
 (410) 546-1318
 (410) 643-7711
 (410) 628-2855
 (703) 250-7711

Colleen Craney
 13700 Clarksville Pike (Route 108)
 Highland, Md 20777

Reporting Date: 12/23/2005
 Report #: K1395

Submitted Sample Address: 13700 Clarksville Pike (Route 108)
 Highland, Md 20777
 Submitted Sample Source: Outside faucet
 Date / Time Collected: 12/21/2005 03:11 PM
 Sample Type: Drinking Water
 Sampler/Company: J. Schwarzmans 0457JS, WTL of MD
 Field Record: Chlorine residual: Absent
 Well #: HO-94-2961

ICOP
issued
glendy

Analytical Results

Parameter	Result	Units	Detection Level	MCL	Analytical Method
Total Coliforms	Absent	Coliforms/100 ml	Present/Absent	Present	SM 9223B
E. Coli	Absent	Coliforms/100 ml	Present/Absent	Present	SM 9223B
Nitrates + Nitrites	5.6	mg/L	1.0	10	EPA 353.2
Sand	Absent	P/A	Present/Absent	Present	Visual
Turbidity	4.7	NTU	0.5	10	SM 2130B
pH	6.6	SU	0.1	6.5-8.5 (SMCL)	SM 2130B

Notes:

- Bacteriological analysis of this sample indicates this water is **safe** for human consumption.
- MCL is EPA's maximum contaminant level under primary drinking water regulations. SMCL is secondary maximum contaminant level and is the aesthetic quality only. If your result is above any MCL or SMCL, you may want to consider a water treatment system or a new well. Please check your local regulations for any restrictions or additional limits.
- ND - Not Detected.
- Sample received and examined within EPA's recommended holding time
- SM - Greenberg, Clesceri and Easton, *Standard Methods for the Examination of Water and Wastewater*, 20th Ed.

Reported by,

Christine Rodgers

C. Rodgers, Customer Service Representative

Reviewed by: *LB*

40/9/306 *Bu. 14* *2002*