

6/19/74

Handwritten notes: "I have checked the site and it is suitable for a septic system. The property owner has agreed to the terms of the permit. The permit is valid for 3 years from the date of issuance." Date: 6/20/74. Initials: R.P.

PERMIT

6/20/74
Jerald R.T.

P 19925
A 19872

SEWAGE DISPOSAL SYSTEM

MARYLAND STATE DEPARTMENT OF HEALTH

HOWARD COUNTY

INDEXED

ELLCOTT CITY

DISTRICT 5

DATE 5/8/74

File INDEXED

Marathon Building

IS PERMITTED TO INSTALL ☒ ALTER

ADDRESS 16401 Parkway Terrace, Silver Spring, Md. PHONE 304-6640

A SEWAGE DISPOSAL SYSTEM LOCATED AT

SUBDIVISION ROAD 1844 Ten Oaks Road LOT

PROPERTY OWNER Robert & Suzanne Hill 6.2799 acres

ADDRESS

SPECIFICATIONS - 4 bedrooms

DRAIN FIELD DEPTH FEET, BOTTOM AREA SQ. FT.

SEEPAGE PITS ABSORBENT SIDE-WALL AREA SQ. FT.

SEPTIC TANK CAPACITY 1,250 GALLONS

FOR GARBAGE GRINDER, INCREASE DISPOSAL AREA 25% & TANK CAPACITY 50%

OTHER Dry well - 500 sq. ft. absorbent sidewall area, to begin at 2 ft. below original grade. Maximum depth permitted/dry well is 12 ft. Locate dry well 60 ft. to left of front left corner of house as seen from property line that is 1082.74 ft. long.

(290 ft. from right side line and 50 ft. from front lot line as seen from line that is 1082.74 ft.).

NOTE: ALL PIPE FROM HOUSE TO DRY WELL MUST BE CAST IRON.

PERMIT VOID AFTER THREE YEARS.

PLANS APPROVED BY Robert V. Torre DATE 4/30/74

NOTE: INSTALL STAND PIPE ON SEPTIC TANK AND DRY WELL.

FILL SEPTIC TANK AND DISTRIBUTION BOX WITH WATER BEFORE CALLING FOR AN INSPECTION. COVER NO WORK UNTIL INSPECTED AND APPROVED.

NEITHER THE HOWARD COUNTY COMMISSIONERS NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM.

BLOG. PERMIT SIGNED
AND RETURNED 5-30-77
Serial # B10105979
above ground port

19873

A58466-B