



Bureau of Environmental Health
7178 Columbia Gateway Drive, Columbia, MD 21046
(410) 313-2640 Fax (410) 313-2648
TDD (410) 313-2323 Toll Free 1-866-313-6300
website: www.hchealth.org

Penny E. Borenstein, M.D., M.P.H., Health Officer

November 13, 2006

Mr. John Hann
631 Sidling Court
Sykesville, MD 21784

Re: Invoice No. 5-007408

Dear Mr. Hann:

The water sample recently collected from your house on **October 25, 2006** was found to be free of coliform and E. coli bacteria. The water supply is currently considered bacteriologically safe for consumption.

A nitrate sample was collected on **October 25, 2006** to ascertain the level of nitrate in your water supply. The nitrate level was **2.7 parts per million (ppm)**. The **maximum contaminant level (MCL)** is **10.0 ppm**.

A copy of each test report is enclosed for your information. If there are any questions, please call **(410)-313-1773** between **8:00 A.M.** and **5:00 P.M.**

Sincerely,

A handwritten signature in black ink, which appears to read 'Hank Oswald', is positioned above the typed name.

Hank Oswald, Program Supervisor
Community Hygiene Program

Enclosure

DEPARTMENT OF HEALTH AND MENTAL HYGIENE
LABORATORIES ADMINISTRATION

201 W. Preston Street

PO BOX 2355, Baltimore, Maryland 21203

John M. Deboy, Dr. P.H., Director

Category Code 46Lab. No. 11921BACTERIOLOGICAL DRINKING WATER REPORT
Field Record

Source John Hann - 1st Fl. Bathroom
 Location: 631 Sidling Ct.
 Iced: Yes ☐ No ☐
 Treated Yes ☐ No ☒ Time Collected 9:00 ☒ a.m. ☐ p.m.
 Collector # 54-2002 Bottle No. 44-631-25B
 Collector Name S. Hunter County Howard

Community ☐
 Non-Community ☐
 Non-Transient ☐
 Private ☒
 Check Sample ☐
 C.O.P. ☐

TEST
 QUANTITATIVE ☒
 P/A ☐
 MTF ☐

County 13 Plant No. 102506 Sampling Station 102506 Date Collected 102506

pH 6.8 Res. Cl: Free 00 Total 68 Card No.

LABORATORY RECORD

Thiosulfate: Pres. ☒ Absent ☐ Undetermined ☐

PRESUMPTIVE MTF • P/A TEST*

CONFIRMED MTF • P/A TEST

ml of Sample	10 ml.	100 ml.	ml of Sample	10 ml.	100 ml.	No. of +
Gas. 24 hours			Coliforms †			
Gas. 48 hours			Fecal Coliforms ‡			

P/A TEST (CONFIRMED) ***

ml. of Sample	100 ml.
Total Coliforms	
E. Coli	

QUANTITATIVE TEST (CONFIRMED) ***

100 ml. of Sample	No. of Pos	MPN
Total Coliforms	0	<1
E. Coli	0	<1

** Presumptive Coliforms/100 mi. (Membrane Filter) = † Verified Total Coliforms/100 mi. (Membrane Filter) ÷ ‡ Verified Fecal Coliforms/100 mi. (Membrane Filter) = 24 • 48 • 72 Hrs/Heterophic Plate Count §/ml. =

- ** using m Endo-Agar LES at 35° C incubation
 * using Lauryl Sulfate Trypticase Broth at 35° C incubation
 † using Brilliant Green Lactose Bile Broth at 35° C incubation
 ‡ using EC Broth at 44.5° C incubation
 § using Plate Count Agar at 35° C incubation
 *** using ONPG-MCG at 35° C incubation

Remarks Date & Hour 06 OCT 25 PM 2:17

Laboratory

E. SHORE REG. ☐S. MD REG. ☐CENTRAL ☒W. MD REG. ☐Bacteriologist M. K. [Signature]

U/10-489-5136

0001427 826 8

SAMPLE ID

Federal Project

FIELD

Notes to Lab/Remarks: Sample collected from 10-11-0015

* Results reported in Units, all others in milligrams per liter (ppm)

Date Reported OCT 31 2006