



Howard County  
Health Department

**Bureau of Environmental Health**  
8930 Stanford Boulevard, Columbia, MD 21045  
Main: 410-313-2640 | Fax: 410-313-2648  
TDD 410-313-2323 | Toll Free 1-866-313-6300  
[www.hchealth.org](http://www.hchealth.org)

Facebook: [www.facebook.com/hocohealth](https://www.facebook.com/hocohealth)

Maura J. Rossman, M.D., Health Officer

RECEIPT DATE: 11/29/17

**ONSITE SEWAGE DISPOSAL SYSTEM**

P 562342

INSTALLATION

APPROVAL DATE: 12/8/17 SEC

**PERMIT**  
**TANK REPLACEMENT**

A \_\_\_\_\_

PROPERTY ADDRESS: 800 The Old Station Court

SUBDIVISION: The Southern Station

LOT: 2

TAX ID: 04-345940

CONTRACTOR: Legacy Septic

EMAIL: \_\_\_\_\_

CONTRACTOR ADDRESS: 1538 Manchester Road, Westminster, MD 21557

PHONE: 301-370-4121

PROPERTY OWNER: Laurie Kramer

EMAIL: \_\_\_\_\_

OWNER ADDRESS: 800 The Old Station Court, Woodbine, MD 21797

PHONE: 704-502-0240

BAT UNIT MODEL: \_\_\_\_\_

PUMP SIZE: N/A

PUMP TANK CAPACITY: N/A

NUMBER OF BEDROOMS: \_\_\_\_\_

SEPTIC TANK SIZE: 1500 gal

DRAINFIELD SIZE/TYPE: \_\_\_\_\_

LOCATION:	
NOTES:	Pump + remove existing tank, put new tank in same location.

ISSUED BY: Sarah Collins

ISSUE DATE: 12/8/17

EXPIRATION DATE: 12/8/18

NOTE: CONTRACTOR MUST SCHEDULE AN INSPECTION AND GAIN APPROVAL OF ALL COMPONENTS PRIOR TO COVERING

NOTE: AN ELECTRICAL PERMIT IS REQUIRED FOR INSTALLATION OF ANY ELECTRICAL COMPONENTS OF THE SYSTEM

NOTE: MDE RECOMMENDS SEPTIC TANKS, BAT, AND OTHER PRETREATMENT UNITS BE PUMPED AT A FREQUENCY ADEQUATE TO ENSURE THAT SOLIDS ARE NOT DISCHARGED TO THE DISPOSAL AREA

**NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE  
FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM.  
PERMITTEE RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT.  
CALL 410-313-1771 FOR INSPECTION OF SEPTIC SYSTEM.**

NOT TO SCALE

W H0-81-2306

EXISTING  
SPECS

Driveway

Garage

30'

33'

ROAD NAME

#### TRENCH/DRAINFIELD DATA

WIDTH	INLET	BOTTOM
2'	4'	8'
NUMBER OF TRENCHES		2
TOTAL LENGTH		165'
ABSORPTION AREA		330' + SIDEWALL
DISTRIBUTION BOX LEVEL		?
DISTRIBUTION BOX BAFFLE		NO
DISTRIBUTION BOX PORT		NO

#### SEPTIC TANK DATA

SEPTIC TANK LEVEL	YES
MANUFACTURER	BAYSTAR
CAPACITY	1500 GAL
SEAM LOC	TOP
TANK LID DEPTH	1.5-2'
BAFFLES	YES
BAFFLE FILTER	NO
MANHOLE LOC	FRONT + REAR
6" PORT LOC	NONE
WATERTIGHT TEST	NO
SLOTTED	YES
DATE ON LID	11-16-17

#### PUMP/SEPTIC TANK LEVEL

MANUFACTURER	
CAPACITY	GAL
SEAM LOC	
TANK LID DEPTH	
BAFFLES	
BAFFLE FILTER	
MANHOLE LOC	
6" PORT LOC	
WATERTIGHT TEST	
SLOTTED	
DATE ON LID	

#### PRE-CONSTRUCTION:

12/5/17 OK to set tank in same location as ex. tank. Call for inspection when completed (KMY)

INSTALLATION: 12/8/17 old tank pumped + crushed, new tank set + tied into existing lines. (SO)

FINAL INSPECTOR Sarah Collins DATE OF APPROVAL 12/8/17