

PERMIT

SEWAGE DISPOSAL SYSTEM

DEPARTMENT OF HEALTH AND MENTAL HYGIENE

05-350026

P 57400A

A REPAIR

DISTRICT

DATE 11-13-96

HOWARD COUNTY HEALTH DEPARTMENT

BUREAU OF ENVIRONMENTAL HEALTH

XXXXXX

313-2640

DATE SYSTEM APPROVED 12/23/96

INSPECTOR

INDEXED

Jack Fyock Septic Service

IS PERMITTED TO INSTALL

ALTER X

ADDRESS 4105 Ten Oaks Road, Dayton, Maryland 21036

PHONE 988-9270

SUBDIVISION

LOT

8020 HUNTERBROOKE LANE
ROAD 11845 Lime Kiln Road

PROPERTY OWNER

Thomas Atwell

11845 Lime Kiln Road

ADDRESS

Dayton, Maryland 21046

SEPTIC TANK CAPACITY 1000 GALLONS

NUMBER OF BEDROOMS 3

125 SQUARE FEET PER BEDROOM

LINEAR FEET OF TRENCH REQUIRED

per Jack Fyock - OK to use existing Septic Tank
(check is short tanks) and upgrade to a top sealed tank when
feasible. Keep maximum bottom depth of 4ft but ok to
place pipe inlet lower in 2ft of gravel fill to keep
gravity flow. 12/19/96

REPAIR - PURPOSE - SEPTIC SYSTEM HAS FAILED.

Call for inspection when ground is opened so sanitarian can recommend repair.
11/13/96

Install 100 Lin Ft (1250 gal) 4" dia. - Trans system, Four Foot Max Bottom,
2ft Gravel Fill - inlet as shallow as possible. Recommend a minimum Septic
tank replacement (to keep out high water table sewage) with a top sealed 1000 ST
(1500 2 chambered top sealed preferred).
12/19/96

PLANS APPROVED BY

DATE

COVER NO WORK UNTIL INSPECTED AND APPROVED

NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM

NOTE: CLEANOUT REQUIRED EVERY 70 FEET OF SEWER LINE AND/OR AT 90° SWEEPS IN LINES FROM HOUSE TO DRAIN FIELDS, 90° ELBOWS NOT ACCEPTABLE.

NOTE: ALL PARTS OF SEPTIC SYSTEMS (I.E. TANK, DISTRIBUTION BOX TRENCHES) TO BE 100 FEET FROM WELL (UNLESS OTHERWISE SPECIFICALLY AUTHORIZED)

NOTE: IF DEEP TRENCH(ES) ARE USED CALL FOR INSPECTION BEFORE AND AFTER PLACING GRAVEL IN TRENCH(ES)

NOTE: NO DRY WELL SHALL EXCEED 15 FOOT IN DIAMETER NO ABSORPTION TRENCH TO EXCEED 100 FEET IN LENGTH

NOTE: ALL PIPE FROM HOUSE TO SEPTIC TANK MUST BE CAST IRON OR SCHEDULE 35/40 PVC OR ABS

PERMIT VOID AFTER TWO YEARS

NOTE: INSTALL STAND PIPE ON SEPTIC TANK AND DRY WELL STAND PIPES MUST BE 6 INCHES IN DIAMETER CAST IRON, CONCRETE OR TERRA COTTA OR PVA OR ABS ACCEPTED, IF TOP OF SEPTIC TANK IS DEEPER THAN 3 FEET, MANHOLE TO GRADE REQUIRED.

NOTE: DISTRIBUTION BOXES MUST HAVE BAFFLES

*INSTALLER IS RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT

HD-260(6-90)

*CALL 461-9933 FOR INSPECTION OF SEPTIC SYSTEM.

57400A

