

7/15/84 ASH-  
4/1/83  
1.10 PM

ppm 113/54  
Stayer

# PERMIT

SEWAGE DISPOSAL SYSTEM

MARYLAND STATE DEPARTMENT OF HEALTH

P 32746

A 24034

HOWARD COUNTY  
BUREAU OF ENVIRONMENTAL HEALTH  
992-2330

INDEX

05-385156

ELLICOTT CITY

DISTRICT 5th

DATE 5/9/83

Oskar Schulz, Inc.

IS PERMITTED TO INSTALL ☒ ALTER ☐

ADDRESS 6610 Blackwatch Lane, Highland, Maryland 20777 PHONE 531-2000

SUBDIVISION ~~KMZ Highland Lake~~ ROAD 6535 River Clyde Drive LOT 91, Sec. 3, Area 1

PROPERTY OWNER ~~Oskar Schulz, Inc.~~ Alan Linda Anderson

ADDRESS same as above

IF GARBAGE GRINDER IS USED INCREASE SEPTIC TANK CAPACITY BY 50% AND ABSORPTION AREA BY 22%.

GARBAGE GRINDER? YES ☐ NO ☒

SEPTIC TANK CAPACITY 1250 GALLONS NUMBER OF BEDROOMS 4

TRENCHES - 165 sq. ft. per bedroom. Minimum total square feet for 4 bedrooms is 660 sq. ft. Trench to be 2 feet wide. Inlet 3 ft. below original grade. Effective area begins at 3 ft. below original grade. Maximum depth 8 ft. below original grade. 5 feet of stone below distribution pipe. NO TRENCH TO EXCEED 100 FEET IN LENGTH. IF MORE THAN ONE TRENCH USED, A DISTRIBUTION BOX IS REQUIRED. TRENCHES TO BE INSTALLED ON LEVEL GROUND. Trench to be 150 ft. away from and parallel to front lot line.

B.P. Appl. 17779  
for 500gal tank -  
propane tank - adjusted location  
approved 4-18-83

BUDG. PERMIT SIGNED  
AND RETURNED 3/23/84  
Sent to Sub  
Interior Division  
BUDG. PERMIT SIGNED  
AND RETURNED 3/23/84  
Mail # 1677-PM

PLANS APPROVED BY Frank A. Skinner DATE 10/5/82

COVER NO WORK UNTIL INSPECTED AND APPROVED.

NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM.

NOTE: IF TRENCH IS USED CALL FOR INSPECTION BEFORE AND AFTER PLACING GRAVEL IN TRENCH.

NOTE: NO DRY WELL SHALL EXCEED 15 FOOT IN DIAMETER. NO ABSORPTION TRENCH TO EXCEED 100 FEET IN LENGTH

NOTE: ALL PIPE FROM HOUSE TO SEPTIC TANK MUST BE CAST IRON OR SCHEDULE 40 PVC OR ABS

PERMIT VOID AFTER THREE YEARS

NOTE: INSTALL STAND PIPE ON SEPTIC TANK AND DRY WELL. STAND PIPES MUST BE 6 INCHES IN DIAMETER. CAST IRON, CONCRETE OR TERRA COTTA, OR PVC OR ABS ACCEPTED IF TOP OF SEPTIC TANK IS DEEPER THAN 3 FEET MANHOLE TO GRADE REQUIRED.

\*INSTALLER IS RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT

\*CALL 992-2330 FOR INSPECTION OF SEPTIC SYSTEMS.

EH - 2-1082

AS-1001

[illegible]

INDICATE NORTH. - NAME ADJOINING ROADWAY AS BASE LINE.

PERMIT CARD ✓

SEPTIC TANK, LEVEL. ✓ 1500

CLEANOUTS 31 2WDISTRIBUTION BOX, LEVEL 1TILE FIELD, DEPTH 8 FT. TRENCH WIDTH 2 FT.

GRAVEL DEPTH 3 IN. TOTAL LENGTH 80 FT.

NUMBER OF TRENCHES 1 TOTAL BOTTOM AREA 4.00

SEEPAGE PITS, INSIDE DIAMETER 60 FT. DEPTH BELOW INLET 5 FT.

ABSORBENT AREA 700 SQ. FT.

REMARKS: TRENCHES INSTALLED, HOUSE CONNECTION OK. ADD GRAVEL. 11-1-83 CW

7/5/84 Location & type of system changed because of swimming Pool. Per FS

OK to add stone in trench. js  
1/5/84 OK to cover all work. js

1/5/84 OK to cover all work. *[initials]*

DATE SYSTEM APPROVED \_\_\_\_\_

7/5/84

INSPECTOR

Stoner