

C1 00811 (THIS NUMBER IS TO BE PUNCHED IN COLS. 3-6 ON ALL CARDS)		SEQUENCE NO. (OEP USE ONLY)		STATE OF MASSACHUSETTS WELL COMPLETION PERMIT FILL IN THIS FORM COMPLETELY PLEASE PRINT OR TYPE		THIS REPORT MUST BE SUBMITTED WITHIN 45 DAYS AFTER WELL IS COMPLETED.	
DATE RECEIVED 		DATE WELL COMPLETED 		DEPTH OF WELL (TO NEAREST FOOT) 		PERMIT NO. FROM "PERMIT TO DRILL WELL" 	
OWNER Burger, Raymond		STREET OR RFD Old Frederick Rd		TOWN Lisbon		SECTION 5	
SUBDIVISION Nursery View		LOT 5					

WELL LOG Not required for driven wells STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING			GROUTING RECORD WELL HAS BEEN GROUTED (Circle Appropriate Box) TYPE OF GROUTING MATERIAL CEMENT ☒ CM BENTONITE CLAY ☒ BC			PUMPING TEST HOURS PUMPED (nearest hour) 		
DESCRIPTION (Use additional sheets if needed)			NO. OF BAGS 5 NO. OF POUNDS 500			PUMPING RATE (gal. per min. to nearest gal.) 		
FEET FROM TO			GALLONS OF WATER 30			METHOD USED TO MEASURE PUMPING RATE Buck		
Top Soil 0 2			DEPTH OF GROUT SEAL (to nearest foot) from 0 ft. to 19 ft.			WATER LEVEL (distance from land surface) BEFORE PUMPING 4.5		
Brown Slate 2 11			CASING RECORD case types insert appropriate code below ST CO			WHEN PUMPING 20		
Brown Slate 11 25			MAIN CASING TYPE PL Nominal diameter top (main) casing (nearest inch) 6 Total depth of main casing (nearest foot) 20			TYPE OF PUMP USED (for test) A P T		
Blue Slate 25 40			OTHER CASING (if used) diameter inch depth (feet) from to			C R O		
Brown Slate 40 45 ✓			SCREEN RECORD screen type or open hole insert appropriate code below ST BR HO			TYPE OF PUMP INSTALLED DRILLER WILL INSTALL PUMP (CIRCLE) (YES or NO) YES ☒ NO ☐		
Blue Slate 45 260			DEPTH (nearest ft.) H O			IF DRILLER INSTALLS PUMP, THIS SECTION MUST BE COMPLETED FOR ALL WELLS EXCEPT HOME USE TYPE OF PUMP INSTALLED PLACE (A,C,J,P,R,S,T,O) IN BOX - SEE ABOVE:		
Brown Slate 260 265 ✓			SLIT SIZE 1 2 3			CAPACITY: GALLONS PER MINUTE (to nearest gallon) 		
Blue Slate 265 300			DIAMETER OF SCREEN (NEAREST INCH)			PUMP HORSE POWER 		
10 gpm / 3 hr. pump test			GRAVEL PACK 10			PUMP COLUMN LENGTH (nearest ft.) 		
CIRCLE APPROPRIATE LETTER A A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED E ELECTRIC LOG OBTAINED P TEST WELL CONVERTED TO PRODUCTION WELL			IF WELL DRILLED WAS FLOWING WELL INSERT F IN BOX 68			CASING HEIGHT (circle appropriate box and enter casing height) + -		
I HEREBY CERTIFY THAT THIS WELL HAS BEEN CONSTRUCTED IN ACCORDANCE WITH COMAR 10.17.13 "WELL CONSTRUCTION" AND IN CONFORMANCE WITH ALL CONDITIONS STATED IN THE ABOVE CAPTIONED PERMIT, AND THAT THE INFORMATION PRESENTED HEREIN IS ACCURATE AND COMPLETE TO THE BEST OF MY KNOWLEDGE.			TELESCOPE CASING ☐ 70 LOG INDICATOR ☐ 72 OTHER DATA			LAND SURFACE 1 (nearest foot)		
DRILLERS IDENT. NO. 253 Ralph Wayne			OEP USE ONLY (NOT TO BE FILLED IN BY DRILLER) T W			LOCATION OF WELL ON LOT SHOW PERMANENT STRUCTURE SUCH AS BUILDING, SEPTIC TANKS, AND/OR LANDMARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL)		
DRILLERS SIGNATURE (MUST MATCH SIGNATURE ON APPLICATION) Ralph E. Wayne			W O					
SITE SUPERVISOR (sign of driller or journeyman responsible for sitework if different from permittee)			TELESCOPE CASING ☐ 70 LOG INDICATOR ☐ 72 OTHER DATA			Prop Line		

HEALTH

A17294

August 28, 1986

Mr. Raymond Burger, Jr.
791 Old Frederick Road
Liston, Maryland 21765

Dear Mr. Burger:

The water sample recently submitted for testing was free of coliform and fecal coliform bacteria at the time of sampling and is bacteriologically safe for drinking.

FINAL CERTIFICATE OF POTABILITY

This certifies that all sampling requirements of COMAR 10.17.13 "Well Regulations" have been met for the water supply system installed under permit(s) HO-21-1267.

July 22, 1986
Date of Final Sampling

July 29, 1986
Date of Acceptance

Craig Williams

Craig Williams, Director
Water and Sewerage Program

CH/JS:JR

7-22 Nitrate 60.2
Iron 0.13
pH 7.2

Date Well Approved: 12/22/85
Date Septic Approved: 4/26/86

Water Sample Dates: 6/25/86 Delmar
7/22/86 Dumas