



Howard County
Health Department

3525 H Ellicott Mills Drive, Ellicott City, MD 21043
(410) 313-2640 Fax (410) 313-2648
TDD (410) 313-2323 Toll Free 1-866-313-6300
website: www.hchealth.org

Penny E. Borenstein, M.D., M.P.H., Health Officer

February 25, 2004

Southern Kraft Builders
8899 Frederick Road
Ellicott City, MD 21043

SENT VIA FACSIMILE 410-750-1407

RE: 1720 St. Michaels Road
BP # B00141203
Well Permit # No tag

Dear Sirs:

This is to advise you that the septic system for the above referenced property will be installed and inspected as soon as the ground thaws sufficiently to install a sand mound system. **Final approval of the septic system will be granted at that time.**

The water sample results indicate that the water samples submitted for testing were free of coliform and fecal coliform bacteria at the time of sampling and are bacteriologically safe for drinking. The water sample results were found to be in compliance with COMAR water quality standards.

INTERIM CERTIFICATE OF POTABILITY

This certifies that the **initial** sampling requirements of COMAR 26.04.04 "Well Regulations" have been met for the water supply system installed under well permit No Tag. Although the submitted sample results are in compliance with COMAR standards, the Health Department does not guarantee water supplies. Based upon satisfactory investigation and evaluation, the Howard County Health Department, as authorized by the Maryland Department of the Environment accepts this well system as required by COMAR 26.04.04.

This certificate may become final upon completion of the second bacteriological test, which is to be taken by the county health department within six months of receipt of this letter. **Please contact (410) 313-1773 to schedule a final water sample appointment. Currently, there is no charge for this final sampling.**

Date of Water Sample: 02/20/2004

Respectfully,

John Boris, R. S.
Well and Septic Program

JB/mlb

cc: Building Inspector's Office
Community Services Program
File