

DEPARTMENT OF INSPECTIONS, LICENSES & PERMITS 3430 COURT HOUSE DRIVE ELLICOTT CITY, MD 21043 PERMITS (410) 313-2455 INSPECTIONS (410) 313-1850	<b>HOWARD COUNTY          RESIDENTIAL          HEATING-VENTILATION-AIR          CONDITIONING AND          REFRIGERATION PERMIT          APPLICATION</b>	HVACR PERMIT # <u>M/8000657</u> BUILDING PERMIT #
---	---	--

BUILDING ADDRESS: <u>3513 Rhode Valley Ct Ellicott City</u> SUITE/APT: <u>21042</u> SUBDIVISION: CENSUS TRACT: LOT: BLOCK: PROPERTY ID: TYPE OF IMPROVEMENTS:	SECTION: TAX MAP: ZONE: MAP COORDINATES: USE:	OWNERS NAME: <u>Zhang, Jianyue</u> ADDRESS: <u>3513 Rhode Valley Trail</u> CITY: <u>Ellicott City</u> STATE: <u>MD</u> ZIP CODE: <u>21042</u> HOME PHONE: <u>240-228-4540</u> WORK PHONE:
--	---	---

CHECK ONE	HOW MANY	COMPANY NAME:
SINGLE FAMILY DWELLING <input checked="" type="checkbox"/>	<u>1</u> ZONES	<u>Total Energy Concepts</u>
SINGLE FAMILY TOWNHOUSE <input type="checkbox"/>	___ ZONES	LICENSEE NAME: <u>Terry Artman</u>
MULTI-FAMILY / HOTEL/MOTEL <input type="checkbox"/>	___ ROOMS	ADDRESS: <u>PO Box 605</u>
ASSISTED LIVING HOMES (16 OR FEWER RESIDENTS) <input type="checkbox"/>	___ ROOMS	CITY: <u>Churchville</u>
		STATE: <u>MD</u> ZIP CODE: <u>21028</u>
		PHONE: <u>410-452-0562</u> HVACR LICENSE NO: <u>14202-01</u>

☐ New  
☒ Heating and Air Conditioning  
☒ Geo Thermal System

☐ Heating System Only  
☐ Ductless Mini Splits

☐ Other Work (Describe):  
☐ Thru The Wall Systems

Replacement  
☐ Heating  
☐ Air Conditioning  
☒ Heating and Air Conditioning

Additions and Alterations  
☐ Heating  
☐ Air Conditioning  
☐ Heating and Air Conditioning

\*\*\*\*Replacement Geo Thermal Systems are not required; However, if a tax credit is being sought a permit is required\*\*\*\*

<b>Zones</b> Permit Fee = # of Zones x \$40 = <u>40</u> Technology Fee (10% of Permit Fee) = <u>4</u> Plus Application Fee <u>\$50.00</u> Total Fees Due = <u>94</u>	<b>Rooms</b> Permit Fee = # of Rooms x \$80 = _____ Technology Fee (10% of Permit Fee) = _____ Plus Application Fee \$50 <u>\$50.00</u> Total Fees Due = _____
--	--

I HAVE CAREFULLY EXAMINED AND READ THIS APPLICATION AND KNOW IT IS TRUE AND CORRECT. THE WORK DESCRIBED HEREIN WILL BE PERFORMED BY A STATE HVACR LICENSED PERSON(S), AND ALL WORK WILL BE PERFORMED IN COMPLIANCE WITH APPLICABLE CODES AND STANDARDS OF HOWARD COUNTY THE STATE OF MARYLAND.

SIGNATURE OF LICENSEE  
TERRY L. ARTMAN  
 PRINT NAME OF LICENSEE  
Terry @ totalenergyonline.com  
 Email Address

7/30/18  
 Approved System Plan  
 Howard County Health Department  
 Signature

<b>Validation</b> Check Number: <u>16757</u> Receipt Number: <u>542633</u>
--

8/6/18  
**RECEIVED**  
 JUL 30 2018  
 LICENSES & PERMITS  
 DIVISION

M18000657

*Zhang Jiangyue*  
*HVAC Load Calculations*

for

Jiangyue Zhang  
3513 Rhode Valley Court  
Ellicott City, MD 21042



**RHVAC** RESIDENTIAL  
HVAC LOADS

Prepared By:

Terry Artman  
Total Energy Concepts  
2620 Dublin Road  
Street, MD 21154  
410-452-0562  
Monday, July 30, 2018

Rhvac is an ACCA approved Manual J and Manual D computer program.  
Calculations are performed per ACCA Manual J 8th Edition, Version 2, and ACCA Manual D.



## Project Report

### General Project Information

Project Title: Zhang Jiangyue  
Designed By: Total Energy Concepts  
Project Date: 7/30  
Client Name: Jiangyue Zhang  
Client Address: 3513 Rhode Valley Court  
Client City: Ellicott City, MD 21042  
Company Name: Total Energy Concepts  
Company Representative: Terry Artman  
Company Address: 2620 Dublin Road  
Company City: Street, MD 21154  
Company Phone: 410-452-0562

### Design Data

Reference City: Baltimore, Maryland  
Building Orientation: Front door faces North  
Daily Temperature Range: Medium  
Latitude: 39 Degrees  
Elevation: 148 ft.  
Altitude Factor: 0.995

	Outdoor Dry Bulb	Outdoor Wet Bulb	Outdoor Rel.Hum	Indoor Rel.Hum	Indoor Dry Bulb	Grains Difference
Winter:	13	11.86	n/a	n/a	70	n/a
Summer:	91	75	48%	50%	75	41

### Check Figures

Total Building Supply CFM:	1,492	CFM Per Square ft.:	0.709
Square ft. of Room Area:	2,103	Square ft. Per Ton:	711
Volume (ft <sup>3</sup> ):	22,536		

### Building Loads

Total Heating Required Including Ventilation Air:	46,155 Btuh	46.155 MBH
Total Sensible Gain:	32,648 Btuh	92 %
Total Latent Gain:	2,827 Btuh	8 %
Total Cooling Required Including Ventilation Air:	35,475 Btuh	2.96 Tons (Based On Sensible + Latent)

### Notes

Rhvac is an ACCA approved Manual J and Manual D computer program.  
Calculations are performed per ACCA Manual J 8th Edition, Version 2, and ACCA Manual D.  
All computed results are estimates as building use and weather may vary.  
Be sure to select a unit that meets both sensible and latent loads according to the manufacturer's performance data at your design conditions.



## Miscellaneous Report

System 1 Input Data	Outdoor Dry Bulb	Outdoor Wet Bulb	Outdoor Rel.Hum	Indoor Rel.Hum	Indoor Dry Bulb	Grains Difference
Winter:	13	11.86	80%	n/a	70	n/a
Summer:	91	75	48%	50%	75	40.76

### Duct Sizing Inputs

	Main Trunk	Runouts
Calculate:	Yes	Yes
Use Schedule:	Yes	Yes
Roughness Factor:	0.00300	0.01000
Pressure Drop:	0.1000 in.wg./100 ft.	0.1000 in.wg./100 ft.
Minimum Velocity:	650 ft./min	450 ft./min
Maximum Velocity:	900 ft./min	750 ft./min
Minimum Height:	0 in.	0 in.
Maximum Height:	0 in.	0 in.

### Outside Air Data

	Winter	Summer
Infiltration Specified:	0.000 AC/hr 0 CFM	0.000 AC/hr 0 CFM
Infiltration Actual:	0.000 AC/hr	0.000 AC/hr
Above Grade Volume:	X 22,536 Cu.ft. 0 Cu.ft./hr	X 22,536 Cu.ft. 0 Cu.ft./hr
	X 0.0167	X 0.0167
Total Building Infiltration:	0 CFM	0 CFM
Total Building Ventilation:	0 CFM	0 CFM

### ---System 1---

Infiltration & Ventilation Sensible Gain Multiplier:	17.51	= (1.10 X 0.995 X 16.00 Summer Temp. Difference)
Infiltration & Ventilation Latent Gain Multiplier:	27.57	= (0.68 X 0.995 X 40.76 Grains Difference)
Infiltration & Ventilation Sensible Loss Multiplier:	62.37	= (1.10 X 0.995 X 57.00 Winter Temp. Difference)
Winter Infiltration Specified:	0.000 AC/hr (0 CFM)	
Summer Infiltration Specified:	0.000 AC/hr (0 CFM)	

### Duct Load Factor Scenarios for System 1

No.	Type	Description	Location	Attic Ceiling	Duct Leakage	Duct Insulation	Surface Area	From [T]MDD
1	Supply		Basement	-	0.06	8	471	No



## Load Preview Report

Scope	Net Ton	ft. <sup>2</sup> /Ton	Area	Sens Gain	Lat Gain	Net Gain	Sens Loss	Sys Htg CFM	Sys Cig CFM	Sys Act CFM	Duct Size
Building	2.96	711	2,103	32,648	2,827	35,475	46,155	603	1,492	1,492	
System 1	2.96	711	2,103	32,648	2,827	35,475	46,155	603	1,492	1,492	16x16
Supply Duct Latent					744	744					
Zone 1			2,103	32,648	2,083	34,731	46,155	603	1,492	1,492	16x16
1-1F Kitchen Addition Area			255	7,497	883	8,380	8,514	111	343	343	4-5
2-2F Stair And Loft Area			576	6,302	0	6,302	7,792	102	288	288	3-6
3-2F Master Bath And WIC			128	2,021	0	2,021	2,811	37	92	92	1-6
4-2F Master Bedroom			210	2,721	400	3,121	3,166	41	124	124	2-5
5-Great Room			384	7,851	400	8,251	12,901	168	359	359	4-6
6-1F Bathroom			96	215	0	215	865	11	10	10	1-4
7-1F Stairs Area			108	241	0	241	973	13	11	11	1-4
8-1F Right Bedroom			180	3,465	200	3,665	5,044	66	158	158	2-5
9-1F Left Bedroom			168	2,335	200	2,535	4,088	53	107	107	1-6



## System 1 Room Load Summary

Room No	Name	Area SF	Htg Sens Btuh	Min Htg CFM	Run Duct Size	Run Duct Vel	Clg Sens Btuh	Clg Lat Btuh	Min Clg CFM	Act Sys CFM
---Zone 1---										
1	1F Kitchen Addition Area	255	8,514	111	4-5	628	7,497	883	343	343
2	2F Stair And Loft Area	576	7,792	102	3-6	489	6,302	0	288	288
3	2F Master Bath And WIC	126	2,811	37	1-6	470	2,021	0	92	92
4	2F Master Bedroom	210	3,166	41	2-5	456	2,721	400	124	124
5	Great Room	384	12,901	168	4-6	457	7,851	400	359	359
6	1F Bathroom	96	865	11	1-4	112	215	0	10	10
7	1F Stairs Area	108	973	13	1-4	126	241	0	11	11
8	1F Right Bedroom	180	5,044	66	2-5	581	3,465	200	158	158
9	1f Left Bedroom	168	4,088	53	1-6	544	2,335	200	107	107
	Duct Latent							744		
	System 1 total	2,103	46,155	603			32,648	2,827	1,492	1,492

System 1 Main Trunk Size: 16x16 in.  
 Velocity: 839 ft./min  
 Loss per 100 ft.: 0.086 in.wg

## Cooling System Summary

	Cooling Tons	Sensible/Latent Split	Sensible Btuh	Latent Btuh	Total Btuh
Net Required:	2.96	92% / 8%	32,648	2,827	35,475
Actual:	3.35	75% / 25%	30,150	10,050	40,200

## Equipment Data

	Heating System	Cooling System
Type:	Two Stage Ground Source HP	Two Stage Ground Source HP
Model:	NDV/NDH038G1*(1,2,4)	NDV/NDH038G1*(1,2,4)
Indoor Model:		
Brand:	5 SERIES	5 SERIES
Description:	Two Stage Ground Source Heat Pump	Two Stage Ground Source Heat Pump
Efficiency:	Hi: 4.1 / Lo: 4.8 COP	Hi: 21 / Lo: 30 EER
Sound:	0	0
Capacity:	26,700 Btuh	40,200 Btuh
Sensible Capacity:	n/a	30,150 Btuh
Latent Capacity:	n/a	10,050 Btuh
AHRI Reference No.:	n/a	5696562