

C1	1111	SEQUENCE NO. (DENV USE ONLY)	STATE OF MARYLAND WELL COMPLETION REPORT FILL IN THIS FORM COMPLETELY PLEASE PRINT OR TYPE		THIS REPORT MUST BE SUBMITTED WITHIN 45 DAYS AFTER WELL IS COMPLETED.	
1 2 3 (THIS NUMBER IS TO BE PUNCHED IN COLS. 3-6 ON ALL CARDS)				COUNTY NUMBER <u>A. 35021</u>		
ST/CO USE ONLY DATE Received		DATE WELL COMPLETED <u>08/1/99</u>		PERMIT NO. FROM "PERMIT TO DRILL WELL" <u>40-88-1923</u>		
8 13		15 20		22 26 (TO NEAREST FOOT)		

OWNER FRANK R. BENT last name BENT first name
STREET OR RFD 1000 BENT TOWN LAUREL
SUBDIVISION LAUREL SECTION 7 LOT 7

WELL LOG
Not required for driven wells
STATE THE KIND OF FORMATIONS
PENETRATED, THEIR COLOR, DEPTH,
THICKNESS AND IF WATER BEARING

DESCRIPTION (Use additional sheets if needed)	FEET		Check if water bearing
	FROM	TO	
Top Soil	0	2	
Brown slate	2	15	
Blue slate	15	50	
Brown slate	50	60	L
Blue slate	60	75	
Brown slate	75	90	L
Blue slate	90	205	

GROUTING RECORD
WELL HAS BEEN GROUTED ☒ YES ☐ NO
(Circle Appropriate Box)
TYPE OF GROUTING MATERIAL
CEMENT ☒ BENTONITE CLAY ☐

NO. OF BAGS 5 NO. OF POUNDS 500
GALLONS OF WATER 30
DEPTH OF GROUT SEAL (to nearest foot)
from 1 ft. to 19 ft.
(enter 0 if from surface)

CASING RECORD
casing types insert appropriate code below
☒ ST ☐ CO
STEEL CONCRETE
☒ PL ☐ OT
PLASTIC OTHER

MAIN CASING TYPE ☒ PL
Nominal diameter top (main) casing (nearest inch) 1
Total depth of main casing (nearest foot) 21

OTHER CASING (if used)
diameter inch from to
EACH CASING

SCREEN RECORD
screen type or open hole insert appropriate code below
☒ ST ☐ BR ☐ HO
STEEL BRASS OPEN
BRONZE HOLE
☒ PL ☐ OT
PLASTIC OTHER

C2
DEPTH (nearest ft.)
1 40 2 31 3 194
EACH SCREEN
1 2 3
23 24 26 30 32 36
38 39 41 45 47 51
SLOT SIZE 1 2 3
DIAMETER OF SCREEN (NEAREST INCH)
56 60

CIRCLE APPROPRIATE LETTER
A A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED
E ELECTRIC LOG OBTAINED
P TEST WELL CONVERTED TO PRODUCTION WELL

I HEREBY CERTIFY THAT THIS WELL HAS BEEN CONSTRUCTED IN ACCORDANCE WITH COMAR 26.04.04 "WELL CONSTRUCTION" AND IN CONFORMANCE WITH ALL CONDITIONS STATED IN THE ABOVE CAPTIONED PERMIT, AND THAT THE INFORMATION PRESENTED HEREIN IS ACCURATE AND COMPLETE TO THE BEST OF MY KNOWLEDGE.

DRILLER'S IDENT. NO. 453
Frank R. Bent
DRILLER'S SIGNATURE (MUST MATCH SIGNATURE ON APPLICATION)
Frank R. Bent
SITE SUPERVISOR (sign of driller or journeyman responsible for sitework if different from permittee)

GRAVEL PACK IF WELL DRILLED WAS FLOWING WELL INSERT F IN BOX 68

OEP USE ONLY
(NOT TO BE FILLED IN BY DRILLER)
T (E.R.O.S.) W Q
70 72 74 75 76
TELESCOPE CASING LOG INDICATOR OTHER DATA

C3
PUMPING TEST
HOURS PUMPED (nearest hour) 3
PUMPING RATE (gal. per min. to nearest gal.) 6
METHOD USED TO MEASURE PUMPING RATE Bucket
WATER LEVEL (distance from land surface)
BEFORE PUMPING 45
WHEN PUMPING 70
TYPE OF PUMP USED (for test)
☒ A air ☐ P piston ☐ T turbine
☒ C centrifugal ☐ R rotary ☐ O other (describe below)
☐ J jet ☒ S submersible

PUMP INSTALLED
DRILLER WILL INSTALL PUMP YES ☒ NO
IF DRILLER INSTALLS PUMP, THIS SECTION MUST BE COMPLETED FOR ALL WELLS EXCEPT HOME USE
TYPE OF PUMP INSTALLED PLACE (A,C,J,P,R,S,T,O) IN BOX - SEE ABOVE:
CAPACITY: GALLONS PER MINUTE (to nearest gallon) 31
PUMP HORSE POWER 37
PUMP COLUMN LENGTH (nearest ft.) 41
CASING HEIGHT (circle appropriate box and enter casing height)
☒ above 49
☐ below 49
LAND SURFACE 1 (nearest foot)

LOCATION OF WELL ON LOT
SHOW PERMANENT STRUCTURE SUCH AS BUILDING, SEPTIC TANKS, AND/OR LANDMARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL)
600 X well
1200
Sub-1111A For permit
V. J. For permit

COUNTY