

SITE INSPECTION SHEET

OWNER: _____ PHONE #: N/A
ADDRESS: 8453 ROLLING RIDGE CONTRACTOR: N/A
8447 ROLLING RIDGE WELL TAG #: N/A
SUBDIVISION: _____ LOT: _____ COUNTY #: (XIII)
PROPOSAL: FOLLOW UP TO SEWAGE OVERFLOW ON 8447
ROLLING RIDGE

LOCATION DIAGRAM

OWNER - LAWRENCE DYSON (8453)

- WITNESSED SEWAGE OVERFLOW 10/21/2018 ON 8447 ROLLING RIDGE
- SAID WELL WATER HAD SEWAGE SMELL
- RECOMMENDED WATER TESTING (RAW) (HO-73-1961)

(8447) STATUS OF OVERFLOW
OWNER SHALABY FOLLOW UP

- GROUNDS OBSERVED TO BE WET.
- NO LAST RAIN ~ SATURDAY
- EVIDENCE OF SOIL SATURATION ~ 30' from House.
- EFFLUENT VISIBLE FROM ~~SE~~ BROKEN OBS PORT
- TANK NEEDS TO BE PUMPED.
- SLIGHT SEWAGE SMELL IN YARD, ADD ON BOOTS IN THE CAR.

COMMENTS: NO SIGN OF ACTIVATED LINE

~~CALLER~~ CALL FROM TENANT AT 8447 ROLLING RIDGE
STATING WEEKEND OVERFLOW. REPORTED NEIGHBORS HAD
PHOTOGRAPHS AND OVERFLOW REACHED THEIR YARD.

DATE: 10/22/2018

INSPECTOR: _____

REPAIR

ASSOC. w/

NO ✓

10/18/2018



10/22/2018 WEEKEND OVERFLOW (2nd call)
TANK IS FULL AGAIN. SURFACE SEWAGE.
8447 ROLLING RIDGE
11:30 AM @ 01997



2nd
call

10/22/2018 WEEKEND OVERFLOW (GROUND
SATURATION 1-30' FROM HOUSE)
8447 ROLLING RIDGE
11:30 AM (+001997

7004 1160 0002 3409 5196

U.S. Postal ServiceTM
CERTIFIED MAILTM RECEIPT
(Domestic Mail Only; No Insurance Coverage Provided)

For delivery information visit our website at www.usps.com.

OFFICIAL USE

Postage	\$
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	
Total Postage & Fees	\$

Postmark
Here

Sent To	ELIAB SHALABY
Street, Apt. No., or PO Box No.	10925 SASHA BLVD
City, State, ZIP+4	HAGERSTOWN MD 21742

PS Form 3800, June 2002

See Reverse for Instructions

NOTICE OF VIOLATION

October 18th, 2018

**Ehab M Shalaby
10925 SASHA BLVD
HAGERSTOWN, MD 21742**

CERTIFIED MAIL: 7004 1160 0002 3409 5196

RE: Sewage overflow; pollution of ground surface at 8447 ROLLING RIDGE COURT, ELLICOTT CITY, MD 21742

Dear *Owner*:

On October 17th 2018 a site investigation was conducted at 8447 Rolling Ridge Court in Ellicott City, MD, postal code 21742. At the time of investigation *the septic tank was observed to be actively overflowing at the broken cleanout by the house and discharging raw sewage into the yard*. At the time of investigation we were able to conclude that the onsite sewage disposal system serving the house at 8447 Rolling Ridge Court was the source of the sewage effluent at the surface of the ground.

Be advised that the condition of sewage effluent emerging onto the soil surface is a violation of the Code of Maryland (COMAR) 26.04.02.02(E): "A person may not dispose of sewage, body, or industrial wastes in any manner which may cause pollution of the ground surface, the waters of the State, or create a nuisance." This condition is also in violation of the Howard County Code 3.804(a)(1), as a sewage overflow is defined as a nuisance, [12.110(a)]. It is the property owner's responsibility to maintain the onsite sewage disposal system so that an overflow does not occur until a repair can be performed.


You are hereby ordered to immediately pump and haul the contents of the sewage disposal system and treat the contaminated soil with hydrated lime. You will be responsible for continuing to pump the contents of the system at a frequency that prevents sewage effluent from coming to the ground surface. Furthermore, you must apply for a septic permit within 7 (seven) days and install within 14 (fourteen) days of receiving this notice. Failure to comply will result in the issuance of a civil citation(s). Under Howard County Code, paragraph 12.112, each day this violation is allowed to occur is considered a separate offense.

If you believe that the condition described above is not and could not be a hazard to health, or that the Health Department is not acting in compliance with pertinent laws and regulations, you may request a formal hearing before the Board of Health within 15 (fifteen) days of receipt

Maura J. Rossman, M.D., Health Officer

of this letter. All requests are to be made in writing and directed to the Executive Secretary of the Board of Health at the above address.

If you have any questions regarding this letter, please contact me at 410-313-1771.



Joseph C Cabahug
Licensed Environmental Health Specialist
Well and Septic Program

10/18/2008



10/19/2018 SERVICE OF NOV


8447 ROLLING RIDGE (FRONT DOOR)

12:15 PM (f) 001997

SITE INSPECTION SHEET

OWNER: EHAB SHALABY PHONE #: _____
ADDRESS: 8447 ROLLING RIDGE CT CONTRACTOR: N/A
ELLICOTT CITY, MD 21043 WELL TAG #: PUB. WATER
SUBDIVISION: 9001 LOT: 3 COUNTY #: (XIII)
PROPOSAL: INVESTIGATE SEWAGE OVERFLOW

LOCATION DIAGRAM



COMMENTS: SEWAGE IS VISIBLE AT GRADE BY BROKEN CLEANOUT.
SEWAGE IS ACTIVELY FLOWING OUT OF THE C/O.

PHOTO AND VIDEO RECORD. ATTACHED INVOICES
FROM CONTRACTOR STATING SYSTEM WAS FAILING (NOV 2017)

DATE: 10/17/2018 INSPECTOR: [Signature]

001997




10/17/2018 - SEWAGE OVERFLOW (ACTIVE)

8447 ROLLING RIDGE

11:30 AM @ 001997



10/17/2018 - SEWAGE OVERFLOW (ACTIVE)
8447 ROLLING RIDGE
11:30 AM @cc1997



10/17/2018 - SEWAGE OVERFLOW AFFECTED
AREA
8HH7 ROLLING RIDGE
11:30 AM @ 001997

Fogle's Septic Clean, Inc.

580 Obrecht Road
Sykesville, MD 21784

Invoice Date
11/22/2017

Invoice #
289597

INVOICE

**PLEASE PAY
THIS AMOUNT**

\$0.00

Make checks payable to: **Fogle's Septic Clean, Inc.**

Bill To:

SINNI MANAGEMENT DEVELOPMENT, LLC
EHAB SHALABY
10945 SASHA BLVD
HAGERSTOWN, MD 21742

Service Address

8447 ROLLING RIDGE CT
ELLICOTT CITY, MD 21043

Phone # 410-795-5670

Fogle's Septic Clean, Inc.
580 Obrecht Road
Sykesville, MD 21784

PLEASE DETACH AND RETURN TOP PORTION WITH PAYMENT

P.O. No.	Due Date	Rep	Ship Date
	11/22/2017	RCH	11/21/2017

Description	Qty	Rate	Amount
EMERGENCY PUMPING		335.00	335.00
TANK OVERFULL - WATER RUNNING BACK FROM OUTLET (FAILING SYSTEM) INLET STILL CLOGGED, NO ACCESS TO SNAKE FROM OUTSIDE NEED PLUMBER TO SNAKE FROM INSIDE			

Thank you for your business.

1.5% interest will be charged monthly on all unpaid balances after 30 days. \$30 CHARGE
FOR RETURNED CHECK. RECEIPT DATE STAMPS ARE STRICTLY ENFORCED
for ALL DISCOUNTS.

Billing Questions - call 410-795-5670

Total \$335.00

Payments/Credits -\$335.00

Customer Total Balance \$0.00

Fogle's Septic Clean, Inc.
580 Obrecht Road
Sykesville, MD 21784

Invoice Date
7/26/2018

Invoice #
295579

INVOICE

PLEASE PAY
THIS AMOUNT

\$0.00

Checks payable to: Fogle's Septic Clean, Inc.

Bill To:

SINNI MANAGEMENT DEVELOPMENT, LLC
EHAB SHALABY
10945 SASHA BLVD
HAGERSTOWN, MD 21742

Service Address

8447 ROLLING RIDGE CT
ELLCOTT CITY, MD 21043

Phone # 410-795-5670

Fogle's Septic Clean, Inc.
580 Obrecht Road
Sykesville, MD 21784

PLEASE DETACH AND RETURN TOP PORTION WITH PAYMENT

P.O. No.	Due Date	Rep	Ship Date
	7/26/2018	JWB	7/25/2018

Description	Qty	Rate	Amount
EMERGENCY PUMPING		240.00	240.00
EMERGENCY FEE PAID DIRECTLY TO DRIVER \$100			0.00
SYSTEM IS FAILING			
PAID BY CREDIT CARD			

Thank you for your business.

Total \$240.00

1.5% interest will be charged monthly on all unpaid balances after 30 days. \$30 CHARGE FOR RETURNED CHECK. RECEIPT DATE STAMPS ARE STRICTLY ENFORCED for ALL DISCOUNTS.

Payments/Credits -\$240.00

Billing Questions - call 410-795-5670

Customer Total Balance \$0.00

Fogle's Septic Clean, Inc.

580 Obrecht Road
Sykesville, MD 21784

Invoice Date
10/8/2018

Invoice #
297604

INVOICE

**PLEASE PAY
THIS AMOUNT**

\$0.00

Make checks payable to: **Fogle's Septic Clean, Inc.**

Bill To:

RAMACHANDRA SISTA
8447 ROLLING RIDGE CT
ELLICOTT CITY, MD 21042

Service Address

RAMACHANDRA SISTA
8447 ROLLING RIDGE CT
ELLICOTT CITY, MD 21042

Phone # 410-795-5670

Fogle's Septic Clean, Inc.
580 Obrecht Road
Sykesville, MD 21784

PLEASE DETACH AND RETURN TOP PORTION WITH PAYMENT

P.O. No.	Due Date	Rep	Ship Date
	10/8/2018	HLK	10/6/2018

Description	Qty	Rate	Amount
EMERGENCY PUMPING		245.00	245.00
FAILING SYSTEM PER HARRY, TOILET RUNNING			
\$100 PAID TO DRIVER			
PAYMENT ~ THANK YOU CHECK #1442			-245.00

	Total	\$0.00
1.5% interest will be charged monthly on all unpaid balances after 30 days. \$30 CHARGE FOR RETURNED CHECK. RECEIPT DATE STAMPS ARE STRICTLY ENFORCED for ALL DISCOUNTS.	Payments/Credits	\$0.00
Billing Questions - call 410-795-5670	Customer Total Balance	\$0.00