

APPLICATION

SEWAGE DISPOSAL TESTING

MARYLAND STATE DEPARTMENT OF HEALTH

HOWARD COUNTY

ELLICOTT CITY

DISTRICT 5TH

DATE Apr 19 72

TO: THE COUNTY HEALTH OFFICER
ELLICOTT CITY, MARYLAND

I, HEREBY, APPLY FOR THE NECESSARY TESTS IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE DISPOSAL SYSTEM.

PROPERTY OWNER WILLIAM E RICHARDS

ADDRESS _____

CALL MR PECK
PHONE 384 8095
BURTONSVILLE, MD

PROPERTY LOCATION:

SUBDIVISION _____

LOT NO. _____

ROAD AND DESCRIPTION ADJACENT TO TEN OAKS NURSERY AT
TRIDELPHIA RD. APPROX 2 MILES WEST OF
CLARKSVILLE, MD

OCCUPANT _____

PHONE _____

PERSON TO CONSTRUCT SYSTEM _____

ADDRESS _____

PHONE _____

SIZE OF LOT 11 ACRES (APPROX)

TYPE BLDG. NONE

NUMBER OF BEDROOMS _____

IF NOT SINGLE RESIDENCE DESCRIBE _____

SIGNATURE OF APPLICANT John W. Munter

APPROVED BY _____

FOR _____

(KIND OF SYSTEM)

DATE _____

REJECTED BY _____

FOR _____

(KIND OF SYSTEM)

DATE _____

HOLD PENDING FURTHER TESTS RH

DATE _____

REASONS FOR REJECTION OR HOLDING 6/13/72 rejected by RH due to improper stakes

THIS IS NOT A PERMIT

APPLICATION

A 17237

P _____

SEWAGE DISPOSAL TESTING,

MARYLAND STATE DEPARTMENT OF HEALTH

HOWARD COUNTY Septic Tank - 1200 galELLICOTT CITY 5thDISTRICT 5thDATE 7-18-72

Dry Well - 400 sq ft absorbent sidewalk area to begin
below the inlet. Maximum depth permitted
for dry well is 10 1/2 ft below original grade
Locate dry well 130 ft from right side lane and
100 ft from front property line as seen from Tradelphia MS

TO: THE COUNTY HEALTH OFFICER
ELLICOTT CITY, MARYLANDVOIDED BY RH DUE TO
RETEST BY GUERNSEYI, HEREBY, APPLY FOR THE NECESSARY TESTS IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE
DISPOSAL SYSTEM.

PROPERTY OWNER

William E. Richards & WF % Jassq Pack

ADDRESS

15532 Columbia Pike

PHONE

384-8095

PROPERTY LOCATION:

SUBDIVISION

LOT NO. C

ROAD AND DESCRIPTION

S. Side Tradelphia Mill Rd W. of Iron Oaks Rd

OCCUPANT

PHONE

PERSON TO CONSTRUCT SYSTEM

ADDRESS

PHONE

SIZE OF LOT

11 Ac ±

TYPE BLDG.

4 BR

NUMBER OF BEDROOMS

IF NOT SINGLE RESIDENCE DESCRIBE

SIGNATURE OF APPLICANT

Ronald E. Bailey837-0194

APPROVED BY

Robert V. Tamm

FOR

Dry Well

(KIND OF SYSTEM)

DATE

8/10/72

REJECTED BY

FOR

(KIND OF SYSTEM)

DATE

HOLD PENDING FURTHER TESTS

DATE

REASONS FOR REJECTION OR HOLDING

THIS IS NOT A PERMIT

DATE _____