## PERMIT

Repair

SEWAGE DISPOSAL SYSTEM MARYLAND STATE DEPARTMENT OF HEALTH\*

HOWARD COUNTY

BUREAU OF ENVIRONMENTAL HEALTH 992-2330

03-281868

ELLICOTT CITY

DISTRICT\_3rd DATE 12/23/83

Ji	ack Fyock IS PERMITTED TO INSTALL ALTERX
ADDRE	ESS 13775 Triadelphia Road, Glenelg, Md. 21737 PHONE 988-9270
SUBDI	vision ROAD 1015 River Road LOT 3 sect 2
PROPE	ERTY OWNER Mr. James Yim
ADDRE	SS 1015 River Road, Sykesville, Maryland 21784
IF GAR	BAGE GRINDER IS USED INCREASE SEPTIC TANK CAPACITY BY 50% AND ABSORPTION AREA BY 22%.
GARBA	AGE GRINDER? YES NO
SEPTIC	TANK CAPACITY GALLONS NUMBER OF BEDROOMS
RI	EPAIR - Call for inspection when ground is opened up and Sanitarian will
	recommend the repair system.
	BUILDING PERMIT SIGNED
	AND RETURNED
- Go	23 05 BOD 154328- GAVIBGE
PLANS	APPROVED BY Frank A. Skinner DATE 12/21/83
COVER	NO WORK UNTIL INSPECTED AND APPROVED.
NEITHE	R THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM.
NOTE:	IF TRENCH IS USED CALL FOR INSPECTION BEFORE AND AFTER PLACING GRAVEL IN TRENCH
NOTE:	NO DRY WELL SHALL EXCEED 15 FOOT IN DIAMETER. NO ABSORPTION TRENCH TO EXCEED 100 FEET IN LENGTH.
NOTE:	ALL PIPE FROM HOUSE TO SEPTIC TANK MUST BE CAST IRON OR SCHEDULE 40 PVC OR ABS.
PERMIT	VOID AFTER THREE YEARS.
NOTE:	INSTALL STAND PIPE ON SEPTIC TANK AND DRY WELL. STAND PIPES MUST BE 6 INCHES IN DIAMETER, CAST IRON, CONCRETE OR TERRA COTTA, OR
	PVC OR ABS ACCEPTED. IF TOP OF SEPTIC TANK IS DEEPER THAN 3 FEET MANHOLE TO GRADE REQUIRED.

\*INSTALLER IS RESPONSIBLE FOR OBTAINING FINAL APROVAL ON THIS PERMIT

\*CALL 992-2330 FOR INSPECTION OF SEPTIC SYSTEMS.

EH - 2-1082

200 150 HOUSE 100 INDICATE AORTH. - NAME ADJOINING ROADWAY AS BASE LINE.

PERMIT CARD
BUILDING PERMIT SIGNED
SEPTIC TANK, LEVEL CLEANOUTS GRANTER GVA
DISTRIBUTION BOX LEVEL # 1 # 2
TILE FIELD, DEPTHS-6 7-8 FT. TRENCH WIDTH 8 7 FT. #2
GRAVEL DEPTH IN. TOTAL LENGTH 53 3 TT. # 2
NUMBER OF TRENCHES 2 TOTAL BOTTOM ARE \$24 259 -683
SEEPAGE PITS, INSIDE DIAMETERFT. DEPTH BELOW INLETFT.
ABSORBENT AREASQ. FT.
REMARKS LEACHING BED - SUPPOSED TO HAVE 2
FT STONE WHEN FINISHED.
SUIL LOOKS VERT STANDY
water well in backrising
DATE SYSTEM APPROVED 1 125 3 INSPECTOR Paymond Thoules