PERMIT

SEWAGE DISPOSAL SYSTEM

HOWARD COUNTY HEALTH DEPARTMENT

BUREAU OF ENVIRONMENTAL HEALTH

ISSUE DATE

410-313-2640

APPROVAL DATE

Barnard Brothers	IS PERMITTED TO INSTALL ALTER _X	
\DDRESS	PHONE 410-489-7621	
SUBDIVISION Ridgewood LOT NUMBER 26	ADDRESS 13307 Royden Court	
ROPERTY OWNER Earl & Kimberly Scott PROPERTY OWNER'S ADDRESS Same		
SEPTIC TANK CAPACITY EX OK GALLONS		
PUMP CHAMBER CAPACITY GALLONS		
NUMBER OF BEDROOMS 5 w/finished addition		
SQUARE FEET PER BEDROOM /80		
INEAR FEET OF TRENCH REQUIRED		
RENCHES: Trenches to be Z feet wide. Inlet . # feet below original grade. Bottom maximum depth		
OCATION: general feet below original grade. If feet of stone below distribution box.		
REPAIR - PURPOSE - In support of Building Permit #B00126824 Call for inspection when ground is opened so sanitarian canrecommend repair. 1/26/01		
dari for imprection when ground to opened to bunifed fan cantecomment repair. 1/20/01		
(2) 68' TRENCHES DOWNHILL OF	F EXISTING (MR)	
I EX. 90' TRENCH TO BE ABA	PNDONED	
PLANS APPROVED	DATE	
PERMIT VOID AFTER 2 YEARS		
NOTE: CONTRACTOR RESPONSIBLE FOR SCHEDULING A PRE-CONSTRUCTION INSPECTION FOR ALL INSTALLATIONS		

NOTE: TOP OF SEPTIC TANKS ARE TO BE NO DEEPER THAN 3.0 FEET BELOW FINISH GRADE

NOTE: WATERTIGHT SEPTIC TANKS REQUIRED

NOTE: CLEANOUT REQUIRED EVERY 70 FEET OF SEWER LINE AND/OR AT 90° SWEEPS IN LINES FROM HOUSE TO DRAIN FIELDS, 90° ELBOWS ARE NOT ACCEPTABLE Install 4G LP tank

NOTE: ALL PARTS OF SEPTIC SYSTEMS (I.E. TANK, DISTRIBUTION BOX, DRAINFIELDS) TO BE 100 FEET FROM ANY WATER WELL UNLESS OTHERWISE SPECIFICALLY AUTHORIZED BLAG. PERMIR SIGNED

NOTE: NO ABSORPTION TRENCH TO EXCEED 100 FEET IN LENGTH UNLESS SPECIFICALLY AUTHORIZED TO REPURNED 10/17/2001 BOO 132860

NOTE: ALL PIPE FROM HOUSE TO SEPTIC TANK MUST BE CAST IRON OR SCHEDULE 35/40 PVC OR ABS INGROUND FOOL

NOTE: MANHOLE RISERS REQUIRED ON ALL SEPTIC TANKS AND PUMP CHAMBERS

NOTE: DISTRIBUTION BOXES MUST HAVE BAFFLES

NOTE: IF PUMPED SEPTIC SYSTEM REQUIRED, (1) SEPTIC PUMP DETAIL TO BE PROVIDED BY INSTALLER PRIOR TO ISSUANCE OF SEPTIC PERMIT (2) PUMP PERFORMANCE TEST IS NECESSARY PRIOR TO HEALTH DEPARTMENT APPROVAL OF SEPTIC PERMIT

NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM PERMITTEE RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT CALL 410-313-2640 FOR INSPECTION OF SEPTIC SYSTEM

BO0132624

	TRENCH DATA	
KNDEKEL	TRENCH WIDTH	
	TRENCH INLET DEPTH	
	TRENCH BOTTOM DEPTH 8	
	DEPTH OF STONE	
1.0	NUMBER OF TRENCHES 2	
+0	TOTAL TRENCH LENGTH 95 + 140 = 2	
EXTRENCH 23 FD EX. 96'	ABSORBENT AREA_ 920	
DISCONNECTED TO	DISTRIBUTION BOX LEVEL	
=== H-C	BAFFLE IN DISTRIBUTION BOX EX.	
15) OEX. S.T. C/O		
NEW OEX. S.T. C/O	SEPTIC TANK DATA	
	SEPTIC TANKGALLONS	
DECK NEW ADD'N	MANHOLE RISER	
IV EX.	6 INCH INSPECTION PORT	
HOUSE EX.	PUMP CHAMBER DATA	
GAR	PUMP CHAMBER GALLONS	
	MANHOLE RISER	
WELL	ALARM	
ROYDEN)	PUMP PERFORMANCE TEST	
DDE CONSTRUCTION INSPECTION.		
PRE-CONSTRUCTION INSPECTION:		
9/10/-2	(.2)	
INSPECTION COMMENTS: 9/19/07 OK TO COVER (MD)		
	7	
INSPECTOR M. Rifkin DATE SYSTEM APPROVED 9/19/01		
DATE STSTEM APPROVED ////		

