



APPLICATION

FOR PERCOLATION TESTING AND SITE EVALUATION

TEST DATE(S) _____ TEST TIME _____

AGENCY REVIEW: _____

APP 555310-M
DATE 11-12-14

DO NOT WRITE ABOVE THIS LINE

I HEREBY APPLY FOR THE NECESSARY TESTING/EVALUATION PRIOR TO ISSUANCE OF SEWAGE DISPOSAL SYSTEM PERMIT(S) TO:

CHECK AS NEEDED:

- ☒ CONSTRUCT NEW SEPTIC SYSTEM(S)
☐ REPAIR/ADD TO AN EXISTING SEPTIC SYSTEM
☐ REPLACE AN EXISTING SEPTIC SYSTEM

CHECK AS NEEDED:

- ☒ NEW STRUCTURE(S)
☐ ADDITION TO AN EXISTING STRUCTURE
☐ REPLACE AN EXISTING STRUCTURE

CHECK ONE:

- ☒ CREATE NEW LOT(S)
☐ BUILD ON AN EXISTING LOT IN A SUBDIVISION
☐ BUILD ON AN EXISTING PARCEL OF RECORD

IS THE PROPERTY WITHIN 2500' OF ANY RESERVOIR?

- ☐ YES
☒ NO

THE TYPE OF STRUCTURE IS:

- ☒ RESIDENTIAL WITH 4-5 PROPOSED BEDROOMS IN THE COMPLETED STRUCTURE (NOTE **UNKNOWN** IF APPROPRIATE)
☐ COMMERCIAL (PROVIDE DETAIL OF NUMBERS AND TYPES OF EMPLOYEES/ CUSTOMERS ON ACCOMPANYING PLAN)
☐ INSTITUTIONAL/GOVERNMENT (PROVIDE DETAIL OF NUMBERS AND TYPES OF EMPLOYEES/USERS ON ACCOMPANYING PLAN)

PROPERTY OWNER(S) THE WILBUR AND EVELYN HINKLE FAMILY LIMITED PARTNERSHIP (ATTN: PHILLIP HINKLE)

DAYTIME PHONE _____ CELL 443-864-7470 FAX 410-223-4341

MAILING ADDRESS 13915 KENNARD ROAD GLENELG MD 21737
STREET CITY/TOWN STATE ZIP

APPLICANT WILLIAMSBURG GROUP LLC, BOB CORBETT

DAYTIME PHONE _____ CELL 410-977-3343 FAX 410-997-4358

MAILING ADDRESS 5485 HARPERS FARM RD #200 COLUMBIA, MD 21044
STREET CITY/TOWN STATE ZIP

APPLICANT'S ROLE: DEVELOPER BUILDER BUYER RELATIVE/FRIEND REALTOR CONSULTANT

PROPERTY LOCATION

SUBDIVISION/PROPERTY NAME HINKLE PROPERTY LOT NO. 93

PROPERTY ADDRESS 12545 SCAGGSVILLE RD HIGHLAND MD
STREET TOWN/POST OFFICE

TAX MAP PAGE(S) 40 GRID _____ PARCEL(S) 93 PROPOSED LOT SIZE 50,000-60,000 SF
1 AC +/-

AS APPLICANT, I UNDERSTAND THE FOLLOWING: THE SYSTEM INSTALLED SUBSEQUENT TO THIS APPLICATION IS ACCEPTABLE ONLY UNTIL PUBLIC SEWERAGE IS AVAILABLE. THIS APPLICATION IS COMPLETE WHEN ALL APPLICABLE FEES AND A SUITABLE SITE PLAN HAVE BEEN RECEIVED. I ACCEPT THE RESPONSIBILITY FOR COMPLIANCE WITH ALL M.O.S.H.A. AND "MISS UTILITY" REQUIREMENTS. APPROVAL IS BASED UPON SATISFACTORY REVIEW OF A PERC CERTIFICATION PLAN.

TEST RESULTS WILL BE MAILED TO APPLICANT.

SIGNATURE OF APPLICANT

HOWARD COUNTY HEALTH DEPARTMENT, BUREAU OF ENVIRONMENTAL HEALTH, WELL AND SEPTIC PROGRAM
7178 COLUMBIA GATEWAY DRIVE COLUMBIA, MARYLAND 21046 (410) 313-2640 FAX (410) 313-2648
TDD (410) 313-2323 TOLL FREE 1-877-4MD-DHMH

Proposed Lot 7 6

A/P

(7D)

0.4' dk brn L
to red L
thick platy
3.2' red & red-brn
sl. thick platy
many mica
33' red-yel, dk brn
& brn-yel
ls, thick platy
many mica
9' dk, grey-brn
& very pale brn
ls, thick platy
few mica
12'

(7E)

0.4' dk brn
thick platy
12' red L
thick platy

North

wooded

7A

Hay field

7B

7E

7D

7C

(7C)

0.4' dk brn L
thick platy
22' red L 3' sbk
to 3' sbk
red & brn L
& dk grey-brn
ls, many mica
2.8' alternating
strata of
red-yel, red
& dk, grey-brn
ls, many mica
and
red-yel ls
common mica
C3p (very pale brn)
dipping
to SE
12'

(7B)

0.4' dk brn L
thick platy
12' red L, thick
platy
2.9' red-yel
& pale brn L
thick platy
many mica
4.4' red-yellow
& very pale brn
ls, thick platy
many mica
8' water seeps
red-yel & dk, grey-brn
ls, many mica
thick platy
m3p (dk brn, Ha)
Fe

DATE	TEST #	DEPTH	START	BREAK 1" DROP	STOP 2" DROP	TIME OF 2ND INCH	P/F/H
5/12/15	7D	4.6'	10:50	10:52	10:56	4	P
5/12/15	7C	5.5'	11:23	11:25	11:28	3	P
5/12/15	7E	5.5'	11:40	11:43	11:48	5	P
5/12/15	7B	4' 8"	11:55	11:57	12:02	5	P
5/12/15	7A	9.5'	Visual	sidewall	3'-5.5'	1.2 gpt / 0+2	P

REMARKS

SANITARIAN R. Bricker BACKHOE Mike Johnson OTHERS _____

TEST HOLES USED IN SDA _____ AVG. PERC TIME _____ SQ. FT/BR _____

TRENCH WIDTH _____ INLET DEPTH _____ MAX. BOT DEPTH _____ EFFECTIVE SW _____

3.5' red-yel
& dk, grey-brn
ls, thin platy
many mica
31' red-yel
& dk, grey-brn
ls, thin platy
many mica
9.5' water seeps
very pale brn
& grey ls
thick platy
many mica
3p (red & red-yel)

