

9106 Philadelphia Road
Suite 106
Rosedale, MD 21237



**HOME LAND
ENVIRONMENTAL
HEALTH LABS**

"Healthy Homes Start Here"

State Certified
Water Quality
Laboratory #353

Certificate of Analysis

Property Information	Customer Information
Property Address: 12031 Scaggsville Road Fulton, MD 20759 Well Tag Number: No visible well tag	Name: Home Land Environmental Phone Number: (443) 995-5385 Email: info@homelandhealthyhomes.com

Field Data		
Date & Time Sampled: 11/16/2018 12:00PM Date & Time Received: 11/16/2018 4:45PM Sampled By: Nick Riehl Sampler ID: 5104NR Sample Location: Basement bathroom sink, Lead – First draw kitchen sink	pH: 5.80 Chlorine Residual: 0.0 Clarity: Clear Sand: None Preservation: Cool, 4°C	Well Type: Drilled Well Height: 20" Cap Type: 2-piece Casing: Metal Conduit: N/A
Water Conditioning: Sediment Filter, Acid Neutralizer		

Parameter	Method	Result	Pass/Fail	Units	MCL	RL	Analyst	Date of Analysis
Total Coliform	Colitag	Absent	Pass	Per/100mL	Present	1.0	KMB	11/18/2018
E. Coli	Colitag	Absent	Pass	Per/100mL	Present	1.0	KMB	11/18/2018
Nitrate+Nitrite	EPA 353.2	14.8	Fail	mg/L	10.0	0.5	KMB	11/17/2018
Nitrate	EPA 353.2	14.8	Fail	mg/L	10.0	0.5	KMB	11/17/2018
Nitrite	EPA 353.2	ND	Pass	mg/L	1.0	0.1	KMB	11/17/2018
Turbidity	EPA 180.1	ND	Pass	NTU	10.0	0.5	KMB	11/19/2018
Iron	H 8008	ND	Pass	mg/L	0.3	0.05	KMB	11/19/2018
Lead	PT 1001	0.354	Fail	mg/L	0.015	0.005	KMB	11/19/2018

Approved By: Kevin Barnaba Kevin Barnaba, Lab Director

Report Date: 11/19/2018

Environmental Testing Lab Inc.

108 Old Solomons Island Rd
Annapolis, MD 21401



3430 Rockefeller Ct
Waldorf, MD 20602

State Certified Water Quality
Laboratory # 106

State Certified Water Quality
Laboratory # 139

Certificate of Analysis

Water Doctor MD Water Conditioning
10983-E Guilford Road
Annapolis Junction, MD 20701

Project
Date Received 12/20/2018
Date Reported 12/24/2018

This report is the sole property of Water Doctor-MD Water Conditioning. Any questions about the report MUST be directed to Water Doctor-MD Water Conditioning at (410) 792-0327.

Environmental Testing Lab is not at liberty to discuss this report without written consent from Water Doctor-MD Water Conditioning.

Sample No: 167304-01 Sampled: 12/19/2018 9:25:0 Sampler: VBurtis6118VB (Exp. 2/12/2020)
Location: 12031 Scaggsville Road Preservation: H2SO4, pH < 2
 Fulton, MD 20759 Sample Point: R/O Unit

Parameter	Method	Result	Qualifiers	Units	RL	Test Date	Analyst
Nitrate + Nitrite as N	EPA 353.2	2.8		mg/l	1	12/21/2018	DB-139

EPA Maximum Contaminate Level for Nitrate/Nitrite is 10.0 mg/l

Approved By

Daniel J. Brumsted, Laboratory Director

Annapolis

Ph 410-224-4304 Fax 443-926-0586

Waldorf

Ph 410-224-4304 Fax 443-926-0586