

STATE OF MARYLAND
WATER RESOURCES ADMINISTRATION
JAMES STATE OFFICE BLDG., ANNAPOLIS, MD. 21401

WELL COMPLETION REPORT

FILL IN THIS FORM COMPLETELY

COUNTY NUMBER

DATE RECEIVED (WRA USE ONLY)

DATE WELL COMPLETED Sept 24 1964

DEPTH OF WELL 300

(TO NEAREST FOOT)

PERMIT NO. FROM "PERMIT TO DRILL WELL"

DRILLERS IDENTIFICATION NO. 42

OWNER John W. Hunt

STREET OR RFD 7 W. 1st St.

FIRST NAME John

POST OFFICE Ellicott City

WELL LOG

STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING

DESCRIPTION (USE ADDITIONAL SHEETS IF NECESSARY)	FEET		CHECK IF WATER BEARING
	FROM	TO	

GROUTING RECORD

WELL HAS BEEN GROUTED (CIRCLE APPROPRIATE BOX) YES ☒ NO ☐

TYPE OF GROUTING MATERIAL (CIRCLE BOX): CEMENT ☒ BENTONITE CLAY ☐

NO. OF BAGS 200 NO. OF POUNDS 4000

GALLONS OF WATER 100

DEPTH OF GROUT SEAL (TO NEAREST FOOT)

FROM 48 FT. TO 58 FT.

(ENTER 0 IF FROM SURFACE)

CASING RECORD

CASING TYPES: INSULT ☒ STEEL ☐ CONCRETE ☐

APPROPRIATE CODE BELOW: PL ☒ OT ☐

MAIN CASING TYPE PL NOMINAL DIAMETER TOP (MAIN) CASING (NEAREST INCH) 6 TOTAL DEPTH OF MAIN CASING (NEAREST FOOT) 70

OTHER CASING (IF USED)

DIAMETER (INCH) 4 DEPTH (FEET) FROM 0 TO 10

SCREEN RECORD

SCREEN TYPE OR OPEN HOLE: (CIRCLE APPROPRIATE CODE BELOW) ST ☒ BR ☐ HO ☐

STEEL ☒ BRASS OR BRONZE ☐ PL ☐ OT ☐

PLASTIC ☐ OTHER ☐

C 2 (SEQ. NO.)

DEPT (NEAREST WHOLE FOOT) FROM 1 TO 21

1 1 2 15 3 21

2 23 3 28 4 30 5 36

3 38 4 41 5 45 6 47 7 51

SLOT SIZE 1. 2. 3.

DIAMETER OF SCREEN 5 (NEAREST INCH) FROM TO

GRAVEL PATH

IF WELL DRILLED W/ A FLOWING WELL CIRCLE BOX ☒

WRA USE ONLY (NOT TO BE FILLED IN BY DRILLER)

LOG INDICATION: T ☐ F ☐ W ☐

74 75 76 OTHER DATA AVAILABLE

PUMPING TEST

HOURS PUMPED (TO NEAREST HOUR) 8

PUMPING RATE (GALLONS PER MINUTE TO NEAREST GALLON) 1

METHOD USED TO MEASURE PUMPING RATE Bucket

WATER LEVEL (DISTANCE FROM LAND SURFACE)

BEFORE PUMPING 80 (NEAREST FOOT)

WHEN PUMPING 300 (NEAREST FOOT)

TYPE OF PUMPED USED (CIRCLE APPROPRIATE BOX)

AIR ☐ PISTON ☐ TURBINE ☐

CENTRIFUGAL ☐ ROYALTY ☐ OTHER (DESCRIBE BELOW) ☐

JET ☐ SUBMERSIBLE ☐

PUMP INSTALLED

TYPE OF PUMP (WRITE APPROPRIATE LETTER IN BOX - SEE ABOVE: A, C, J, P, R, S, T, O)

DRILLER WILL INSTALL PUMP (CIRCLE APPROPRIATE BOX) YES ☐ NO ☐

CAPACITY:

GALLONS PER MINUTE (TO NEAREST GALLON)

PUMP HORSE POWER

PUMP COLUMN LENGTH (NEAREST FOOT) 45

CASING HEIGHT (CIRCLE APPROPRIATE BOX AND ENTER CASING HEIGHT)

+ ABOVE LAND SURFACE (NEAREST FOOT)

- BELOW

LOCATION OF WELL ON LOT

SHOW PERMANENT STRUCTURE SUCH AS BUILDINGS, SEPTIC TANKS, AND/OR OTHER LAND MARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL).

CIRCLE APPROPRIATE BOXES

☐ A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED

☐ E ELECTRIC LOG OBTAINED

☐ P TEST WELL CONVERTED TO PRODUCTION WELL

I HEREBY CERTIFY THAT I HAVE COMPLIED WITH ALL CONDITIONS STATED ON THE ABOVE-CAPTIONED "PERMIT TO DRILL WELL", AND THAT INFORMATION CONTAINED IN THIS REPORT IS TRUE, ACCURATE, AND COMPLETE TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF.

DRILLER'S NAME

RELEASE DATE

SIGNATURE