

APPLICATION

A 23917

P _____

SEWAGE DISPOSAL TESTING

STATE OF MARYLAND - DEPARTMENT OF HEALTH AND MENTAL HYGIENE

HOWARD COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SERVICESP O BOX 476, ELLICOTT CITY, MARYLAND 21043
TELEPHONE: 465-5000, EXT. 356DISTRICT 3DATE 9/10/76

*3/30/77 Backhoe had not
shown up by 2:15 pm. WWZ.*
*4/27/77
1:30 p.m.*

TO: THE COUNTY HEALTH OFFICER
ELLICOTT CITY, MARYLANDI, HEREBY, APPLY FOR THE NECESSARY TEST IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE
DISPOSAL SYSTEM.PROPERTY OWNER Harry E. MartinsonADDRESS 19 Powder Horn Drive, Wayne, New Jersey

07470

PHONE

same Mrs. O'Neil
1-942-1200

PROPERTY LOCATION:

SUBDIVISION Wooded AcresLOT NO. 4 AROAD AND DESCRIPTION Thompson Drive off Route 144SIZE OF LOT 7.1347 acresTYPE BLDG. 3 or 4

NUMBER OF BEDROOMS

IF NOT SINGLE RESIDENCE DESCRIBE

(Single Fmly. Dwllg.)

THE SYSTEM INSTALLED UNDER THIS APPLICATION IS ACCEPTABLE ONLY UNTIL PUBLIC
FACILITIES BECOME AVAILABLE.SIGNATURE OF APPLICANT /s/ Harry E. Martinson, Jr.

APPROVED BY _____ FOR _____ DATE _____

(KIND OF SYSTEM)

REJECTED BY H. H. Z. FOR any system DATE 4/27/77

(KIND OF SYSTEM)

HOLD PENDING FURTHER TESTS WWZ DATE 10/14/76REASONS FOR REJECTION OR HOLDING Water in all holes. May possibly be testedfor drainfields in Mar-Apr. season.* 4/27/77. High water table — water @ 8' on highest knoll* 5/2/80 on lot. High water table. Tests near RYTO Fence — water 5'-6' from**THIS IS NOT A PERMIT**surface
C.B.J.

APPLICATION

A 23917

P _____

SEWAGE DISPOSAL TESTING

STATE OF MARYLAND - DEPARTMENT OF HEALTH AND MENTAL HYGIENE

HOWARD COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SERVICESP. O. BOX 476, ELLICOTT CITY, MARYLAND 21043
TELEPHONE: 465-5000, EXT. 356DISTRICT 3DATE 9/10/76TO: THE COUNTY HEALTH OFFICER
ELLICOTT CITY, MARYLANDI, HEREBY, APPLY FOR THE NECESSARY TEST IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE
DISPOSAL SYSTEM.PROPERTY OWNER Harry E. MartinsenADDRESS 19 Powder Horn Drive, Wayne, New Jersey PHONE 07470

PROPERTY LOCATION:

SUBDIVISION Wooded Acres LOT NO. 4 AROAD AND DESCRIPTION Thompson Drive off Route 144SIZE OF LOT 7.1347 acres TYPE BLDG. 3 or 4IF NOT SINGLE RESIDENCE DESCRIBE _____
NUMBER OF BEDROOMS
(Single Fmly. Dwlg.)THE SYSTEM INSTALLED UNDER THIS APPLICATION IS ACCEPTABLE ONLY UNTIL PUBLIC
FACILITIES BECOME AVAILABLE.SIGNATURE OF APPLICANT /s/ Harry E. Martinsen, Jr.APPROVED BY _____ FOR _____ DATE _____
(KIND OF SYSTEM)REJECTED BY _____ FOR _____ DATE _____
(KIND OF SYSTEM)

HOLD PENDING FURTHER TESTS _____ DATE _____

REASONS FOR REJECTION OR HOLDING _____

THIS IS NOT A PERMIT



23917

INDICATE NORTH. - NAME ADJOINING ROADWAY AS BASE LINE.

DATE	TEST NO.	DEPTH	PRE-WET		TEST - 1" DROP		TIME
			START	STOP	START	STOP	
10/14/76	①	10'	Water @	7'			
	2	10'	Water @	10'			
	3	12'	Water @	11'			
	4	12 1/4'	Water @	10'			
4/29/77	5	3 1/4'	2:24	2:30	2:30	2:40	10
	5-A						
	5-B	8 1/2'	Water				
	6	4 1/4'	Not Perked				
	6-A	7'	Water				
	7	Water @ 3'					
	8	7 1/2'	Water				
	9	8'	Water (as per Brittingham's crew)				

REMARKS

7 appears to, same contours as 5

TYPE OF SOIL

Sandy, wet.

TESTED BY

W. J. R.

ALSO PRESENT:

Greiner, Jr.
Brittingham Co.