

APPLICATION

PERCOLATION TESTING

A 49237

P _____

HOWARD COUNTY HEALTH DEPARTMENT
BUREAU OF ENVIRONMENTAL HEALTH
P.O. BOX 476 ELLICOTT CITY, MARYLAND 21043
TELEPHONE 461-9933

DISTRICT _____

DATE 5/18/93

TO: THE COUNTY HEALTH OFFICER
ELLICOTT CITY, MARYLAND

I, HEREBY, APPLY FOR THE NECESSARY TEST IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE DISPOSAL SYSTEM.

PROPERTY OWNER Edgewood Farm Inc. KRECKEL

ADDRESS P.O. Box 189 Glenelg 21738 PHONE (410) 531-3455

PROSPECTIVE BUYER Land Marketing Consultants Inc.

ADDRESS 10805 Hickory Ridge Col 21044 St.210 PHONE (410) 992-5263

PROPERTY LOCATION:

SUBDIVISION Cattail Creek Country Club LOT NO. (old) 31 Final #49

ROAD AND DESCRIPTION Sycamore Valley Run 200 feet North of Barn

BLDG. PERMIT SIGNED

~~AND RETURNED~~ 7-23-92
Serial # B0106962

TAX MAP 21 PARCEL # _____

SIZE OF LOT 4.317 TYPE BLDG Single Family - 4 Bm
(SINGLE FAMILY DWELLING OR COMMERCIAL)

THE SYSTEM INSTALLED UNDER THIS APPLICATION IS ACCEPTABLE ONLY UNTIL PUBLIC FACILITIES BECOME AVAILABLE. I FULLY UNDERSTAND THE
FEE CONNECTED WITH THE FILING OF THIS PERC TEST APPLICATION IS NON-REFUNDABLE UNDER ANY CIRCUMSTANCES. I ALSO AGREE TO COMPLY
WITH ALL M.O.S.H.A. REQUIREMENTS IN TESTING THIS LOT.

(SIGNATURE OF APPLICANT) [Signature]

APPROVED BY _____ FOR _____ DATE _____

REJECTED BY _____ FOR _____ DATE _____

HOLD PENDING FURTHER TESTS _____ DATE _____

REASONS FOR REJECTION OR HOLDING _____

HD-216

THIS IS NOT A PERMIT

Hand-drawn survey map of a 5x5 grid. The map includes the following annotations:

- Top Left:** "LOT 31" with an arrow pointing to a circled "31".
- Top Center:** "150' ±" with an arrow pointing right.
- Top Right:** "103" with an arrow pointing right, and "102' To fence" with an arrow pointing left.
- Right Edge:** "House" with an arrow pointing to a small rectangle, "Small Tree" with an arrow pointing to a small circle, and "32' 1/2" with an arrow pointing left.
- Grid Annotations:**
 - Row 1, Column 1: "Fence" with an arrow pointing left, "61'" with an arrow pointing left, and "94 1/2'" with an arrow pointing down.
 - Row 1, Column 2: "Fence" with an arrow pointing down.
 - Row 1, Column 3: "3 to 4" with an arrow pointing down, "Rock" with an arrow pointing down, and "32' 1/2" with an arrow pointing left.
 - Row 2, Column 1: "Low" with an arrow pointing down, "10h" with an arrow pointing down, and "94 1/2'" with an arrow pointing down.
 - Row 2, Column 2: "579' ±" with an arrow pointing down.
 - Row 2, Column 3: "3' (Clay)" with an arrow pointing down, "Low" with an arrow pointing down, and "32' 1/2" with an arrow pointing left.
- Left Edge:** "Pasture High" with an arrow pointing up, and "Pasture Low" with an arrow pointing down.
- Bottom Edge:** "Pasture High" with an arrow pointing up, and "Pasture Low" with an arrow pointing down.

RY 97

DATE	TEST NO.	DEPTH	PRE-WET		TEST - 1" DROP		TIME
			START	STOP	START	STOP	
5/25/83	(1)	5'-3"	1:05	1:18	1:18	1:43	25 in
	(# No. 100)	11'-3"	0' to 5 1/2" clay		100 in		100 in
	(2)	'	100 in		100 in		0
	(# No. 100)	11'	0' to 5 1/2" clay		100 in		100 in
	(3)	4 1/2'	2:05	2:07	2:07	2:13	6 in
	(# No. 100)	10'	0' to 1' clay		300 in		100 in
	(4)	6'	4:13	4:15	4:15	4:19	4 in
	(# No. 100)	11'-8"	0' to 5 1/2" clay		100 in		100 in
	(marked)						

④ hole

$\frac{2}{1} - \frac{5}{1} \pm 1$

$\frac{5}{1} - \frac{7}{1}$

11'-8"

6 oam

Note Septu-
area No.
on both sides of
dirt road

REMARKS 5/25 Tests in high area (DOGS at house) shallow tests per above
water - all hole dry!
TYPE OF SOIL Loam (below clay in test hole)
TESTED BY C. B. d ALSO PRESENT 1 Kettler
[2:15 to 3:15 on road switched truck] J. T. Feagles