

Wolf, Kevin

From: Kirit Parmar <kiritparmar123@gmail.com>
Sent: Thursday, April 26, 2018 2:20 PM
To: Williams, Jeffrey; 'Rob Vogel'
Cc: 'Arsy'; Wolf, Kevin
Subject: RE: Fyock Well Ten Oaks

7/16/18

*Met w/ Sank Fyock
on site @ property. He
wanted to bring fresh water in
from outside source to supply
for ex. bathroom sink. I
said this would be OK by health
dept. -Kw

Jeff - Port a Potties is the likely path that will be taken. Either way, the well will not be connected to any other use other than the washing.

Let me know when I can have someone come over to pick up the permit.

Thanks.
Kirit Parmar

NOTICE:

The information contained in this message may be privileged, confidential, and protected from disclosure. If the reader of this message is not the intended recipient, or any employee or agent responsible for delivering this message to the intended recipient, you are hereby notified that any dissemination, distribution, or copying of this communication is strictly prohibited. If you have received this communication in error, please notify us immediately by replying to the message and deleting it from your computer.

From: Williams, Jeffrey [mailto:jewilliams@howardcountymd.gov]
Sent: Tuesday, April 03, 2018 1:25 PM
To: 'Kirit Parmar'; 'Rob Vogel'
Cc: 'Arsy'; Wolf, Kevin
Subject: RE: Fyock Well Ten Oaks

I was just discussing this with Kevin and I realized that we need to know which path you are taking with the trailer before we can issue the well permit:

- We strongly recommend not connecting the water line to the trailer at all (either using port a potties or using some other water source). We can then classify the well as an industrial well and be able to issue the permit right away. We then won't need any potability testing after well construction and we won't have to worry about the sewage disposal.
- If you were to propose the onboard holding tank, the more we think about that, the more we find problems with that setup. Normally, these things are for temporary use only and the water comes from an onboard water tank. If the well line is connected directly, if there is a faucet leak, it could overflow the holding tank. We would also have to go through the whole process of making the well a potable well.

Let us know how you want to proceed before we can mail the permit. Thanks
Jeff

From: Kirit Parmar [mailto:kiritparmar123@gmail.com]
Sent: Monday, April 02, 2018 10:08 PM
To: Williams, Jeffrey; 'Rob Vogel'
Cc: 'Arsy'
Subject: RE: Fyock Well Ten Oaks

Thank you so much, Jeff. Let me know when you mail it, please.

Thanks.
Kirit Parmar

NOTICE:

The information contained in this message may be privileged, confidential, and protected from disclosure. If the reader of this message is not the intended recipient, or any employee or agent responsible for delivering this message to the intended recipient, you are hereby notified that any dissemination, distribution, or copying of this communication is strictly prohibited. If you have received this communication in error, please notify us immediately by replying to the message and deleting it from your computer.

From: Williams, Jeffrey [mailto:jewilliams@howardcountymd.gov]
Sent: Monday, April 02, 2018 1:42 PM
To: 'Kirit Parmar'; 'Rob Vogel'
Cc: 'Arsy'
Subject: RE: Fyock Well Ten Oaks

Will do.

From: Kirit Parmar [mailto:kiritparmar123@gmail.com]
Sent: Thursday, March 29, 2018 10:35 AM
To: 'Rob Vogel'; Williams, Jeffrey
Cc: 'Arsy'
Subject: RE: Fyock Well Ten Oaks

Jeff - I talked to the well drilling company and they said to have it mailed to them directly.
Can you please do that. Their information is:

*Sara V Easterday
Administrative Assistant
L. Franklin Easterday, Inc.
9265 Brown Church Road
Mt. Airy, Md. 21771*

Let me know when it is mailed, so I can talk to them.

Thanks.
Kirit Parmar

NOTICE:

The information contained in this message may be privileged, confidential, and protected from disclosure. If the reader of this message is not the intended recipient, or any employee or agent responsible for delivering this message to the intended recipient, you are hereby notified that any dissemination, distribution, or copying of this communication is strictly prohibited. If you have received this communication in error, please notify us immediately by replying to the message and deleting it from your computer.

From: Rob Vogel [mailto:Rob.Vogel@timmons.com]
Sent: Wednesday, March 28, 2018 5:49 PM
To: 'Williams, Jeffrey'
Cc: Kirit Parmar
Subject: Fyock Well Ten Oaks

Jeff

I believe the well driller will be stopping by to pickup the well permit in regards to the relocation of Fyock's well. I understand Mr. Parmar and Mr. Fyock are working to accommodate one of the two solutions we discussed. Either a holding take under and attached to the trailer or port-a-potty.

Thanks, Rob

Robert H. Vogel P.E.,M.ASCE

VOGEL ENGINEERING + TIMMONS GROUP | www.timmons.com

8407 Main Street | Ellicott City, MD 21043

Office: 410.461.7666 | Fax: 410.461.8961

<https://www.linkedin.com/company/timmons-group>

Your Vision Achieved Through Ours

To send me files greater than 20MB [click here](#)

Wolf, Kevin

From: Wolf, Kevin
Sent: Thursday, December 28, 2017 11:42 AM
To: 'Rob Vogel'
Subject: RE: Fyock Ten Oaks Well Relocation

Yes, it should. But I have not heard of a bathroom without a sink?

From: Rob Vogel [mailto:Rob.Vogel@timmons.com]
Sent: Thursday, December 28, 2017 10:26 AM
To: Wolf, Kevin
Subject: RE: Fyock Ten Oaks Well Relocation

I do not know the answers but will find out. Does it matter if is not used for any type of drinking water but toilet only?
Thanks

Robert H. Vogel P.E.,M.ASCE

VOGEL ENGINEERING + TIMMONS GROUP | www.timmons.com
8407 Main Street | Ellicott City, MD 21043
Office: 410.461.7666 | Fax: 410.461.8961
<https://www.linkedin.com/company/timmons-group>
Your Vision Achieved Through Ours

To send me files greater than 20MB [click here](#).


From: Wolf, Kevin [mailto:KWolf@howardcountymd.gov]
Sent: Thursday, December 28, 2017 9:57 AM
To: Rob Vogel <Rob.Vogel@timmons.com>
Subject: RE: Fyock Ten Oaks Well Relocation

Rob,
Based on your inspection with Sarah last week at the property, we have some concerns that this well may be used as a potable water source as well as for industrial use. In order to proceed with well permit approval and release, we need to confirm with the owner what their water use intent is along with the bus washing. Once we have this information, we will address the well permit status with MDE and also for sampling requirements based on COMAR 26.04.04.30. The permit is ready to release once we receive this information. Thanks

Thanks,

Kevin M. Wolf, LEHS, REHS/RS
Groundwater Mgmt. Sec. Supervisor
Well & Septic Program
Bureau of Environmental Health
8930 Stanford Blvd.
Columbia, MD 21045

(o) 410-313-2645
(f) 410-313-2648



kwolf@howardcountymd.gov

CONFIDENTIALITY NOTICE

This message and the accompanying documents are intended only for the use of the individual or entity to which they are addressed and may contain information that is privileged, confidential, or exempt from disclosure under applicable law. If the reader of this email is not the intended recipient, you are hereby notified that you are strictly prohibited from reading, disseminating, distributing, or copying this communication. If you have received this email in error, please notify the sender immediately and destroy the original transmission.

From: Rob Vogel [<mailto:Rob.Vogel@timmons.com>]
Sent: Thursday, December 21, 2017 7:02 PM
To: Wolf, Kevin
Subject: RE: Fyock Ten Oaks Well Relocation

Good for tomorrow. Thanks

Robert H. Vogel P.E., M.ASCE

VOGEL ENGINEERING + TIMMONS GROUP | www.timmons.com
8407 Main Street | Ellicott City, MD 21043
Office: 410.461.7666 | Fax: 410.461.8961
<https://www.linkedin.com/company/timmons-group>
Your Vision Achieved Through Ours

To send me files greater than 20MB [click here](#).

From: Wolf, Kevin [<mailto:KWolf@howardcountymd.gov>]
Sent: Thursday, December 21, 2017 4:58 PM
To: Rob Vogel <Rob.Vogel@timmons.com>
Subject: Re: Fyock Ten Oaks Well Relocation

I am off in till next Wednesday the 27th but I can cc Sarah in our office to get out there tomorrow if that works.

----- Original message -----

From: Rob Vogel <Rob.Vogel@timmons.com>
Date: 12/21/17 4:54 PM (GMT-05:00)
To: "Wolf, Kevin" <KWolf@howardcountymd.gov>
Subject: RE: Fyock Ten Oaks Well Relocation

Fyock would like to know what day you will be there? Thanks. Have a great Christmas

----- Original message -----

From: "Wolf, Kevin"
Date: 12/21/2017 12:43 PM (GMT-05:00)
To: Rob Vogel
Subject: Re: Fyock Ten Oaks Well Relocation

Thanks Rob.

Yes we will need to perform a site inspection to verify it's location. Is this something we can do on our own? Or does this need to be scheduled?

----- Original message -----

From: Rob Vogel <Rob.Vogel@timmons.com>
Date: 12/21/17 12:33 PM (GMT-05:00)
To: "Wolf, Kevin" <KWolf@howardcountymd.gov>
Subject: Fyock Ten Oaks Well Relocation

Hi Kevin

I hope all is well.

We have staked the well and the letter and plan are attached. Do you need anything additional to release the well permit?

Thanks, Rob

Robert H. Vogel P.E., M.ASCE

VOGEL ENGINEERING + TIMMONS GROUP | www.timmons.com

8407 Main Street | Ellicott City, MD 21043

Office: 410.461.7666 | Fax: 410.461.8961

<https://www.linkedin.com/company/timmons-group>

Your Vision Achieved Through Ours

To send me files greater than 20MB [click here](#).

From: Wolf, Kevin [<mailto:KWolf@howardcountymd.gov>]

Sent: Wednesday, December 13, 2017 12:15 PM

To: Rob Vogel <Rob.Vogel@timmons.com>

Subject: Re: Well Relocation

Yes, this looks fine.

----- Original message -----

From: Rob Vogel <Rob.Vogel@timmons.com>
Date: 12/13/17 12:13 PM (GMT-05:00)
To: "Wolf, Kevin" <KWolf@howardcountymd.gov>
Subject: RE: Well Relocation

Kevin
Was the location shown acceptable?
Thanks! Rob

Robert H. Vogel P.E.,M.ASCE

VOGEL ENGINEERING + TIMMONS GROUP | www.timmons.com
8407 Main Street | Ellicott City, MD 21043
Office: 410.461.7666 | Fax: 410.461.8961
<https://www.linkedin.com/company/timmons-group>
Your Vision Achieved Through Ours

To send me files greater than 20MB [click here](#).

From: Wolf, Kevin [<mailto:KWolf@howardcountymd.gov>]
Sent: Wednesday, December 13, 2017 9:53 AM
To: Rob Vogel <Rob.Vogel@timmons.com>
Subject: RE: Well Relocation

Well stake certification form....

From: Rob Vogel [<mailto:Rob.Vogel@timmons.com>]
Sent: Tuesday, December 12, 2017 4:00 PM
To: Williams, Jeffrey; Wolf, Kevin
Subject: Well Relocation

Jeff and Kevin

Attached is the well relocation plan we last prepared. Looks like well driller never dropped off to you. Please confirm this is ok. Thanks, Rob

Robert H. Vogel P.E.,M.ASCE

VOGEL ENGINEERING + TIMMONS GROUP | www.timmons.com
8407 Main Street | Ellicott City, MD 21043
Office: 410.461.7666 | Fax: 410.461.8961
<https://www.linkedin.com/company/timmons-group>
Your Vision Achieved Through Ours

To send me files greater than 20MB [click here](#).

VOGEL ENGINEERING + TIMMONS GROUP

8407 Main Street Ellicott City, MD 21043
P 410.461.7666 F 410.461.8961 www.timmons.com

LETTER OF TRANSMITTAL

Date: December 22, 2017
To: Howard County Health Department
Attn: Kevin Wolf
cc:
Subject: Fyock Property Ten Oaks and Triadelphia, SDP-17-00
Project Number: 11-03.00

ATTACHED:

# Copies	Description
1	Application
2	Well Relocation Exhibit

Remarks:

Thank You

Matthew Ahearn 

Transmitted by:

Jess King

Received by:

Wolf, Kevin

From: Tracy Rocca-Weikart -MDE- <tracy.rocca-weikart@maryland.gov>
Sent: Tuesday, December 12, 2017 10:54 AM
To: Wolf, Kevin
Cc: Mike Eisner -MDE-; Williams, Jeffrey; 'Norman Lazarus -MDE-'
(norman.lazarus@maryland.gov); John Boris -MDE- (john.boris@maryland.gov)
Subject: Re: Fyock Property Ten Oaks SDP-17-002

Kevin,

I apologize for the confusion but I think we are saying the same thing but not using the same terminology. You contacted our department because they have an industrial (vehicle washwater) wastewater discharge and they need an industrial groundwater wastewater discharge permit to discharge onsite. They have applied for permit for washing but they have yet to send us the results from their analysis of the washwater so we have not issued the permit, yet. It is not an industrial well permit but an industrial wastewater permit so I apologize for getting confused.

As to signing off, that is entirely up to you. As of now, they do not have a permit to discharge washwater onsite. If you feel comfortable signing off on the project, that is up to the County's discretion. We do not need to co-sign.

Hope that clears things up.

Tracy

Tracy Rocca-Weikart
Geologist
Wastewater Permits Program
Water Management Administration
Maryland Department of the Environment
410-537-3659

On Tue, Dec 12, 2017 at 9:52 AM, Wolf, Kevin <KWolf@howardcountymd.gov> wrote:

Tracy,

I am not sure what permits MDE is required to issue here. This is why we brought this up to your group when the well permit was submitted as an industrial well. I need to know if we are 'ok' with signing and releasing the well permit and do you need to co-sign.

A GAP should not be required since the use is low (below 5000gpd) but truthfully all we know of the site is that there are several dozen buses that apparently get washed from time to time, a trailer, and a lot of open space.

Kevin

From: Tracy Rocca-Weikart -MDE- [mailto:tracy.rocca-weikart@maryland.gov]
Sent: Tuesday, December 12, 2017 8:02 AM
To: Wolf, Kevin
Cc: Mahmoud Mahmoud -MDE-
Subject: Re: Fyock Property Ten Oaks SDP-17-002

Kevin,

Our group issues wastewater discharge permits (industrial & municipal - Dr. Tien & Mike Eisner). We are in the same program as the NPDES permits but we don't issue NPDES permits as groundwater permits are state permits not federal permits which is what NPDES refers to (National Pollution Discharge and Elimination System) and is subject to EPA review. That being said, I'm not sure to which permit you are referring. We don't really issue industrial well permits here; we have the well permits issued from the county, but we don't issue them. Are you perhaps referring to a water appropriation permit, i.e. a permit to withdraw water from a well? Those permits are issued from our Water Supply Program.

I have copied Mahmoud Mahmoud, who should be the person that issues water appropriation permits in Howard County. Hopefully, he can answer your questions.

Thanks,

Tracy

Tracy Rocca-Weikart

Geologist

Wastewater Permits Program

Water Management Administration

Maryland Department of the Environment

410-537-3659

On Mon, Dec 11, 2017 at 2:29 PM, Wolf, Kevin <KWolf@howardcountymd.gov> wrote:

Tracy,

Are you referring to an NPDES Permit? And are you ok with issuing the well permit to reflect the groundwater industrial wastewater discharge permit? There is a state signature, does that need to be signed by you or your department?

From: Tracy Rocca-Weikart -MDE- [<mailto:tracy.rocca-weikart@maryland.gov>]

Sent: Monday, December 11, 2017 12:17 PM

To: Wolf, Kevin

Cc: Collins, Sarah

Subject: Re: Fyock Property Ten Oaks SDP-17-002

Kevin,

They have submitted their application but we currently waiting for them to send us an analysis of their wastewater. We will issue the permit once we have received it. Just to be clear, this is a groundwater industrial wastewater discharge permit.

Tracy

Tracy Rocca-Weikart

Geologist

Wastewater Permits Program

Water Management Administration

Maryland Department of the Environment

[410-537-3659](tel:410-537-3659)

On Mon, Dec 11, 2017 at 12:00 PM, Wolf, Kevin <KWolf@howardcountymd.gov> wrote:

Tracy,

Rob Vogel has confirmed that you all are ok with the industrial well permit for this property. Can you please confirm in emails? Thanks

Thanks,

Kevin M. Wolf, LEHS, REHS/RS

Groundwater Mgmt. Sec. Supervisor

Well & Septic Program


Bureau of Environmental Health

8930 Stanford Blvd.

Columbia, MD 21045

(o) 410-313-2645

(f) 410-313-2648



kwolf@howardcountymd.gov

CONFIDENTIALITY NOTICE

This message and the accompanying documents are intended only for the use of the individual or entity to which they are addressed and may contain information that is privileged, confidential, or exempt from disclosure under applicable law. If the reader of this email is not the intended recipient, you are hereby notified that you are strictly prohibited from reading, disseminating, distributing, or copying this communication. If you have received this email in error, please notify the sender immediately and destroy the original transmission.

From: Rob Vogel [<mailto:rvogel@vogeleng.com>]
Sent: Wednesday, July 05, 2017 8:38 AM
To: Wolf, Kevin; Williams, Jeffrey
Cc: Dimmy Zozos; 'Kirit Parmar'
Subject: FW: Fyock Property Ten Oaks SDP-17-002

Kevin and Jeff

We are in the process of obtaining a permit for the wash water discharge. Please see below. Do you require that the new well be installed prior to approval of the SDP? If so, can you release the well permit now? I believe it had been applied for by a well driller but put on hold. We will be resubmitting the SDP with the HOOT system information.

Thanks, Rob

Robert H. Vogel, P.E., M.ASCE

Robert H. Vogel Engineering, Inc.

8407 Main Street

Ellicott City, Maryland 21043

Phone: [410-461-7666](tel:410-461-7666)

FAX: [410-461-8961](tel:410-461-8961)

www.vogeleng.com

From: Tracy Rocca-Weikart -MDE- [<mailto:tracy.rocca-weikart@maryland.gov>]

Sent: Wednesday, July 05, 2017 8:09 AM

To: Rob Vogel

Cc: Kirit Parmar; Dimmy Zozos

Subject: Re: FW: Fyock Property Ten Oaks

Hi Rob,

We've received your application and it is currently being processed. The permit cannot be issued until your application fee is billed. Once the application is entered into the system and we check to make sure everything that is needed is included (map, MSDS for soaps, if applicable, and analyses for TPH & VOCs), we will bill the permittee. Once the application fee is paid, we can then issue the permit.

Meanwhile, we can setup a site visit so that we can explain the permit and take a look at where they're washing. I'm not sure what we have to do with the well approval since our permit is only for the discharge of wash water.

I will check and see where the application is and see if I can speed the process up a little. While you wait for that, we should set up a site visit soon so that the permit can be issued as soon as the application fee is paid. I'm open for most of July so if you'd like to arrange something, that would be great. If you don't need to be there, though, let me know and I'll contact the permittee separately and arrange a meeting myself.

Tracy Rocca-Weikart

Geologist

Wastewater Permits Program

Water Management Administration

Maryland Department of the Environment

410-537-3659

On Tue, Jul 4, 2017 at 1:12 PM, Rob Vogel <rvogel@vogeleng.com> wrote:

Hi Tracy

Could you please acknowledge receipt of the well information? When could we expect approval so that the local Health Department can approve? Per previous discussion and application this well is used to periodically pressure wash off the outside of school busses. Your assistance is greatly appreciated.

Thanks, Rob

Robert H. Vogel, P.E., M.ASCE

Robert H. Vogel Engineering, Inc.

8407 Main Street

Ellicott City, Maryland 21043

Phone: 410-461-7666

FAX: 410-461-8961

www.vogeleng.com

From: Rob Vogel [<mailto:rvogel@vogeleng.com>]

Sent: Monday, June 26, 2017 11:53 AM

To: 'Tracy Rocca-Weikart -MDE-'

Subject: RE: FW: Fyock Property Ten Oaks

Tracy

I wanted to let you know that the application was delivered to MDE Suite 455 (attention Clyde Boatwright instead of you).

Thanks Rob

Robert H. Vogel, P.E., M.ASCE

Robert H. Vogel Engineering, Inc.

8407 Main Street

Ellicott City, Maryland 21043

Phone: 410-461-7666

FAX: 410-461-8961

www.vogeleng.com

From: Tracy Rocca-Weikart -MDE- [<mailto:tracy.rocca-weikart@maryland.gov>]

Sent: Wednesday, December 21, 2016 9:49 AM

To: Rob Vogel

Subject: Re: FW: Fyock Property Ten Oaks

Rob,

If the property owner is washing buses on this property, he will need a permit to properly dispose of his wastewater. Any water that is used in business operations becomes industrial wastewater, even if nothing is added to it. The washwater from rinsing buses may contain oil and grease and other pollutants, even without the addition of soap.

Many of our permittees are small businesses (like body shops, mechanic shops) that do not wash that many cars. It's not the amount of cars but the fact that water is being used in business operations, even though it is just a storage lot.

Any wastewater that is discharged to the waters of the State (this includes all groundwater & surface water) needs a permit. You do not need a permit if the water is not being discharged directly to ground but is going to the sewer or is being collected in a holding tank and hauled offsite to be disposed of properly.

So, yes, your client will need an industrial wastewater permit if he intends to rinse his buses onsite. We have a new general permit for vehicle washing that will probably suit his needs. Please visit <http://bit.ly/16-VW> for more information.

Talking to you about what the owner will need to do is probably best but here are a few details. He will need a dedicated washing/rinsing area and a way to collect the washwater so that it can be tested. It needs to be discharged to the ground in order to qualify for this permit. This means that it cannot be discharged to a storm drain or a tax ditch or a stream. It must go either into the ground (drainfield) or into an infiltration basin or overland flow (onto the ground) provided that the water stays on property and does not discharge into surface waters.

I will be out of the office the next three days but available by phone tomorrow and Friday morning (I'm leaving early today so I'll be unavailable until tomorrow morning). You can reach me on my cell at [301-325-2569](tel:301-325-2569) if you would like to talk to me about this issue. If can't reach me in the next 2 days, I'll be back in the office next Thursday, 12/29.

I hope this helps. Happy Holidays!

Tracy Rocca-Weikart

Geologist

Wastewater Permits Program

Water Management Administration

Maryland Department of the Environment

410-537-3659

On Wed, Dec 21, 2016 at 7:49 AM, Rob Vogel <rvogel@vogeleng.com> wrote:

Good Morning Tracy

I am working with a property owner who is trying to relocate a well on his property. Please see below. The owner basically uses the property to store school buses. They periodically use the well water to wash off the outside of the buses manually. It is not a thorough washing. Kevin Wolf of the How Co Health Department believes we should pursue an industrial permit. He provided a link to permits for Eyre Bus in the vicinity. That operation is a real commercial facility with a vehicle wash system.

Could you please provide insight as to whether we need an industrial well permit and if so, how do we prepare that permit for the use I described. I am also available in the office if you can call me.

Thank you, Rob

Robert H. Vogel, P.E., M.ASCE

Robert H. Vogel Engineering, Inc.

8407 Main Street

Ellicott City, Maryland 21043

Phone: 410-461-7666

FAX: 410-461-8961

www.vogeleng.com

From: Wolf, Kevin [mailto:KWolf@howardcountymd.gov]
Sent: Monday, November 21, 2016 11:02 AM
To: Rob Vogel
Subject: RE: Fyock Property Ten Oaks

Rob,

See the information below from Tracy Rocca-Weikart at MDE. The link describes in detail what needs to be done for Industrial Well permits for NPDES permits. We will probably need this information from the property owner, Fyock not Mr. Parmar.

Kevin

On Fri, Nov 18, 2016 at 3:33 PM, Rocca-Weikart, Tracy <tracy.rocca-weikart@maryland.gov> wrote:

Kevin,

Eyre Bus, Tour & Travel ([13600 Triadelphia Road](#)) has an industrial groundwater discharge permit (to discharge bus washing wastewater) with us. I've attached a copy of the permit to this email so you can take a look at it if you would like. As long as Eyre's is the company to which you are referring, they already have the necessary permits to discharge their washwater onsite.

As to how someone can go about acquiring a permit (for vehicle washing), we have a new general vehicle washing permit. You find more information here: <http://bit.ly/16-VW>. There are also links at the bottom of the page to direct you to more information about other wastewater discharge permits from our department. You can also search for a copy of any our permits at this site: <http://mes-mde.mde.state.md.us/WastewaterPermitPortal/>. This will actually give you a copy of the permit & fact sheet.

I hope this is what you wanted. Let me know if I can help in any other way.

Happy Friday!

Tracy Rocca-Weikart

Geologist

Wastewater Permits Program

Water Management Administration

Maryland Department of the Environment

410-537-3659

On Fri, Nov 18, 2016 at 2:48 PM, Wolf, Kevin <KWolf@howardcountymd.gov> wrote:

Mike/Tracy,

I have a property here in Howard County that we are currently working thru on a replacement well; Industrial well to that fact. The need for the replacement well is a little complicated. Basically the property owner adjacent to this property where this well is located is proposing some onsite septic system changes that influenced the setback distance to the well. This is where I need your guidance...

Originally the existing well was known to be used for bus washing. Since this has been confirmed by the well driller on the application, we cannot assume anything other than what they are proposing. So, my question to you all is do they currently have the correct permits to operate this existing industrial well for bus washing or do they need to apply for one? And if so, how would they go about doing this?

Any help in this is appreciated. Please let me know what information you need. I do not know the well tag for the existing well, but I have attached a site plan for your reference.

Thanks,

Kevin M. Wolf, LEHS, REHS/RS

Groundwater Mgmt. Sec. Supervisor

Well & Septic Program


Bureau of Environmental Health

8930 Stanford Blvd.

Columbia, MD 21045

(o) 410-313-2645

(f) 410-313-2648



kwolf@howardcountymd.gov

CONFIDENTIALITY NOTICE

This message and the accompanying documents are intended only for the use of the individual or entity to which they are addressed and may contain information that is privileged, confidential, or exempt from disclosure under applicable law. If the reader of this email is not the intended recipient, you are hereby notified that you are strictly prohibited from reading, disseminating, distributing, or copying this communication. If you have received this email in error, please notify the sender immediately and destroy the original transmission.

From: Rob Vogel [<mailto:rvogel@vogeleng.com>]
Sent: Thursday, November 17, 2016 11:45 AM
To: Wolf, Kevin
Cc: Collins, Sarah
Subject: RE: Fyock Property Ten Oaks

Sorry. I do not know anything about day care. I will ask owner. We were not aware of a septic system. We were using gis topo but I did go to site recently and there were several port a potties. I will inquire

Sent from my Verizon Wireless 4G LTE Smartphone

----- Original message -----

From: "Wolf, Kevin"

Date:11/17/2016 10:40 AM (GMT-05:00)

To: Rob Vogel

Cc: "Collins, Sarah"

Subject: RE: Fyock Property Ten Oaks

Rob,

This plan is not showing everything we requested. Where is the septic system for this property. Site visits from our office confirm that there is a Day Care facility on this property. Close to where you indicate the replacement well siting there are concrete manhole risers which look to be for a septic tank. Also, where are the underground utilities? Please revise the site plan indicating these pertinent items.

Kevin

From: Rob Vogel [<mailto:rvogel@vogeleng.com>]

Sent: Tuesday, November 15, 2016 4:35 PM

To: Wolf, Kevin

Cc: Collins, Sarah

Subject: RE: Fyock Property Ten Oaks

See attached. Thanks.

Robert H. Vogel, P.E., M.ASCE

Robert H. Vogel Engineering, Inc.

8407 Main Street

Ellicott City, Maryland 21043

Phone: 410-461-7666

FAX: 410-461-8961

www.vogeleng.com

From: Wolf, Kevin [<mailto:KWolf@howardcountymd.gov>]
Sent: Thursday, November 10, 2016 9:24 AM
To: Rob Vogel
Cc: Collins, Sarah
Subject: RE: Fyock Property Ten Oaks

Rob,

We were waiting on an updated well site plan from you. The current well site location is on hold. We visited the property back in September and found some septic components in the proximity of the proposed well location. We followed up with a memo on this to have all septic components located including underground utilities. Sarah issued the memo to the applicant and cc'd you.

Kevin

From: Rob Vogel [<mailto:rvogel@vogeleng.com>]
Sent: Thursday, November 10, 2016 8:00 AM
To: Wolf, Kevin
Subject: Fyock Property Ten Oaks

Kevin

Easterday has submitted a plan to drill a new well on the Fyock Property on Ten Oaks (adjacent to Route 32 right-of-way).

[Click here](#) to complete a three question customer experience survey.

[Click here](#) to complete a three question customer experience survey.

[Click here](#) to complete a three question customer experience survey.

[Click here](#) to complete a three question customer experience survey.

[Click here](#) to complete a three question customer experience survey.

Wolf, Kevin

From: Wolf, Kevin
Sent: Wednesday, December 13, 2017 9:52 AM
To: 'Rob Vogel'
Cc: Williams, Jeffrey
Subject: RE: Well Relocation

Thanks Rob.

Well location looks good. Can you send me a scaled version? You can reduce it to 1" – 100' if that helps. Also, please fill out the well stake certification form once the well site has been staked. From there we will need to perform a quick site inspection to verify its location. Let me know if you have any questions on this.

Kevin

From: Rob Vogel [<mailto:Rob.Vogel@timmons.com>]
Sent: Tuesday, December 12, 2017 4:00 PM
To: Williams, Jeffrey; Wolf, Kevin
Subject: Well Relocation

Jeff and Kevin

Attached is the well relocation plan we last prepared. Looks like well driller never dropped off to you. Please confirm this is ok. Thanks, Rob

Robert H. Vogel P.E.,M.ASCE

VOGEL ENGINEERING + TIMMONS GROUP | www.timmons.com
8407 Main Street | Ellicott City, MD 21043
Office: 410.461.7666 | Fax: 410.461.8961
<https://www.linkedin.com/company/timmons-group>
Your Vision Achieved Through Ours

To send me files greater than 20MB [click here](#).

Wolf, Kevin

From: Wolf, Kevin
Sent: Wednesday, December 13, 2017 12:15 PM
To: Rob Vogel
Subject: Re: Well Relocation

Yes, this looks fine.

----- Original message -----

From: Rob Vogel <Rob.Vogel@timmons.com>
Date: 12/13/17 12:13 PM (GMT-05:00)
To: "Wolf, Kevin" <KWolf@howardcountymd.gov>
Subject: RE: Well Relocation

Kevin
Was the location shown acceptable?
Thanks! Rob

Robert H. Vogel P.E.,M.ASCE

VOGEL ENGINEERING + TIMMONS GROUP | www.timmons.com
8407 Main Street | Ellicott City, MD 21043
Office: 410.461.7666 | Fax: 410.461.8961
<https://www.linkedin.com/company/timmons-group>
Your Vision Achieved Through Ours

To send me files greater than 20MB [click here](#).

From: Wolf, Kevin [<mailto:KWolf@howardcountymd.gov>]
Sent: Wednesday, December 13, 2017 9:53 AM
To: Rob Vogel <Rob.Vogel@timmons.com>
Subject: RE: Well Relocation

Well stake certification form....

From: Rob Vogel [<mailto:Rob.Vogel@timmons.com>]
Sent: Tuesday, December 12, 2017 4:00 PM
To: Williams, Jeffrey; Wolf, Kevin
Subject: Well Relocation

Jeff and Kevin

Attached is the well relocation plan we last prepared. Looks like well driller never dropped off to you. Please confirm this is ok. Thanks, Rob

Robert H. Vogel P.E.,M.ASCE

VOGEL ENGINEERING + TIMMONS GROUP | www.timmons.com

8407 Main Street | Ellicott City, MD 21043

Office: 410.461.7666 | Fax: 410.461.8961

<https://www.linkedin.com/company/timmons-group>

Your Vision Achieved Through Ours

To send me files greater than 20MB [click here](#).