

10/31/78
11/1/79
approved 11/1/79
J. Stayer
P 30154
A 18529

PERMIT

SEWAGE DISPOSAL SYSTEM

MARYLAND STATE DEPARTMENT OF HEALTH*

HOWARD COUNTY

ELLICOTT CITY
5th.

DISTRICT

INDEXED

DATE 8/28/79
9/6/79

Jeff Crane Pal Lendine

IS PERMITTED TO INSTALL ☒ ALTER

ADDRESS 143 Nunnery Lane, Catonsville, Md. 21228 PHONE 744-4432

SUBDIVISION ROAD 4670 Ten Oaks Road, Dayton, Md. Lot 14

PROPERTY OWNER Michael MacMurray

ADDRESS 6814 Lenbern Road, Woodlawn, Md., 21207

SPECIFICATIONS 4 Bedrooms / 1000 DUPLEX - 2 TANKS - 1 SYSTEM

SEPTIC TANK CAPACITY ~~1250~~ GALLONS

DRAIN FIELD DEPTH FEET, BOTTOM AREA SQ. FT.

DEEP TRENCH DEPTH FEET, BOTTOM AREA SQ. FT.

Dry Well SEE PAGE PITS ☒ ABSORBENT SIDE-WALL AREA 350 Total absorbant Area in Dry Well

INLET PIPE 3 FT. BELOW ORIGINAL GRADE, MAXIMUM DEPTH 12 FT. BELOW ORIGINAL GRADE

EFFECTIVE DEPTH AT 5 FT. BELOW ORIGINAL GRADE.

LOCATE DISPOSAL AREA 65 FT. FROM right LOT LINE AND 385 FT. FROM rear LOT LINE AS SEEN WHEN
FACING LOT FROM Ten Oaks Road

TRENCH - to be 50 foot long with 330 sq. ft. absorbant area - Trench inlet at

3 1/4 ft. and maximum depth 12 ft. Effective depth at 5 feet. Trench to come off

left side of Dry Well, follow contour of land towards test hole #5 (Left side of
perc area).

PLANS APPROVED BY W..W. Zepp DATE 7/10/73

COVER NO WORK UNTIL INSPECTED AND APPROVED.

NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM.

NOTE: IF TRENCH IS USED CALL FOR INSPECTION BEFORE PLACING GRAVEL IN TRENCH.

NOTE: NO DRY WELL SHALL EXCEED 15 FOOT IN DIAMETER.

NOTE: ALL PIPE FROM HOUSE TO DISPOSAL AREA MUST BE CAST IRON.

PERMIT VOID AFTER THREE YEARS.

NOTE: INSTALL STAND PIPE ON SEPTIC TANK AND DRY WELL. STAND PIPES MUST BE 6 INCHES IN DIAMETER. CAST IRON, CONCRETE OR TERRA
COTTA ACCEPTED.

*INSTALLER IS RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT.

DISTANCES FROM
REAR OF LOT

