

STATE OF MARYLAND WATER RESOURCES ADMINISTRATION TAWES STATE OFFICE BLDG., ANNAPOLIS, MD. 21401 WELL COMPLETION REPORT		THIS REPORT MUST BE SUBMITTED WITHIN 30 DAYS AFTER WELL COMPLETION FILL IN THIS FORM COMPLETELY COUNTY NUMBER A21192 PERMIT NO. FROM "PERMIT TO DRILL WELL" 41-73-11503 28 29 30 31 32 33 34 35 36 37	
SEQUENCE NO. (WRA USE ONLY) 1509 (THIS NUMBER IS TO BE PUNCHED IN COLD 3-6 ON ALL CARDS)		DATE RECEIVED (WRA USE ONLY) 6/2/78 DATE WELL COMPLETED 6/2/78 DEPTH OF WELL 200 (TO NEAREST FOOT)	
OWNER EVANS INC. LAST NAME EVANS		DRILLERS IDENTIFICATION NO. 209 FIRST NAME J. D.	
STREET OR RFD. 5321 Lanthorn Ct.		POST OFFICE Columbia, Maryland 21044	

WELL LOG			WELL DESCRIPTION																				
STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING			GROUTING RECORD WELL HAS BEEN GROUTED (CIRCLE APPROPRIATE BOX) YES ☒ NO ☐ TYPE OF GROUTING MATERIAL (CIRCLE BOX) CEMENT ☒ BENTONITE CLAY ☐ NO. OF BAGS 10 NO. OF POUNDS 950 GALLONS OF WATER 80 DEPTH OF GROUT SEAL (TO NEAREST FOOT) FROM 0 FT. TO 25 FT. (ENTER 0 IF FROM SURFACE)																				
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">DESCRIPTION (USE ADDITIONAL SHEETS IF NECESSARY)</th> <th colspan="2">FEET</th> <th rowspan="2">CHECK IF WATER BEARING</th> </tr> <tr> <th>FROM</th> <th>TO</th> </tr> </thead> <tbody> <tr> <td>Clay</td> <td>0</td> <td>12</td> <td></td> </tr> <tr> <td>Mica Sand</td> <td>12</td> <td>24</td> <td></td> </tr> <tr> <td>Hard Gray Rock</td> <td>24</td> <td>200</td> <td>X</td> </tr> </tbody> </table>			DESCRIPTION (USE ADDITIONAL SHEETS IF NECESSARY)	FEET		CHECK IF WATER BEARING	FROM	TO	Clay	0	12		Mica Sand	12	24		Hard Gray Rock	24	200	X	CASING RECORD Casing Types: INSERT APPROPRIATE CODE BELOW STEEL ☒ CONCRETE ☐ PLASTIC ☐ OTHER ☐ MAIN CASING TYPE S NOMINAL DIAMETER TOP (MAIN) CASING (NEAREST INCH) 6 TOTAL DEPTH OF MAIN CASING (NEAREST FOOT) 25 60 61 62 63 64 65 66 67 68 69 70		
DESCRIPTION (USE ADDITIONAL SHEETS IF NECESSARY)	FEET			CHECK IF WATER BEARING																			
	FROM	TO																					
Clay	0	12																					
Mica Sand	12	24																					
Hard Gray Rock	24	200	X																				
OTHER CASING (IF USED) DIAMETER (INCH) FROM TO 60 61 62 63 64 65 66 67 68 69 70			SCREEN RECORD SCREEN TYPE OR OPEN HOLE (INSERT APPROPRIATE CODE BELOW) STEEL ☒ BRASS ☐ OPEN HOLE ☐ PLASTIC ☐ OTHER ☐ C 2 1 2 3 (SEQ. NO.) 6 DEPTH (NEAREST WHOLE FOOT) FROM 0 TO 200 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100																				

CIRCLE APPROPRIATE BOXES ☒ A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED ☐ E ELECTRIC LOG OBTAINED ☐ P TEST WELL CONVERTED TO PRODUCTION WELL		I HEREBY CERTIFY THAT I HAVE COMPLIED WITH ALL CONDITIONS STATED ON THE ABOVE-CAPTIONED "PERMIT TO DRILL WELL", AND THAT INFORMATION CONTAINED IN THIS REPORT IS TRUE, ACCURATE, AND COMPLETE TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF. DRILLERS NAME Howard Wilson PLEASE PRINT: Howard Wilson SIGNATURE: <i>Howard Wilson</i>	
IF WELL DRILLED WAS A FLOWING WELL (CIRCLE BOX) F WRA USE ONLY (NOT TO BE FILLED IN BY DRILLER) (E.R.O.S.) TELESCOPE CASING ☐ LOG INDICATOR ☐ OTHER DATA AVAILABLE ☐		PUMPING TEST HOURS PUMPED (TO NEAREST HOUR) 6 PUMPING RATE (GALLONS PER MINUTE TO NEAREST GALLON) 4 METHOD USED TO MEASURE PUMPING RATE TRE WATER LEVEL (DISTANCE FROM LAND SURFACE) BEFORE PUMPING 25 (NEAREST FOOT) WHEN PUMPING 17 (NEAREST FOOT) TYPE OF PUMP USED (CIRCLE APPROPRIATE BOX) A AIR ☐ P PISTON ☐ T TURBINE ☐ 27 27 27 C CENTRIFUGAL ☐ R ROTARY ☐ O OTHER (DESCRIBE BELOW) ☐ 27 27 27 J JET ☐ S SUBMERSIBLE ☐ 27 27 PUMP INSTALLED TYPE OF PUMP (WRITE APPROPRIATE LETTER IN BOX - SEE ABOVE: A, C, J, P, R, S, T, O) 28 DRILLER WILL INSTALL PUMP (CIRCLE APPROPRIATE BOX) YES ☐ NO ☒ CAPACITY: GALLONS PER MINUTE (TO NEAREST GALLON) 31 35 PUMP HORSE POWER 37 41 PUMP COLUMN LENGTH (NEAREST FOOT) 43 47 CASING HEIGHT (CIRCLE APPROPRIATE BOX AND ENTER CASING HEIGHT) + ABOVE } LAND SURFACE (NEAREST FOOT) - BELOW } 49 51 LOCATION OF WELL ON LOT SHOW PERMANENT STRUCTURE SUCH AS BUILDINGS, SEPTIC TANKS, AND/OR OTHER LAND MARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL).	