

APPLICATION

SEWAGE DISPOSAL TESTING

A 07521

P _____

MARYLAND STATE DEPARTMENT OF HEALTH

HOWARD COUNTY

ELLICOTT CITY

DISTRICT 2

DATE 10/1-63

750 gallon tank
well - 450 ft bottom area below
the inlet 450 OR
Leaching Bed - *422 ft* bottom area installed at a depth
of *4 to 6 ft* not exceeding *4 1/2 ft* below grade - *This depth includes bottom of gravel*

Place the leaching bed or dry well in the area *75 ft to 105 ft* from the left side of the lot or seen when facing the lot from Thompson Dr and *1.75 ft to 2.10 ft* from the edge of Thompson Dr.

TO: THE COUNTY HEALTH OFFICER
ELLICOTT CITY, MARYLAND

OBTAIN SEWAGE SYSTEM PERMIT FROM

I, HEREBY, APPLY FOR THE NECESSARY TESTS IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE DISPOSAL SYSTEM.

HEALTH DEPT. REC-4500

PROPERTY OWNER

Howard Brosanne Ellicott City Md

ADDRESS

PHONE

PROPERTY LOCATION:

SUBDIVISION

LOT NO.

ROAD AND DESCRIPTION

Thompson Dr - approx 1/4 mile from Rt 40 on right Southern most lot further from Rt 40

OCCUPANT

PHONE

PERSON TO CONSTRUCT SYSTEM

ADDRESS

PHONE

SIZE OF LOT

1 acre plus

TYPE BLDG.

NUMBER OF BEDROOMS 3

IF NOT SINGLE RESIDENCE DESCRIBE

SIGNATURE OF APPLICANT

R. May Brosanne

APPROVED BY

Raymond Hedges

FOR

Leaching Bed or Dry Well
(KIND OF SYSTEM)

DATE

9 Oct 63

REJECTED BY

FOR

(KIND OF SYSTEM)

DATE

HOLD PENDING FURTHER TESTS

DATE

REASONS FOR REJECTION OR HOLDING

10/10/63

Letter with approval and copies of applic. to Brosanne & ma

THIS IS NOT A PERMIT

[illegible]

SOUTHERN MOST
LOT NO. FARTHEST FROM R440

TENNYSON 3-1043-45

TILDEN 8-8869

Coral-Lynn Co.

PLUMBING, HEATING & EXCAVATING

Authorized Sales & Service Contractors on
Myers • Goulds • Deming & Other Water Pumps

GAMBER ROAD

FINKSBURG, MD. June 15, 1965

To: Howard County Health Department-

Ellisott City, Maryland

W. W. WAGNER

Please send permit for Weldon Nickolas Sewage;
Thompson Drive;

Old Brozena property,

Thank You!!

William W. Wagner

*Used this
application
for*

No 5-0890

*Weldons H. Nicholas
& Thomas E. Nicholas*

October 10, 1963

Mr. Howard Brosenne
Ellicott City, Md.

Dear Sir:

Enclosed are the approved copies of your applications.
Take them to the Building Engineer's Office when you apply
for the building permits. Make sure that the house is placed
on the lot in such a position that the sewage can run down
hill to the sewage system.

Very truly yours,

Raymond Hodges,
Sanitarian

RH/dma

ENC. 2

southern most lot