

186
1:30 PM
now up if possible

APPLICATION

PERCOLATION TESTING

HOWARD COUNTY HEALTH DEPARTMENT
BUREAU OF ENVIRONMENTAL HEALTH
P.O. BOX 476 ELLICOTT CITY, MARYLAND 21043
TELEPHONE: 461-9933

A 36723
P _____
DISTRICT 6th election
DATE 3/27/86

TO: THE COUNTY HEALTH OFFICER
ELLICOTT CITY, MARYLAND

I, HEREBY, APPLY FOR THE NECESSARY TEST IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE DISPOSAL SYSTEM.

PROPERTY OWNER Michael A. & Adele G. Robbins

ADDRESS 8070 SAVAGE - Guilford Rd PHONE (301) 725-2151

PROSPECTIVE BUYER _____

ADDRESS _____ PHONE _____

PROPERTY LOCATION: Digger - Souder Builders, - 792-0834

SUBDIVISION _____ LOT NO. _____

ROAD AND DESCRIPTION ON Vollmerhausen Road; Approx 700ft. West of SAVAGE - Guilford Rd in SAVAGE, Md.

TAX MAP 47 ^⑤ PARCEL # 835

SIZE OF LOT 1/2 Acre TYPE BLDG. Single Family dwelling
(SINGLE FAMILY DWELLING OR COMMERCIAL)

THE SYSTEM INSTALLED UNDER THIS APPLICATION IS ACCEPTABLE ONLY UNTIL PUBLIC FACILITIES BECOME AVAILABLE. I FULLY UNDERSTAND THE FEE CONNECTED WITH THE FILING OF THIS PERC TEST APPLICATION IS NON-REFUNDABLE UNDER ANY CIRCUMSTANCES. I ALSO AGREE TO COMPLY WITH ALL M.O.S.H.A. REQUIREMENTS IN TESTING THIS LOT. Michael A. Robbins
(SIGNATURE OF APPLICANT)

APPROVED BY _____ FOR _____ DATE _____

REJECTED BY _____ FOR _____ DATE _____

HOLD PENDING FURTHER TESTS _____ DATE _____

REASONS FOR REJECTION OR HOLDING 4-29-86 Unsatisfactory Perc. Heavy clay layer + high water table. Still

THIS IS NOT A PERMIT

①

10.5'

②

A1-3
ORANGE BROWN
CLAY LOAM
10-20%
FR. WBS
yellow RED
SAND LOAM
10-12% CLAY
FRAGMENTS
30-40%
STRAINDED
ROCK FRAGMENTS
w/ yellow BR
SAND LOAM

Hand-drawn site plan on a grid. The plan shows a proposed driveway (DRAINAGE WAY) on the left, a parking lot (PARK LOT LINE) at the top, and a building layout. Key dimensions and features include:

- Setbacks:** 35' (left), 84' (right), 63' (bottom right), 70' (bottom left), 100' (middle left), 200' (right).
- Building Footprint:** A rectangular building footprint is shown in the center-right, with a width of 84' and a depth of 63'.
- Driveway:** A driveway is shown on the left, with a width of 35' and a depth of 70'.
- Parking Lot:** A parking lot is shown at the top, with a width of 84' and a depth of 100'.
- Other Features:** A "DRAINAGE WAY" is labeled on the left, and a "PARK LOT LINE" is labeled at the top. A "200'" dimension is shown on the right, indicating a setback from the right boundary.
- Area:** The total area is labeled as "0.5 ACRES" in the bottom right corner.

0
4" 113
STICKY OR SILTY LOAM
ONLY 4-9% FEW
ROCK FRAGMENTS
11" 4" 113 BR, ZONES OF
RED YELLOW, SILTY
LOAM, CLAY 4-12%
ROCK FRAGMENTS 20-
50%, 1" W/DEPTH
16" 113
ROCK FRAGMENTS > 50%
W/ LITTLE SOIL COMPOSE-
ITION
11" 113
APPROACHING
HARD BOTTOM

INDICATE NORTH - NAME ADJOINING ROADWAY AS BASE LINE.
Vollmer Hansen Rd.

[illegible]

MAY 13² Public Sewer Working For This Lot. From 11:00 to Here. IF OK'd (CONSTRUCTION).

REMARKS PARENT MATERIAL SANDSTONE

TYPE OF SOIL

5. Abel

TESTED BY

ALSO PRESENT

SENDER BUILDERS / SENDER
SENT 11/11/11 Robbins

APPLICATION

PERCOLATION TESTING

HOWARD COUNTY HEALTH DEPARTMENT
BUREAU OF ENVIRONMENTAL HEALTH
P.O. BOX 476 ELLICOTT CITY, MARYLAND 21043
TELEPHONE: 461-9933

A 36723

P _____

DISTRICT 6th election

DATE 3/27/86

TO: THE COUNTY HEALTH OFFICER
ELLICOTT CITY, MARYLAND

I, HEREBY, APPLY FOR THE NECESSARY TEST IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE DISPOSAL SYSTEM.

PROPERTY OWNER Michael A. and Adele G. Robbins

ADDRESS 8070 SAVAGE-Guilford Rd. PHONE (301) 725-2151

PROSPECTIVE BUYER _____

ADDRESS _____ PHONE _____

PROPERTY LOCATION:

SUBDIVISION _____ LOT NO. _____

ROAD AND DESCRIPTION ON Vollmerhausen Road; approx. 700 ft. west of Savage-Guilford Rd in Savage, Md.

TAX MAP _____ PARCEL # _____

SIZE OF LOT 1/2 acre TYPE BLDG. single family dwelling
(SINGLE FAMILY DWELLING OR COMMERCIAL)

THE SYSTEM INSTALLED UNDER THIS APPLICATION IS ACCEPTABLE ONLY UNTIL PUBLIC FACILITIES BECOME AVAILABLE. I FULLY UNDERSTAND THE

FEE CONNECTED WITH THE FILING OF THIS PERC TEST APPLICATION IS NON-REFUNDABLE UNDER ANY CIRCUMSTANCES. I ALSO AGREE TO COMPLY

WITH ALL M.O.S.H.A. REQUIREMENTS IN TESTING THIS LOT. Michael A. Robbins
(SIGNATURE OF APPLICANT)

APPROVED BY _____ FOR _____ DATE _____

REJECTED BY _____ FOR _____ DATE _____

HOLD PENDING FURTHER TESTS _____ DATE _____

REASONS FOR REJECTION OR HOLDING _____

THIS IS NOT A PERMIT

HOWARD COUNTY HEALTH DEPARTMENT

JOYCE M. BOYD, M.D., M.P.H.
COUNTY HEALTH OFFICER



Bureau of Environmental Health
3525 Ellicott Mills Drive
Ellicott City, Maryland 21043

Director - 461-9956
Water & Sewerage, Permits - 461-9933
Community Environmental Health - 461-9944
Technical Services - 461-9955

May 15, 1986

Michael A. Robbins
8070 Savage Guilford Road
Savage, Maryland 20863

RE: Percolation Testing
Robbins Property
Tax Map 47 Parcel 835

Dear Mr. Robbins:

Percolation testing performed on April 29, 1986 on the above referenced property revealed unsatisfactory soil conditions. The presence of a deep clay layer and high water table does not permit the use of on-site sewerage disposal.

If you should have any questions concerning this test, please feel free to contact me at the above address or by calling 461-9933.

Very truly yours,

A handwritten signature in cursive script, reading "Craig Williams".

Craig Williams, Director
Water and Sewerage Program

CW/SA:JR