




Maura J. Rossman, M.D., Health Officer

MEMORANDUM

Sent via email to [pat.crone@carrollfuel.net](mailto:pat.crone@carrollfuel.net)

**TO:** Pat Crone (Carroll Fuel)  
Lisa Ryan (Messick Group Inc.)

**FROM:** Kevin M. Wolf, LEHS, REHS/RS, Supervisor   
Groundwater Mgmt. Sec.  
Well & Septic Program

**DATE:** November 29, 2023

**RE:** 15943 Frederick Road  
Lisbon, MD 21765  
M. 7 P.228 Tax ID: 04-314530 10,890 SQ FT (Demolition of existing  
sfd/building, use space as parking)

---

**This is to advise that the Howard County Health Department recommends issuance of the demolition permit for the above referenced property.**

The existing septic system has been properly located and abandoned. This process was done by Earl Preston Septic on 9/30/2023. The system comprised of a home-made cesspool (see pictures and correspondence).

The existing drilled well that served the dwelling/building was property located and sealed. This task was completed by Easterday Well (George Easterday MWD 040) on 10/17/2023 respectively.

Future plans to rebuild on this parcel may require the development of a percolation certification plan.

**IF ANY WELL OR SEPTIC COMPONENTS ARE FOUND DURING SITE WORK, YOU MUST NOTIFY THIS OFFICE IMMEDIATELY!!**

KMW  
Cc: file

## Meade, Herb

---

**From:** Crone, Pat  
**Sent:** Wednesday, September 20, 2023 7:49 AM  
**To:** Meade, Herb  
**Subject:** Fwd: [-->CHECK<--] 15935 Frederick Rd. Septic Abandonment  
**Attachments:** Frederick rd; IMG\_2098-preview.pvt; IMG\_2096-preview.pvt

[Get Outlook for Android](#)

---

**From:** Doug Dufour <douglas@eprestonjr.com>  
**Sent:** Wednesday, September 20, 2023 7:42:44 AM  
**To:** kwolf@howardcountymd.gov <kwolf@howardcountymd.gov>  
**Cc:** Crone, Pat <Pat.Crone@carrollfuel.net>; Stephanie Dufour <steph@eprestonjr.com>  
**Subject:** [-->CHECK<--] 15935 Frederick Rd. Septic Abandonment

Kevin,

Please see attached photos of the septic abandonment of the referenced property for Carroll Fuel.

The septic system was a homemade septic system as shown in the pictures. The system was dry and did not require pumping.

We placed clean fill dirt and compacted with the hoe bucket. Please let me know if there is anything else you need for the septic abandonment.

Regards,  
Doug Dufour  
Earl E. Preston Jr. Inc. & Whiteford Septic Service  
4045-C Federal Hill Road  
Jarrettsville, MD 21084  
410-557-8100 Office  
410-294-9521 Cell  
410-692-9530 Fax







WATER WELL ABANDONMENT-SEALING REPORT FORM

SUBMIT COPIES OF COMPLETED FORM TO:

- \* COUNTY ENVIRONMENTAL AGENCY (contact MDE, WMA if address needed)
- \* WELL OWNER
- \* MDE, WATER MANAGEMENT ADMINISTRATION, WELL PROGRAM

DATE WELL ABANDONED: 07/20/2023 (month/day/year)


\* PERMIT NUMBER OF ABANDONED WELL (if any) \_\_\_\_\_

\* PERMIT NUMBER OF REPLACEMENT WELL: \_\_\_\_\_

\* PERSON ABANDONING WELL: FRANK SUTOW WELL DRILLER'S LICENSE NUMBER: 11000446  
 CIRCLE: MWD / MSD / MGD

\* OWNER'S NAME: CAROLY FINE

SITE LOCATION MAP



\* WELL LOCATION:  
 COUNTY: Howard  
 NEAREST TOWN: 115001  
 TAX MAP \_\_\_\_\_ BLOCK \_\_\_\_\_ PARCEL \_\_\_\_\_  
 SUBDIVISION: \_\_\_\_\_  
 SECTION: \_\_\_\_\_ LOT: \_\_\_\_\_  
 STREET ADDRESS: 15035 FRODOLOK RD

LATITUDE 39.335545

LONGITUDE 77.070044

LOG OF SEALING MATERIAL

MATERIAL	FEET	
	FROM	TO
<u>Benomite</u>	<u>242</u>	<u>1</u>
<u>TOP SOIL</u>	<u>1</u>	<u>0</u>
VOLUME OF MATERIAL USED		
<u>450 # Benomite mixed for slurry</u>		

\* TYPE OF WELL BEING ABANDONED:  
 DRILLED  JETTED  
 BORED  HAND DUG  
 OTHER (specify) \_\_\_\_\_

\* USE CODE:  
 DOMESTIC  MUNICIPAL/PUBLIC  
 IRRIGATION  INDUSTRIAL  
 TEST/OBSERVATION  GEOTHERMAL

\* TYPE OF CASING:  
 STEEL  PLASTIC  
 CONCRETE  OTHER (specify) \_\_\_\_\_

SIZE OF CASING: 10 INCHES IN DIAMETER

DEPTH OF WELL: 242 FEET DEEP

WAS ANY CASING REMOVED?  YES  NO  
 If yes, length removed, in feet: 4

WAS CASING RIPPED OR PERFORATED?  YES  NO

Frank Sutow 11000446  
 SIGNATURE-MASTER WELL DRILLER OR SUPERVISING SANITARIAN LICENSE#

MWD / MSD / MGS 11-30-23  
 CIRCLE ONE DATE

DRILLER

Pursuant to § 10-624 of the State Govt. Article of the Maryland Code, personal info requested on this form is used in processing this form pursuant to COMAR 26.04.04. Failure to provide the info may result in this form not being processed. You have the right to inspect, amend, or correct this form. The Maryland Department of the Environment is subject to the Maryland Public Information Act. This form may be made available on the Internet via MDE's website and is subject to inspection or copying, in whole or in part, by the public and other governmental agencies, if not protected by federal or State Law.



**Easterday-Wilson**  
WATER SERVICES, LLC  
WELL DRILLING, LLC  
Purifying Water For Life

9265 Brown Church Rd.  
Mt. Airy, MD 21771  
301-831-5170  
[www.ew-water.com](http://www.ew-water.com)

Well Drilling  
Pump Repair & Service  
Constant Pressure Pumps  
Water Treatment  
Geo-Thermal Ground

September 15, 2023

Herb Meade  
Carroll Fuels  
18 Loveton Circle  
Sparks, MD 21152

Re: 15935 Frederick Road  
Well abandonment

Dear Mr. Meade:

Thank you for the opportunity to be of service to you. The price to pull the pump and abandon the well at the above referenced location is \$2,500.00 including up to 20 bags of bentonite. Additional bags will be at the rate of \$37.00/bag. Any additional work for ingress, egress, access, site preservation or restoration, etc. is excluded.

Payment is due at the time of service. The abandonment reports will be sent to the approving authority upon receipt of payment in full.

Please sign in the space provided indicating your approval of the prices and terms and return to me.

Should you have any questions, or need additional information, please feel free to contact me. We are looking forward to working with you on this project in the near future.

Very truly yours,

*Sara V. Easterday*

Sara V. Easterday  
Administrative Assistant

Accepted by: *Herb Meade*

Date: 9/15/2023