

**COMPLETE THIS FORM WHEN DROPPING OFF ANY
CORRESPONDENCE AND/OR PLANS TO THE HOWARD COUNTY
DEPARTMENT OF INSPECTIONS, LICENSES AND PERMITS COUNTER:**

Date: 6/7/23

To: Jose Verios-Kohler Electrical
(Reviewer/Requestor's Name) (Division)

From: Wendy Wallace Franco 410-730-2300
(Your Name, Company Name) (Phone Number)

Subject: Project name Potomac Valley Orthopedic Associates
 Project site address 6240 Dobbin Lane, Columbia MD
 Permit # B23001853 SDP # _____
 Other information pertinent to this project _____

✓ Please check the attachments below that you are submitting with this transmittal:

- Letter of response to address plan review comment letter
- Revised plans and/or revised details: When submitting for a complete re-review, duplicate sets shall be submitted.
- Letter Summarizing Changes
- Energy conservation calculations
- Copies of _____ (be specific).
 Health Department Request DPZ/ DED Request Applicant's Request
- Two sets of single-family model plans to be placed on permanent file: Model Name/ # _____
- Other _____


*Approved. MDE letter sent.
-26*

Contact Person Information: (Required)

Don Matthews 410-730-2300
 Please Print Name Telephone No:
donm@ariumae.com
 E-Mail Address:

PLEASE ASSURE ALL DOCUMENTS AND/OR REVISIONS ARE APPROPRIATELY SIGNED AND SEALED, IF NECESSARY, BY A LICENSED ARCHITECT OR ENGINEER. PLEASE BE ADVISED THAT INSUFFICIENT INFORMATION MAY RESULT IN THE DELAY OF REVIEW BY THE PLANS EXAMINER. THE DEPARTMENT OF INSPECTIONS, LICENSES AND PERMITS WILL CONTACT YOU IF THERE IS A PROBLEM. IN ADDITION, ONCE THE BUILDING PERMIT IS APPROVED BY THE PLAN REVIEW DIVISION AND ALL OTHER REQUIRED SIGNATORY AGENCIES, AND THE BUILDING PERMIT IS READY FOR ISSUANCE, THE PERMIT DIVISION WILL NOTIFY THE APPROPRIATE CONTACT PERSON FOR PERMIT PICK UP. ALL PERMIT STATUS INQUIRIES SHALL BE DIRECTED TO THE PERMIT DIVISION AT 410-313-2455 OPTION #4 OR BY VISITING MYHOWARD.INFO. CODE RELATED QUESTIONS AND PLAN REVIEW INQUIRIES SHALL BE DIRECTED TO THE PLAN REVIEW DIVISION AT 410-313-2436. PLEASE ALLOW A MINIMUM OF FIVE (5) WORKING DAYS FOR ANY PLAN SUBMITTALS TO BE REVIEWED. THANK YOU.

RECEIVED

Received by 

JUN 07 2023

June 05, 2023

TO:

José H. Berríos-Köhler
Department of Inspections, Licenses & Permits
3430 Court House Drive
Ellicott City, MD 21043
410-313-1829

FROM:

Wendy Wallace Franco

RE:

Permit No: B23001853
POTOMAC VALLEY ORTHOPEDIC ASSOCIATES
6240 Dobbin Lane
Columbia, Md 21045

RECEIVED

JUN 07 2023

LICENSES & PERMITS
DIVISION

Jose:

The following is in response to your comments on May 25, 2023. Revised drawings are being submitted with this letter. Our responses correspond to the items listed on your comments.

1. Comply with IECC C405.11
Arium AE Response: Comply. Refer to updated general note 4 on drawing E2, and revised receptacles in Waiting Room (100), Office (102), Reception (101), Break Room (108)
2. Comply with NEC 406.12
Arium AE Response: Comply. Refer to updated general note 5 on drawing sheet E2. Refer to Electrical Note #5 on drawing sheet E1

With thanks,

Wendy Wallace Franco

Wendy Wallace Franco
Arium AE, Inc.