

PERMIT

SEWAGE DISPOSAL SYSTEM

DEPARTMENT OF HEALTH AND MENTAL HYGIENE

P 46509A REPAIR

DISTRICT _____

DATE 10/22/90DATE SYSTEM APPROVED 9/20/90INSPECTOR BZH**HOWARD COUNTY HEALTH DEPARTMENT**

BUREAU OF ENVIRONMENTAL HEALTH

461-9933

INDEXED

Jack Fyock Septic ServiceIS PERMITTED TO INSTALL _____ ALTER XADDRESS 13775 Triadelphia Road, Glenelg, Maryland 21737 PHONE 988-9270SUBDIVISION _____ LOT 4 ROAD 5170 Ten Oaks RoadPROPERTY OWNER Travers Sarah Hinkle

ADDRESS _____

SEPTIC TANK CAPACITY NA GALLONSNUMBER OF BEDROOMS 3125 SQUARE FEET PER BEDROOM 375 FOR 3 BRLINEAR FEET OF TRENCH REQUIRED 47REPAIR - FAILED DRYWELL TO BE REPLACED. CALL FOR INSPECTION WHEN GROUND OPENED SO SA
SANITARIAN CAN RECOMMEND REPAIR.9/20/90 - TRENCH OFF OLD DRY WELL 12 FT DEEP
INLET 4 FT, 8 FT STONE BZHPLANS APPROVED BY Craig Williams cm DATE 09/18/90

COVER NO WORK UNTIL INSPECTED AND APPROVED

NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM

NOTE: CLEANOUT REQUIRED EVERY 70 FEET OF SEWER LINE AND/OR AT 90° SWEEPS IN LINES FROM HOUSE TO DRAIN FIELDS, 90° ELBOWS NOT ACCEPTABLE.

NOTE: ALL PARTS OF SEPTIC SYSTEMS (I.E. TANK, DISTRIBUTION BOX TRENCHES) TO BE 100 FEET FROM WELL (UNLESS OTHERWISE SPECIFICALLY AUTHORIZED)

NOTE: IF DEEP TRENCH(ES) ARE USED CALL FOR INSPECTION BEFORE AND AFTER PLACING GRAVEL IN TRENCH(ES)

NOTE: NO DRY WELL SHALL EXCEED 15 FOOT IN DIAMETER NO ABSORPTION TRENCH TO EXCEED 100 FEET IN LENGTH

NOTE: ALL PIPE FROM HOUSE TO SEPTIC TANK MUST BE CAST IRON OR SCHEDULE 35/40 PVC OR ABS

PERMIT VOID AFTER TWO YEARS

NOTE: INSTALL STAND PIPE ON SEPTIC TANK AND DRY WELL STAND PIPES MUST BE 6 INCHES IN DIAMETER CAST IRON. CONCRETE OR TERRA COTTA OR PVA OR ABS ACCEPTED. IF TOP OF SEPTIC TANK IS DEEPER THAN 3 FEET. MANHOLE TO GRADE REQUIRED.

NOTE: DISTRIBUTION BOXES MUST HAVE BAFFLES

***INSTALLER IS RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT**

46509

