

PERMIT

SEWAGE DISPOSAL SYSTEM

DEPARTMENT OF HEALTH AND MENTAL HYGIENE

HOWARD COUNTY HEALTH DEPARTMENT

BUREAU OF ENVIRONMENTAL HEALTH

461-9933

INDEXED

DATE SYSTEM APPROVED

INSPECTOR

A REPAIR

DISTRICT

DATE

4/18/91

C.B.C.

Jack Fyock

IS PERMITTED TO INSTALL ☒ ALTER ☐

ADDRESS 13775 Triadelphia Road, Gleneden, Maryland 21737 PHONE 988-9270

SUBDIVISION LOT ROAD 9265 Vollerhausen Road

PROPERTY OWNER Lash

ADDRESS

SEPTIC TANK CAPACITY Existing GALLONS

NUMBER OF BEDROOMS 4 (?) Existing

120 SQUARE FEET PER BEDROOM

LINEAR FEET OF TRENCH REQUIRED 60

{ 480 sq ft absorbent area required }
* Old Dry Well can be used also *

REPAIR - DRYWELL FULL. CALL FOR INSPECTION WHEN GROUND IS OPENED SO SANITARIAN CAN REC

RECOMMEND REPAIR.

4/18/91 A.M. L. of H. present at site. C.B.C. If dry well, 15' x 15' inlet
2 1/2' minimum depth 10 1/2' below original grade - 10' from
area of existing D. Well; 8' effective area; or after discussing
with Mr. C. Williams on whom trench 2' wide; inlet 2 1/2' man
"Drywell or trenches" - Prefer D. Well - depth 10 1/2'; 8' of stone.
60' long

PLANS APPROVED BY Craig Williams cm DATE 04/08/91 C.B.C.

COVER NO WORK UNTIL INSPECTED AND APPROVED

NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM

NOTE: CLEANOUT REQUIRED EVERY 70 FEET OF SEWER LINE AND/OR AT 90° SWEEPS IN LINES FROM HOUSE TO DRAIN FIELDS, 90° ELBOWS NOT ACCEPTABLE.

NOTE: ALL PARTS OF SEPTIC SYSTEMS (I.E. TANK, DISTRIBUTION BOX TRENCHES) TO BE 100 FEET FROM WELL (UNLESS OTHERWISE SPECIFICALLY AUTHORIZED)

NOTE: IF DEEP TRENCH(ES) ARE USED CALL FOR INSPECTION BEFORE AND AFTER PLACING GRAVEL IN TRENCH(ES)

NOTE: NO DRY WELL SHALL EXCEED 15 FOOT IN DIAMETER NO ABSORPTION TRENCH TO EXCEED 100 FEET IN LENGTH

NOTE: ALL PIPE FROM HOUSE TO SEPTIC TANK MUST BE CAST IRON OR SCHEDULE 35/40 PVC OR ABS

BLDG. PERMIT SIGNED

PERMIT VOID AFTER TWO YEARS

AND RETURNED

NOTE: INSTALL STAND PIPE ON SEPTIC TANK AND DRY WELL STAND PIPES MUST BE 6 INCHES IN DIAMETER CAST IRON. CONCRETE OR TERRA COTTA OR PVA OR ABS ACCEPTED. IF TOP OF SEPTIC TANK IS DEEPER THAN 3 FEET. MANHOLE TO GRADE REQUIRED.

NOTE: DISTRIBUTION BOXES MUST HAVE BAFFLES

*INSTALLER IS RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT

HD-260(6-90)

*CALL 461-9933 FOR INSPECTION OF SEPTIC SYSTEM.

Pg. 1 of 2



Existence

{ Using Old Dry Well

INLET DEPTH 2 1/2 FT.

TOTAL LENGTH 72 FT.

616 SQ. FT. { Plus old dry well -

EFFECTIVE DEPTH BELOW INLET FT.

Plus Old Dry Well

4/18/91 A.M. OK TO CONTINUE: P.M. Trench in and
y feneched. C.B.B. [Material on side] OK to
ob finish last part of trench - Final C.B.B.

Charles Bryan Streaker