

7-8-85
11:30

03-299597

APPROVED
7/9/85
RH

PERMIT

P 35622
A REPAIR

SEWAGE DISPOSAL SYSTEM

MARYLAND STATE DEPARTMENT OF HEALTH

HOWARD COUNTY
BUREAU OF ENVIRONMENTAL HEALTH
992-2330

ELLICOTT CITY

DISTRICT 3rd

DATE 6/19/85

INDEXED

Dennis Feaga

IS PERMITTED TO INSTALL ☒ ALTER ☐

ADDRESS 1625 Henryton Road, Marriottsville, MD 21104 PHONE 442-5623

SUBDIVISION ROAD 1670 Woodstock Road LOT

PROPERTY OWNER Mr. & Mrs. Moore

1670 Woodstock Road

ADDRESS Woodstock, Maryland 21163

IF GARBAGE GRINDER IS USED INCREASE SEPTIC TANK CAPACITY BY 50% AND ABSORPTION AREA BY 22%.

GARBAGE GRINDER? YES ☐

NO ☒

Purpose of Repair
to fix overflow

SEPTIC TANK CAPACITY GALLONS

NUMBER OF BEDROOMS 3

REPAIR - CALL FOR INSPECTION WHEN GROUND IS OPENED UP SO SANITARIAN CAN RECOMMEND REPAIR.

TRENCH 474 S.F. FOR 3 B.R.
(EXAMPLE 7 FT. STONE 67 FLOW
10 FT DEEP) START TRENCH
12 FT BEHIND HOUSE & 117 FT FROM
THE DRIVEWAY RUN THE TRENCH
TOWARD THE BACK RH

PLANS APPROVED BY C. Williams DATE 6/19/85

COVER NO WORK UNTIL INSPECTED AND APPROVED.

NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM.

NOTE: IF TRENCH IS USED CALL FOR INSPECTION BEFORE AND AFTER PLACING GRAVEL IN TRENCH.

NOTE: NO DRY WELL SHALL EXCEED 15 FOOT IN DIAMETER. NO ABSORPTION TRENCH TO EXCEED 100 FEET IN LENGTH.

NOTE: ALL PIPE FROM HOUSE TO SEPTIC TANK MUST BE CAST IRON OR SCHEDULE 40 PVC OR ABS.

PERMIT VOID AFTER THREE YEARS.

NOTE: INSTALL STAND PIPE ON SEPTIC TANK AND DRY WELL. STAND PIPES MUST BE 6 INCHES IN DIAMETER. CAST IRON, CONCRETE OR TERRA COTTA, OR PVC OR ABS ACCEPTED. IF TOP OF SEPTIC TANK IS DEEPER THAN 3 FEET MANHOLE TO GRADE REQUIRED.

BEDG. PERMIT SIGNED
AND RETURNED 5/24/85

Serial #17217-
PMB

*INSTALLER IS RESPONSIBLE FOR OBTAINING FINAL APROVAL ON THIS PERMIT

*CALL 992-2330 FOR INSPECTION OF SEPTIC SYSTEMS.

EH - 2-1082

P 35622

North

Old FREDRICK RD (Rt 99) Approx. 1 Mile

214'±

WOODSTOCK ROAD

