

8/2/77
9:30 am
8/19/77
ditch map
please

PERMIT

Final
Dy H

P 26402

A

SEWAGE DISPOSAL SYSTEM

MARYLAND STATE DEPARTMENT OF HEALTH
HOWARD COUNTY

01-163272

ELLICOTT CITY

DISTRICT 1st

INDEXED

DATE 7/11/77

Cecil's Back-Hoe Service

IS PERMITTED TO INSTALL ☐ ALTER ☒

ADDRESS 5454 Waterloo Road, Ellicott City, Md.

PHONE 465-4772

A SEWAGE DISPOSAL SYSTEM LOCATED AT

SUBDIVISION

ROAD 6135 Waterloo Road

LOT

PROPERTY OWNER Mr. Martin Deutsch

799-5170

ADDRESS 6135 Waterloo Road, Ellicott City, Md.

SPECIFICATIONS 2 bedrooms

DRAIN FIELD DEPTH FEET, BOTTOM AREA SQ. FT.

SEEPAGE PITS ABSORBENT SIDE-WALL AREA SQ. FT.

SEPTIC TANK CAPACITY 1000 GALLONS

FOR GARBAGE GRINDER, INCREASE DISPOSAL AREA 22% & TANK CAPACITY 50%.

OTHER REPAIR-CALL FOR INSPECTION WHEN GROUND IS OPENED UP SO SANITARIAN CAN

RECOMMEND REPAIR.

- come off dw 10' into 3' max depths
11' Run across lot keep pipe level, at end of trench
insert 5' max depth 15' 60' trench. DJOH 8/3/77

PLANS APPROVED BY Palmer F. Wine

DATE 7/11/77

FILL SEPTIC TANK AND DISTRIBUTION BOX WITH WATER BEFORE CALLING FOR AN INSPECTION. COVER NO WORK UNTIL INSPECTED AND APPROVED.

NEITHER THE HOWARD COUNTY COMMISSIONERS NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM.

26402

PERMIT

SEWAGE DISPOSAL SYSTEM

MARYLAND STATE DEPARTMENT OF HEALTH

HOWARD COUNTY

ELLICOTT CITY

DISTRICT

DATE

IS PERMITTED TO INSTALL

ADDRESS

SEWAGE DISPOSAL SYSTEM LOCATED AT

DIVISION

PROPERTY OWNER

ADDRESS

SPECIFICATIONS

DRAIN FIELD

DEPTH

FEET BOTTOM AREA

SQ. FT.

INDICATE NORTH - NAME ADJOINING ROADWAY - AS BASE LINE

SEWAGE PITS

PERMIT CARD

SEPTIC TANK CAPACITY _____ GALLONS

SEPTIC TANK, LEVEL N/A FOR GARBAGE GRINDER INCREASE DRAINAGE AREA SEE TANK CAPACITY FOR

CLEANOUTS N/A

DISTRIBUTION BOX, LEVEL N/A OTHER _____

TILE FIELD, DEPTH 11' FT. TRENCH WIDTH 2-6' FT.

GRAVEL DEPTH 8" IN. TOTAL LENGTH 40 FT.

NUMBER OF TRENCHES 1 TOTAL BOTTOM AREA 320

SEEPAGE PITS, INSIDE DIAMETER _____ FT. DEPTH BELOW INLET _____ FT.

ABSORBENT AREA _____ SQ. FT.

REMARKS Continue to work permission to add stone while digging w/

owners certification to be sent here RDB 19 Aug 77

Cave ins increased area 1 Aug 77 not needed, OK RDB

UNTIL INSPECTED AND APPROVED

SEPTIC TANK AND DISTRIBUTION BOX WITH WATER BEFORE CALLING FOR AN INSPECTION. COVER IN A

NEITHER THE HOWARD COUNTY COMMISSIONERS NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE

SUCCESSFUL OPERATION OF ANY SYSTEM.

DATE SYSTEM APPROVED 12/13/47 INSPECTOR DPO 4/4