

LAYOUT 9-23-07 INSP 4 _____
 INSP 2 9/24/07 INSP 5 _____
 INSP 3 9/25/07 INSP 6 _____

(logged into Post-Track)

ISSUE DATE: 9/2/09

PERMIT

P 531902

APPROVAL DATE: 9/25/09

Tax ID # 05445426

A 525578 517386

**ON-SITE SEWAGE DISPOSAL SYSTEM
 HOWARD COUNTY HEALTH DEPARTMENT
 BUREAU OF ENVIRONMENTAL HEALTH**

Trinity Quality Homes IS PERMITTED TO INSTALL ALTER

ADDRESS: _____ PHONE NUMBER: 410-480-0023

SUBDIVISION: Fulton Ridge LOT NUMBER: 2

ADDRESS: 12115 Fulton Ridge Drive PROPERTY OWNER: Trinity Quality Homes

SEPTIC TANK CAPACITY (GALLONS): 2000 OUTLET BAFFLE FILTER REQUIRED

PUMP CHAMBER CAPACITY (GALLONS): _____ COMPARTMENTED TANK REQUIRED

NUMBER OF BEDROOMS: 4 APPLICATION RATE: 1.2

SQUARE FOOTAGE OF HOUSE: Unkn *Inlet 4, bottom 8'*

LINEAR FEET OF TRENCH REQUIRED: ~~200~~ 150 LF *2' wide*

TRENCHES:	Trenches to be 2.0 feet wide. Inlet 4.0 feet below original grade. Bottom maximum depth 6.0 feet below grade. Effective area begins at 4.0 feet below original grade. 4 feet of stone below distribution pipe.
LOCATION:	<ol style="list-style-type: none"> 1. Set septic tank per layout inspection. 2. Set distribution box near corner of septic easement southwest of large gum tree. 3. Install 200 feet of trench on contour (5) 40' trenches in south portion of septic easement per layout inspection.
NOTES:	<ol style="list-style-type: none"> 1. Stake septic easement corners and additional corners for layout inspection. 2. Call for layout inspection. 3. Mark utilities 4. Gravel tickets must be available for Environmental Sanitarians.

PLANS APPROVED: Dana Bernard DATE: 9/1/09

- NOTE: PERMIT VOID AFTER 2 YEARS
- NOTE: CONTRACTOR RESPONSIBLE FOR SCHEDULING A PRE-CONSTRUCTION INSPECTION FOR ALL INSTALLATIONS
- NOTE: WATERTIGHT SEPTIC TANKS REQUIRED
- NOTE: ALL PARTS OF SEPTIC SYSTEM SHALL BE 100 FEET FROM ANY WATER WELL
- NOTE: MANHOLE RISERS REQUIRED ON ALL SEPTIC TANKS AND PUMP CHAMBERS

NEITHER THE HOWARD COUNTY COUNCIL OR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM PERMITTEE RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT CALL 410-313-1771 FOR INSPECTION OF SEPTIC SYSTEM

NOT TO SCALE

~~See~~ See Separate Sheet for As-Built

TRENCH/DRAINFIELD DATA

WIDTH 2' INLET 4 BOTTOM 8'
NUMBER OF TRENCHES 3
TOTAL LENGTH 150
ABSORPTION AREA 300 +/- SW
DISTRIBUTION BOX LEVEL Level
DISTRIBUTION BOX BAFFLE Yes
DISTRIBUTION BOX PORT Yes

SEPTIC TANK DATA

SEPTIC TANK I LEVEL Yes
MANUFACTURER Bwylor
CAPACITY 2000 GAL
SEAM LOC Top
TANK LID DEPTH 2'
BAFFLES Yes
BAFFLE FILTER
MANHOLE LOC Front
6" PORT LOC Rear
WATERTIGHT TEST
SLOTTED Yes
DATE ON LID 8-4-09

~~PUMP/SEPTIC TANK LEVEL
MANUFACTURER
CAPACITY GAL
SEAM LOC
TANK LID DEPTH
BAFFLES
BAFFLE FILTER
MANHOLE LOC
6" PORT LOC
WATERTIGHT TEST
SLOTTED
DATE ON LID~~

ROAD NAME

PRE-CONSTRUCTION:

9/23/09 Set Dbox a little bit further into SDA as shown on approved CP plan. Run 3x50' trenches across SDA on center. The trenches should wrap some as you get lower into a drain in the septic area. Bottoms of trenches @ 8'. (KW)

INSTALLATION:

9/24/09 (12pm) Tank set. Dbox set. Top trench being dug now. First load of stone on-site. Med fire, small #2's. Must fines. Some ash but OK to use. OK to continue. (KW)

9/25/09 Trenches completed. System looks good. OK to back fill. (KW)

FINAL INSPECTOR

K. Wally

DATE OF APPROVAL

9-25-2009



HOWARD COUNTY HEALTH DEPARTMENT

31902

DATE
9 / 2 / 09

S

Received From Trinity Quality Homes

PHONE #

For septic permit
12115 Fulton Ridge Dr.

DILPV FAXV
Stacy

Accepted
12/2/09
12/2/09
12/2/09
12/2/09

CASH
 CHECK
NO.
018519

Three hundred ninety - only

Dollars

\$ 346 | 00

Received By [Signature]