



3525 H Ellicott Mills Drive, Ellicott City, MD 21043

(410) 313-2640 Fax (410) 313-2648

TDD (410) 313-2323 Toll Free 1-866-313-6300

website: www.hchealth.org

Penny E. Borenstein, M.D., M.P.H., Health Officer

March 10, 2004

South Carroll Backhoe, Inc.
4410 Salem Bottom Rd
Westminster, MD 21157

REF: Refund for Perc Test Application Fee
Receipt # A520079 Issued on 3/2/04

Gentlemen:

It was determined that a percolation test was not required at 987 Day Road, Sykesville MD on March 9, 2004.

We require from you a written request so that the county can process your refund of \$225 for the above fee. Please include the above receipt number in your correspondence.

If you have any questions you may call the secretary, Ms Mary Lou Briggs, at 410-313-2640.

Sincerely,

A handwritten signature in cursive script that reads 'Frank Alfonso'.

Frank Alfonso, RS

FA/fa

Cc
File

FILE INQUIRY FORM ^{BP 00146305}

3/9/04

Property Address: ~~987 DAY STREET~~ ROAD,
SYKESVILLE, MD 21784.

No perc test was necessary on this date since the drawwell will not be in the way of the proposed addition to the house w/ BP 00146305. New tank (1000 gal min) will be required to meet proper setback ~~of~~ ~~setback~~ (10' from addition & 10' from pool).

South Canall needs to write a request for a refund on the perc test application fee to get the \$225 refund from the county. (A520079) w/ the receipt number paid 3/2/04
A520079. (FA)

3/12/04 New 1250 tank installed and field inspection done by SO on 3/13/04.

Permit BP 00146305 released on this per deck released on this date by (FA)